

जयपुर विकास प्राधिकरण, जयपुर

रूम नं. सी.सी.सी. एफ.एफ. 121, नागरिक सेवा केन्द्र,
इन्दिरा सर्किल, जे.एल.एन. मार्ग, जयपुर-302004

क्रमांक / जविप्रा / अधि.अभि. (विद्युत- I I I) 2021-22 / डी-452

दिनांक: 02.11.2021

बिड आमंत्रण सूचना

बिड संख्या-12 / 2021-22

जयपुर विकास प्राधिकरण द्वारा “**Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur**” जिसकी अनुमानित राशि रु. 1032.62 लाख के लिए ऑनलाईन बिड्स दिनांक 22.11.2021 सायंकाल 6:00 बजे तक आमंत्रित की जाती हैं। निविदा बोली का ऑनलाईन आवेदन व भुगतान जयपुर विकास प्राधिकरण पोर्टल पर करने की अन्तिम तिथि 22.11.2021 को सायंकाल 6.00 बजे तक हैं। निविदा बोली के दस्तावेजों का विस्तृत विवरण www.sppp.rajasthan.gov.in, www.eproc.rajasthan.gov.in and www.jda.urban.rajasthan.gov.in पर देखा जा सकता है।

UBN No. :

निविदा में भाग लेने वालों को निम्न शर्तों की पूर्ति करनी होगी :-

1. निविदादाता जयपुर विकास प्राधिकरण की वेबसाईट www.jda.urban.rajasthan.gov.in पर पंजीकृत हो एवं निविदा में भाग लेने के लिए बोलीदाता को आवेदन करने के लिए दस्तावेज शुल्क, अमानत राशि, आर.आई.एस.एल. प्रोसेसिंग शुल्क ऑनलाईन जमा करानी होगी।
2. ऑनलाईन निविदा प्रस्तुत करने के लिए निविदादाताओं का राजस्थान सरकार के ई-प्रोक्यूरमेंट पोर्टल www.eproc.rajasthan.gov.in पर पंजीकृत हो।

अधिशायी अभियन्ता-(विद्युत-I I I)
जविप्रा, जयपुर।

JAIPUR DEVELOPMENT AUTHORITY

Room No. CCC FF-121, CCC Building,
Ram Kishore Vyas Bhavan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302 004

No:- JDA/EE-(Elect.-III)/2021-22/D- 452

Dated: 02.11.2021

NOTICE INVITING BID

NIB No. : 12/2021-22

Online Bids are invited up-to 6.00 PM of 22.11.2021 for "**Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur**". Estimated cost of Rs 1032.62 Lacs. The last date for applying bid and making online payment on JDA portal is up to 6.00 PM dated 22.11.2021. Details may be seen in the Bidding Document at our office or the website of State Public Procurement Portal website www.sppp.rajasthan.gov.in, www.eproc.rajasthan.gov.in and www.jda.urban.rajasthan.gov.in.

UBN No.

To participate in the bid, bidder has to be:

1. Registered on JDA website www.jda.urban.rajasthan.gov.in for participating in the Bid, the Bidder has to apply for the Bid and pay the Bidding Document Fee, RISL Processing Fee and Bid Security deposit online only.
2. Registered on e-Procurement Portal of Government of Rajasthan www.eproc.rajasthan.gov.in for online e- Bid submission.

**Executive Engineer-(Elect.-III)
JDA, Jaipur**

JAIPUR DEVELOPMENT AUTHORITY

Room No. CCC FF-121, CCC Building, Ram Kishore Vyas Bhawan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur-302004
Telephone: +91-141-2569696 e.mail : bhanwarsingh.jda@rajasthan.gov.in

No. JDA/E.E (Elect.-III)/2021-22/D-452

Date: 02.11.2021

**NOTICE INVITING BID
NIB No. : 12/2021-22**

Name & Address of the Procuring Entity	➤ Name: Executive Engineer (Elect.-III), Jaipur Development Authority ➤ Address: Room No. CCC FF-121, CCC Building, Ram Kishore Vyas Bhawan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302 004
Subject Matter of Procurement	➤ Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur ➤ Job No. 084/2021-22
Bid Procedure	Post Assessment Method (Two Part Envelop), open competitive. eBid procedure at http://eproc.rajasthan.gov.in
Bid Evaluation Criteria (Selection Method)	➤ Post Assessment Method (eg. Least Cost Based Selection (LCBS) - L1)
Websites for downloading Bidding Document, Corrigendum's, Addendums, etc.	➤ Websites : www.sppp.rajasthan.gov.in , www.eproc.rajasthan.gov.in , www.jda.urban.rajasthan.gov.in
Website for online Bid application and payment *	➤ Website: www.jaipurjda.org ➤ For participating in the Bid, the Bidder has to apply for this Bid and pay the Bidding Document Fee, RISL Processing Fee & Bid Security Deposit online only. ○ Bidding document fee: Rs. 1000/- (Rupees One Thousand only) ○ RISL Processing Fee: Rs. 1000/- (Rupees One Thousand only) ○ Requisite Bid Security Deposit Stamp Paper
Estimated Procurement Cost	➤ INR 1032.62 Lacs (Rs. Ten Crore Thirty Two Lacs and Sixty Two Thousand Only)
Bid Security Deposit	All the eligible contractors should be submit bid security declaration on non-judicial stamp of Rs. 50/- as per order issued by finance department (GF&AR) GoR dated 23.12.2020 (Declaration attached with tender document). It is mandatory to submit bid security declaration in prescribed format along with the bid. ➤ Eligibility: Bidder who is E-1 class contractor registered on other Govt. Department and bidder registered as contractor E-1 in JDA
Date/time/place of Pre-Bid	➤ NA
Applying bid and making online payment on JDA portal (www.jda.urban.rajasthan.gov.in)	➤ Start Date: 03.11.2021 at 9.30 AM onwards ➤ End Date: 22.11.2021 at 6.00 PM ➤ In case EMD in form of 50/- Stamp Paper, original Stamp Paper is to be submitted in CCC FF-121, CCC Building, Ram Kishore Vyas Bhawan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302 004 by 23.11.2021 upto 03.00 PM
Bid submission on e-procurement portal of GOR (www.eproc.rajasthan.gov.in)	➤ Start Date: 03.11.2021 at 9.30 AM onwards ➤ End Date: 22.11.2021 at 6.00 PM
**Date/ Time/ Place of Technical Bid Opening	➤ 23.11.2021 at 4.00 PM Room No. CCC FF-121, CCC Building, Ram Kishore Vyas Bhawan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur – 302 004
Date/ Time/ Place of Financial Bid Opening	➤ Will be intimated latter to the technically qualified bidders.
Bid Validity	➤ 120 days from the bid submission deadline
Time Period	➤ 09 Months
Job No.	➤ JDA/EE Electric III/ A & F/2021-2022/Jul/084 Dated : 08/07/2021
Note:	

1. Bidder (authorized signatory) shall submit their offer on-line in Electronic formats both for technical and financial proposal.
2. In case, any of the bidders fails to pay the Tender Fee, BSD, and RISL Processing Fee, online (subject to confirmation), its Bid shall not be accepted.
3. To participate in online bidding process, Bidders must procure a Digital Signature Certificate (Type III) as per Information Technology Act-2000 using which they can digitally sign their electronic bids. Bidders can procure the same from any CCA approved certifying agency, i.e. TCS, Safe crypt, Ncode etc. Bidders who already have a valid Digital Signature Certificate (DSC) need not procure a new DSC. Also, bidders must register on <http://eproc.rajasthan.gov.in> (bidders already registered on <http://eproc.rajasthan.gov.in> before 30-09-2011 must register again).
4. JDA will not be responsible for delay in online submission due to any reason. For this, bidders are requested to upload the complete bid well advance in time so as to avoid 11th hour issues like slow speed; choking of web site due to heavy load or any other unforeseen problems.
5. Bidders are also advised to refer "Bidders Manual Kit" available at eProc website for further details about the e-Tendering process.
6. Training for the bidders on the usage of e-Tendering System (eProcurement) is also being arranged by DoIT&C, GoR on a regular basis. Bidders interested for training may contact e-Procurement Cell, DoIT&C for booking the training slot.
Contact No: 0141-4022688 (Help desk 10 am to 6 pm on all working days) e-mail: eproc@rajasthan.gov.in
Address : e-Procurement Cell, JDA, Yojana Bhawan, Tilak Marg, C-Scheme, Jaipur
7. The procuring entity reserves the complete right to cancel the bid process and reject any or all of the Bids.
8. No contractual obligation whatsoever shall arise from the bidding document/ bidding process unless and until a formal contract is signed and executed between the procuring entity and the successful bidder.
9. Procurement entity disclaims any factual/ or other errors in the bidding document (the onus is purely on the individual bidders to verify such information) and the information provided therein are intended only to help the bidders to prepare a logical bid-proposal.
10. The provisions of RTPPA Act 2012 and Rules thereto shall be applicable for this procurement. Furthermore, in case of any inconsistency in any of the provisions of this bidding document with the RTPP Act 2012 and Rules thereto, the later shall prevail.

➤ The following condition is now the part of the tender document.

🚩 **"If any bidder quotes a rate below than the schedule "G" rates, i.e. rates below than "at par", then the bidder has to deposit the difference amount i.e. difference amount of the rates as per "at par" and quoted "below", as "work Performance Guarantee." This amount has to be deposited before the commencement of work and will be refund after successful completion of DLP Period. Lowest bidder will be issued LOA (Letter of Acceptance) and within 14 days period he has to deposit difference amount in the form of B.G./FDR/NSC. The validity of these shall be for a period three months beyond the date for completion of DLP Period as per requirement. In case of non-deposition of the same in specified period, the Bid Security will be forfeited. In case work is not completed satisfactorily, the "work performance guarantee" will be forfeited and other action will be taken as per Contract Agreement (Order No. प.01(24)नविवि/1/2020 लूज जयपुर, दिनांक 20.09.2021)."**

Executive Engineer- (Elect.-III)
JDA, Jaipur



राजस्थान सरकार
नगरीय विकास एवं आवासन विभाग

क्रमांक:- प.01(24)नविवि/1/2020 लूज

जयपुर, दिनांक:- 20 SEP 2021

आदेश

नगरीय विकास एवं आवासन विभाग के अन्तर्गत विभिन्न विकास कार्यों की निविदाओं में संवेदकों द्वारा बी.एस.आर. दर से कम दर डालने पर अन्तर राशि (AT PAR की दर से जितनी कम है) वर्क परफोरमेंस गारन्टी के रूप में कार्य प्रारम्भ करने से पूर्व ली जाएगी तथा इसे कार्य के सन्तोषजनक रूप से पूर्ण होने के पश्चात दोष निवारण अवधि में कार्य की स्थिति सन्तोषजनक पाए जाने पर, दोषनिवारण अवधि उपरान्त वापस लौटा दिया जावेगा। न्यूनतम दरदाता की बोली नियमानुसार स्वीकृत कर Letter of acceptance (LOA) जारी किया जावेगा एवं बी.एस.आर. दर से कम दर की अन्तर राशि की BG/FDR/NSC प्रस्तुत करने हेतु 14 दिवस का समय दिया जायेगा। अन्तर राशि जमा नहीं कराने पर BID SECURITY की राशि नियमानुसार जब्त कर ली जावे। यदि संवेदक वर्क परफोरमेंस गारन्टी राशि जमा कराने के पश्चात कार्य सन्तोषजनक रूप से पूर्ण नहीं करता है अथवा दोष निवारण अवधि में कार्य में खराबी होती है तो उसकी वर्क परफोरमेंस गारन्टी की राशि जब्त कर ली जावे एवं अनुबन्धानुसार अन्य कार्यवाही भी संपादित की जावे। यह आदेश तुरन्त प्रभाव से लागू किये जाते हैं। यह आदेश उन सभी निविदाओं पर लागू होगा जो कि भविष्य में जारी होगी तथा वे निविदाएं जो इस आदेश के जारी होने की दिनांक तक अप्राप्त हैं, इस सम्बन्ध में निविदा दस्तावेजों में आवश्यक संशोधन तुरन्त संबन्धित उपापन अधिकारी द्वारा किया जावे एवं नवीन सभी निविदाओं में उक्त शर्तों का समावेश किया जाना सुनिश्चित किया जावे।

यह आदेश सक्षम स्तर से अनुमोदित है।


(कुन्जीलाल मीना)
प्रमुख शासन सचिव
नगरीय विकास विभाग

कार्यालय का पता- खाद्य भवन, द्वितीय तल, कमरा नं० 7203, शासन सचिवालय, जयपुर-302005

ई-मेल आई.डी. CEUDHRAJASTHAN@GMAIL.COM

Jaipur Development Authority, Jaipur

Office Order

No. : JDA/IT(1074501)/E-Services/2015-16/D-399

Dated: 4-10-2016

Subject: Payment mechanism for participating in tender.

Jaipur Development Authority has decided to receive Earnest Money Deposit (EMD) (Bid Security), Tender Fee and RISL processing fee online through JDA Portal. The bid security options available in tender for participants are as mentioned below:

A. Payment Options:

Option-1: Bank Guarantee (BG) against EMD / Bid Security

Bidder may opt Bank Guarantee (BG) against EMD (Bid Security), for which bidder requires to prepare BG before applying in the tender. The details of BG requires to be fed on JDA portal before paying balance amount (Tender Fee + RISL Processing Fee). This amount will be paid through **Payment Gateway only**, option to make balance payment through EFT (RTGS/NEFT) will not be available.

If bidder does not opt for BG against EMD, options of making complete payment through Payment Gateway or through EFT (NEFT / RTGS) will be available.

Option-2: Electronic Fund Transfer (EFT: NEFT/RTGS)

If the bidder selects payment mode as EFT (NEFT/RTGS), "**Paying Slip for EFT (NEFT/RTGS)**" will be generated by the system for the complete amount. The payment can be made from **any Bank any Branch** using this Paying Slip through NEFT/RTGS (Claim against payment made through EFT in any other JDA bank account will not be acceptable and bidder stands disqualified from participation in the bid applied for). After successful transaction through NEFT/RTGS, as per the standard procedures it may take 4 to 24 hours in process of confirmation of EFT through Auto-Process depending on the time of EFT done. Therefore, option to make payment through EFT (NEFT/RTGS) will be available till 2 days prior to closing date of bid participation.

Option-3: Payment Gateway (Aggregator)

The facility to make payment through Debit Card, Credit Card, Net banking etc., will be available. User can use this facility from **anywhere any time** till the closing date & time of bid participation.

B. Bid Participation Receipt

After confirming payment, the bidder will get Bid Participation Receipt on the basis of which user will get the payment details along with other details for bidding on e-Procurement portal of GOR.

- In case of BG as the remaining payment will be done through Payment Gateway, on successful transaction the "**Bid Participation Receipt**" will be generated on real time basis.

- In case complete payment is done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis.
- In case complete payment is done through EFT (NEFT/RTGS), on confirmation of payment from ICICI Bank (Auto Process) "Bid Participation Receipt" will be available on Login of Bidder on JDA portal.

This payment mechanism will come into force w.e.f 15/10/2016. Thereafter, old payment mechanism related to NEFT/ RTGS in which the bidder makes direct payment without "Paying Slip for EFT (NEFT/RTGS)" in JDA's bank account will be discontinued.

All procuring entities are hereby directed to clearly mention this procedure in NIB document.


(Pawan Arora)
Secretary

Copy for information and further necessary action to:

1. P.S. to JDC, JDA, Jaipur.
2. P.S. to Secretary, Secretary, JDA, Jaipur.
3. Director (Law / Finance / Town Planning / Engineering-I / Engineering-II), JDA, Jaipur.
4. All Additional Chief Engineer _____, JDA, Jaipur
5. DC (Administration)/DC(Store)/DC (Vehicle), JDA, Jaipur
6. System Analyst, JDA, Jaipur
7. Analyst-cum-Programmer, JDA to ensure integration of software w.e.f 01/10/2016.
8. All Xen _____, JDA, Jaipur.
9. Officer-in-charge, SPPP Portal, Jaipur.
10. OSD (Public Relation) / PRO, JDA, Jaipur.


(Brijesh Kishore Sharma)
OSD (RM)

Bidder has to submitted as proof of deposited amount against the Bid on e-Procurement Portal

Jaipur Development Authority

Bid Participation Receipt

Date & Time : 09/06/2015 05:13 PM

Bid Detail

Bid Id : 6215152001 **Procurement Entity :** XXXXXXXXXXXXXXXX
Bid Title : Testing
Bid Value : 300000 **Bid Opening Place :** Manthan Hall, Jaipur
Development Authority

Bidder Detail

Name of Entity : XXXXXXXXXXXXXXXX **Mobile:** 9829012345
Registration Type: Individual **Instrument Amount :** 32500.00
Payment Mode: Online/UTR **Payment Channel :** Payment Gateway/ICICI Branch - JDA
Instrument No : 456123789 **Instrument Date :** 17-06-2015

Dates Detail

Sr. No.	Event Name	Event Date
1	Publishing Date	01/06/2015 01:00 PM
2	Bid Opening Date	01/07/2015 03:00 PM

Specific Instrument Detail for eProc Rajasthan

Instrument Type: DD			
Instrument Number	Head Name	Amount	Date
10000	Tender Fee	400.00	05/06/2015
10001	RISL Processing Fee	1000.00	05/06/2015
10002	Bid Security Deposit	30,000.00	05/06/2015
Issuer Detail : Jaipur Development Authority		ChallanNumber: 641515600014	

Form of Bid-Securing Declaration

Date :

Bid No. :

Alternative No. :

To :

We, the undersigned, declare that:

We understand that, according to your conditions, bids must be supported by a Bid-Securing Declaration.

We accept that we are required to pay the bid security amount specified in the Term and Condition of Bid, in the following cases, namely :-

- (a) when we withdraw or modify our bid after opening of bids;
- (b) when we do not execute the agreement, if any, after placement of supply/work order within the specified period;
- (c) when we fail to commence the supply of the goods or service or execute work as per supply/work order within the time specified;
- (d) when we do not deposit the performance security within specified period after the supply/work order is placed; and
- (e) if we breach any provision of code of integrity prescribed for bidding specified in the Act and Chapter VI of these rules.

In addition to above, the State Government shall debar us from participating in any procurement process undertaken for a period not exceeding three years in case where the entire bid security or any part thereof is required to be forfeited by procuring entity.

We understand this Bid Securing Declaration shall expire if :-

- (i) we are not the successful Bidder;
- (ii) the execution of agreement for procurement and performance security is furnished by us in case we are successful bidder;
- (iii) thirty days after the expiration of our Bid.
- (iv) the cancellation of the procurement process; or
- (v) the withdrawal of bid prior to the deadline for presenting bids, unless the bidding documents stipulate that no such withdrawal is permitted.

Signed :-----

Name :-----


In the capacity of :-----

Duly authorized to sign the bid for and on behalf of :

Dated on day of

Corporate Seal -----

[Note: In case of a Joint Venture, the Bid Securing Declaration must be signed in name of all partners of the Joint-Venture that is submitting the bid.]





राजस्थान सरकार
वित्त (सामान्य वित्तीय एवं लेखा नियम) विभाग

Annexure - 21



क्रमांक : एफ.2(1)वित्त/जीएण्डटी-एसपीएफसी/2017 जयपुर, दिनांक : 23-12-2020

परिपत्र

वित्त विभाग की अधिसूचना क्रमांक एफ. 2(1)वित्त/जीएण्डटी - एसपीएफसी/2017 दिनांक 18.12.2020 द्वारा आरटीपीपी नियम, 2013 के नियम 42(2) में संशोधन करते हुए आमंत्रित की जाने वाली आगामी बोलियों के संदर्भ में दिनांक 31.12.2021 तक बिड सिक्यूरिटी राशि प्राप्त नहीं करने एवं इसके स्थान पर बिड सिक्यूरिटी के संबंध में घोषणा पत्र (Declaration) प्राप्त करने का प्रावधान किया गया है।

चूंकि उक्त नियमों में बिड सिक्यूरिटी राशि के स्थान पर बिड सिक्यूरिटी के संबंध में घोषणा पत्र (Declaration) प्राप्त करने का नवीन प्रावधान किया गया है। अतः समस्त उपापन संस्थाओं के उपयोगार्थ बिड सिक्यूरिटी के संबंध में लिए जाने वाले घोषणा पत्र (Declaration) का मानक प्रारूप संलग्न प्रेषित है। राजस्थान स्टाम्प अधिनियम, 1998 की धारा 3 सपडित अनुसूची के अनुच्छेद 4 के अनुसार घोषणा पत्र (Declaration) पर 50/- रुपये स्टाम्प ड्यूटी देय है तथा इस स्टाम्प ड्यूटी की राशि पर नियमानुसार 30 प्रतिशत सरचार्ज देय है। अतः समस्त उपापन संस्थाओं को निर्देशित किया जाता है कि बिड सिक्यूरिटी के संबंध में प्रस्तुत किए जाने वाले घोषणा पत्र (Declaration) पर उक्तानुसार राजस्थान राज्य में स्टाम्प ड्यूटी एवं सरचार्ज का भुगतान सुनिश्चित करावें।

संलग्न- उपरोक्तानुसार

(विमल कुमार गुप्ता)
संयुक्त शासन सचिव

प्रतिलिपि निम्नांकित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित है:-

1. सचिव, राज्यपाल/प्रमुख सचिव, मुख्यमंत्री/विशिष्ट सहायक समस्त मंत्रीगण/राज्य मंत्रीगण
2. उप सचिव, मुख्य सचिव/निजी सचिव, समस्त अति. मुख्य सचिव/प्रमुख शासन सचिव/ शासन सचिव/विशिष्ट शासन सचिव।
3. सचिव, राजस्थान विधानसभा, राजस्थान, जयपुर।
4. सचिव, लोकयुक्त सचिवालय, राजस्थान, जयपुर।
5. सचिव, राजस्थान लोक सेवा आयोग, अजमेर।
6. रजिस्ट्रार, राजस्थान उच्च न्यायालय जोधपुर/जयपुर।
7. प्रधान महालेखाकार ए एण्ड ई राजस्थान जयपुर।
8. प्रधान महालेखाकार ऑडिट राजस्थान जयपुर।
9. समस्त संयुक्त शासन सचिव/उप शासन सचिव/सचिवालय के समस्त अनुभाग/दिभाग।
10. समस्त विभागाध्यक्ष/जिला कलक्टर/संभागीय आयुक्त।
11. रजिस्ट्रार, राजस्थान सिविल सेवा अपील अधिकरण, जयपुर।
12. समस्त वित्तीय सलाहकार/मुख्य लेखाधिकारी।
13. समस्त कोषाधिकारी।
14. समस्त उपापन संस्थाएं।
15. तकनीकी निदेशक वित्त विभाग को भेजकर लेख है परिपत्र को वित्त विभाग की वेबसाईट पर प्रकाशित करवाने की व्यवस्था करावें।
16. रक्षित पत्रावली।

23/12/2020
संयुक्त शासन सचिव

SCHEDULE 'A' : INFORMATION USE FULL FOR THE CONTRACTORS:

The bidder should see the site and fully understand the condition of the site before bidding and include all lead, lifts etc. for the material in his item rate / percentage to the quoted on the rates as given in schedule 'G'. Then work shall be carried out in accordance with the Rajasthan PWD specification for electric works 1980 and to the entire satisfaction of the Engineer-Incharge of the work.

SCHEDULE 'B': LIST OF THE DRAWING TO BE SUPPLIED BY THE DEPARTMENT:

The drawing may be seen in office of the undersigned.

SCHEDULE 'C': LIST OF THE DRAWING TO BE SUPPLIED BY THE CONTRACTOR:

List of the drawing to be supplied by the contractor Nil. But the contract or shall have to arrange drawings required for the work at his own cost after deposition necessary cost within JDA.

SCHEDULE 'D': TEST OF THE MATERIALS:

The test of the material and workmanship shall be conducted by the JDA staff as necessary. The result of such tests should confirm to be standard laid down in the Indian standards and or the standards laid down in the detailed specification of the Public Works.

Deptt. proper quality control is required to be maintained by the contractor. Qualified personnel as required under the contractor enlistments rules duly approved by the Deptt. shall have to be engaged at site by the contractor. The Deptt. reserves the right to engage such staff and recover the expenses from the contractor on such account in case of his failure to do so.

SCHEDULE 'E': SAMPLES OF THE MATERIALS:

The samples of the material to be used by the contractor shall be deposited 15 days in advance with the Engineer In-charge and be got approved by him before use.

SCHEDULE 'F': TIME OF COMPLETION:

The work should start within 15 days of issue of work order and completion within months/days.

SCHEDULE 'G': ATTACH SEPARATELY SCHEDULE 'G' BASED ON 2016 JDA BSR (Elect) RAJASTHAN JAIPUR/JDA APPROVED.

SCHEDULE 'H': SPECIAL CONDITION ATTACHED SEPARATELY.

SCHEDULE 'I': LIST F THE MATERIAL TO BE SUPPLIED BY THE DEPTT.

Whatever material available in JDA store shall be issued @ the prevailing store issue date of JDA + 5% storage charges at the time of issue of cement.

**Signature of Contractor
with full address.**

**Executive Engineer (Elect.-III)
JDA, Jaipur.**

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR
Special Terms & Conditions for Electrification work.

The Contractor has to give the performance guarantee of the following materials for the period mentioned against them from the date of completion of work:

- | | | |
|-----|---------------------------|-----------|
| (a) | Transformers | 30 Months |
| (b) | All types of Insulators | 18 Months |
| (c) | ACSR Conductors | 6 Months |
| (d) | Isolators | 6 Months |
| (e) | Horn gap fuse set | 6 Months |
| (f) | LT Pillar Box | 6 Months |
| (g) | All types of HT/LT cables | 18 Months |

1. DLP period for various type of above works will now be governed by Director (Engineering-I) office order no. 29 dated 11.03.2016 (Copy Enclosed named by DLP period)
2. The Contractor has to arrange for the permission for the charging of electrical system from the Electrical Inspector Govt. of Rajasthan. He will have to deposit the necessary fees, which shall be reimbursed by Jaipur Development Authority.
3. The contractor will coordinate for the system handing over and charging process and if any defects, is pointed out by the RSEB/JVVNL/PWD/JNN, then he will have to rectify the same.
4. The final bill shall be paid after the lines and substations are handed over to RSEB/JVVNL/PWD/JNN and system is charged.
5. Inspection shall be bear by the contractor it self.
6. The material shall be purchased from the firms, which are also supplying the material to RSEB/JVVNL.
7. All HT/LT cables should be sequentially marked with cable size & length duly embossed.
8. The contractor shall return unused material issued to him by the deptt. If desired by the Engineer in-charge and in case, of failure to do so he shall be charged for such unreturned material at double the issue rate including storage and supervision charges or the market rate whichever is higher. The basis of the theoretical consumption and allowing for wastage @ 5% at double the issue rate including storage and supervision charges or market rate which ever is higher.
9. **The contractor shall be fully responsible to follow safety code as per IS 3764:1992 (upto date). The work should be executed without damaging existing water pipe line, LT/HT electric under ground cable, poles, existing surface drain, water connections, Telephone cables etc. In case of any damages the penalty/ liability imposed for such work shall be borne by the contractor and shall be got repaired immediately by arranging material/ labor/ assistance etc. In case of delay JDA reserve right to execute/ get executed the work at the cost and risk of the contractor.**
10. It is a mandatory condition that contractor will get all insulated material tested from CTL of JVVNL before using it at site.

Executive Engineer (Elect.-III)
JDA, Jaipur

I carefully study & do agree for above terms & Conditions.
Signature & Seal of the Contractor

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

SPECIAL CONDITION

- The following condition is now the part of the tender document.
- 🚩 **"If any bidder quotes a rate below than the schedule "G" rates, i.e. rates below than "at par", then the bidder has to deposit the difference amount i.e. difference amount of the rates as per "at par" and quoted "below", as "work Performance Guarantee." This amount has to be deposited before the commencement of work and will be refund after successful completion of DLP Period. Lowest bidder will be issued LOA (Letter of Acceptance) and within 14 days period he has to deposit difference amount in the form of B.G./FDR/NSC. The validity of these shall be for a period three months beyond the date for completion of DLP Period as per requirement. In case of non-deposition of the same in specified period, the Bid Security will be forfeited. In case work is not completed satisfactorily, the "work performance guarantee" will be forfeited and other action will be taken as per Contract Agreement (Order No. प. 01(24)नविवि/1/2020 लूज जयपुर, दिनांक 20.09.2021)."**

SCHEDULE 'H'

01. If there is any typographical error or otherwise in the 'G' Schedule the rates given in the relevant BSR on which schedule 'G' has been prepared, shall prevail.
02. Special Conditions of Contract regarding Defect Liability Period (DLP) for Roads works costing Rs. 25.00 lacs and more shall be applicable
03. The contractor shall follow the contractor labour regulation and abolition Act 1970 & Rule 1971.
04. The JDA shall have right to cause on audit and technical examination of the work and the final bills of the contractor including all supporting vouchers, abstract etc. to be made within two years after payment of the final bills and if as a result such audit any amount is found to have been over paid/excess in respect of any work done by the contractor under the contract or any work claimed by him to have been done under this contract and found not to have been executed the contractor shall sum from him in ; the manner prescribed in special condition no. 8 or any other manner legally permissible and if it is found that the contractor was paid less then that was due to him under the contract in respect of any work executed by him under it, the amount of such under payment shall be paid bay the JDA to the contractor.
05. The contractor shall not work after the sunset and before sunrise without specific permission of the authority Engineer.
06. Whenever any claim against the contractor for the payment of a sum of money arises out or under the contracts, the JDA shall be entitled to recover the sum by appropriating in part or whole of the security deposit of the contractor. In the event of the security being insufficient of if no security has been taken from the contractor then the balance of the total sum recoverable as the case may shall be deducted from any sum then due or which a any time there contract with the JDA should this sum be sufficient to recover the full amount recoverable, the contractor shall pay to JDA on demand the balance remaining due. The JDA shall further have the right to effect such recoveries under P.D.R. Act.
07. The rate quoted by the contractor shall remain valid for a period of 4 (Four) months from the date of opening of the tenders.
08. By submission of this tender the contractor agree to abide with all printed conditions provided in the PWD manual from 64 (Chapter 3-para 36) and subsequent modification.
09. No conditions are to be added by the contractor and conditional tender is liable to be rejected.
10. All transaction in the execution of this work and this tender will be liable to sale-tax vide section 2(B) read with sub clause (4) Sale-tax Rule, 1954.
11. If any bidder withdraws his tender prior to expiry of said validity period given at S. No. 7 or mutually extended prior or makes modifications in the rates, terms and conditions or fails to the tender within the said period, which are not acceptable to the department or fails to commence the work in the specified period, fails to execute the agreement and fails to furnish performance guarantee the department shall, without prejudice to any, other right or remedy, be at liberty to forfeit the amount of earnest money given in any from absolutely. If any contractor, who having submitted a tender does not execute the agreement or start the work or does not complete the work and the work has to be put to retendering, shall stand debarred for 6 Months from participating of tendering in JDA in addition to forfeiture of Earnest Money/Security/Performance Guarantee and other action under agreement.
12. The contractor shall arrange his own machinery required for the work.
13. The contractor shall arrange his own storage, yard of sufficient capacity for storing wherever supplied by the department.
14. Rules regarding enlistment of contractors provide that work ; upto five times limit for which they are qualified for tendering can be allotted to them Therefore, before tender the contractors will keep this in mind, and submit the details of work. Tenders with incomplete or incorrect information are liable to be rejected.

15. Any material not conforming to the specifications collected at site shall have to be removed by the contractor within a period of 3 days of the instructions, issued by the Engineer-In charge in writing. Failing which, such material shall be removed by the Engineer-In charge at risk and the contractor after expiry of 3 days period.
16. The material collected at site and paid provisionally shall remain under the watch and ward of the contractor till it is consumed, fully on the work.
17. None of the permanent works shall be carried out during night or Sunday or any authorized holiday without permission in writing of the Engineer-In charge.
18. **The contractor shall be fully responsible to follow safety code as per IS 3764:1992 (upto date). The work should be executed without damaging existing water pipe line, LT/HT electric under ground cable, poles, existing surface drain, water connection, Telephone cables etc. In case of any damages the penalty/ liability imposed for such work shall be borne by the contractor and shall be got repaired immediately by arranging material/ labor/ assistance etc. In case of delay JDA reserve right to execute/ get executed the work at the cost and risk of the contractor.**
19. The contractor/firm or company will display necessary signboards & lights from safety point on view during nights at site of work on his own cost as directed by the authorized Engineer In charge.
20. The surplus earth & damaged materials will be immediately removed from the site of work & dumped as per instruction of Engineer In charge.
21. No extra payment will be made to the contractor on account of clearance of soakage well/septic falling in the alignment of overhead or underground line.
22. The onus of safety and security of men and material at work including the road user shall be completely of the contractor only.
23. The rate provided in tender documents is inclusive of all Taxes & royalty.
24. The bidder are required to furnish the following documents along with the tender:
 - i. Duly executed power of attorney in original along with two certified copies in the name of the tender's authorized representative to act on behalf of the bidder and the power to agree to refer dispute to arbitration.
 - ii. Sales Tax & Income-Tax clearance certificate.
 - iii. Construction programme of work in the form of bar charts.
 - iv. Financial resources with particulars.
 - v. Constitution, capital, registration, place of business of the bidder.
 - vi. Particulars of registration with central or State Government Organization if any.
 - vii. Details of work of similar type and magnitude already carried out by the tender.
 - viii. Details of work Tendered for and as on the date of issue of tender.
 - ix. Details of Plant machinery available with the tender for this work.
 - x. Details of plant machinery proposed to be used on the work; but not immediately available.
 - xi. **Details of qualified technical personnel proposed to employ on the work.**
 - xii. A declaration to the effect that the bidder is engineering construction firm or any associate of such firms which has successfully carried out large works of this nature and have adequate organization and experienced personnel to handle the present work.
 - xiii. Copies of certificates if any.
25. No extra load of earth / material shall be paid over and above as specified in 'G' Schedule. Source/ borrow Pit area for earth shall have to be arranged by the Contractor at his own cost.
26. Undersigned has full right to reject any or all tenders without given any reasons.
27. It is a mandatory condition that contractor will get all insulated material tested from CTL of JVVNL before using it at site.
28. All the provision of the RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT, 2012 AND RULES, 2013 WILL BE APPLICABLE. IF THERE IS ANY CONTRADICTIONS IN EXISTING SPECIAL CONDITIONS AND PROVISION OF THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT, 2012 AND RULES, 2013 SHALL BE APPLICABLE.

**SIGNATURE OF CONTRACTOR
WITH FULL ADDRESS:**

**EXECUTIVE ENGINEER (Elect.-III),
JDA, JAIPUR**

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

DETAILED SPECIAL CONDITION AND SPECIFICATIONS

1. The scope of the Schedule 'H' and 'G' comprises HT/LT Line work on the road mentioned in schedule 'G'
2. The tubular poles are proposed to be erected generally in the median strip of the road or sides unless otherwise instructions are given to change the alignment.
3. The road in question in national, highway / important only road and as not only heavy traffic passes through the road but all the VIPs also pass through it the before it will be the contractor responsibility the provide all retendered caution signs during the execution of work at his own cost in order in to avoid any mis-happening.
4. No opening shall be left uncovered during night. The bidder shall make all arrangement to avoid any claim if preferred on his account shall be the liability of the bidder.
5. No road or part of the road shall be cut without taking the prior permission in writing from the competent authority. The permission shall be arranged by bidder on the request of JDA. However, any changes will be borne by JDA.
6. The contractor shall be deemed to have carefully examined the specifications general condition and tender drawing etc. and they have been fully informed and have satisfied himself as to the nature and character of the work to be executed site conditions and other relevant matters and details.
7. References to standard code specifications recommendation shall mean the attested addition of such publications of the work to be executed at site before the date of invitation to submit proposals.
8. The excavated material shall be place within 1.5 Mtr. of the edge the half of the depth of the trench with have is more site clear shall be done within 24 hours.
9. The work shall be carried out strictly complying within Indian Electricity Rules in forces and as per specifications for Electrical work issued by PWD Raj., Jaipur 1980.
10. **Trenching:** The trenches shall be of shaper size as instructed by the Engineer-In-Charge.
 - (a) **Width**
 - (i) The minimum width of trench for laying single cable shall be 35 Cm.
 - (ii) Where more than one cable is to be laid in the same trench in horizontal formation. The width of the trench shall be increased such that the spacing between the cable shall be at least 20 Cm.
 - (b) **Depth:**
 - (i) Where cable core laid in single tier formation in the total depth of shall not be less than 75 cm for cable upto 1.1 KV.
 - (ii) When more than one tier of cable is unavoidable and vertical formation of laying is adopted depth of trench in (i) above shall increases by 30 cm for each additional tier to be formed.
 - (iii) The depth shall be 1.0 Mtr. of 11 KV, 1.5 Mtr. For 33 KV.
 - (c) **Excavation**

The trench must be excavated straight and if it is necessary to give band or curve radius of such trench shall be at least 12 time the over all dia meter of the cable.
 - (d) **Placing of the Cable**

The cable must be places in the trench on band of fine sand of 8 cm thick bed, and the cable shall be laid below water and sewer lines.
 - (e) For the safe guard of cable it must have covering of clean dry rever sand or any other type of soil as directed by Engineer-In-Charge in not less than 17 cm.
 - (f) **Protection**

To protect the cable against mechanical damages the second class bricks or stone katla as specification shall be placed over the cable width wise.

11. Satisfactory type/acceptance test that results wherever applicable conducted from Govt./Govt. approved laboratory as per ISS shall be submitted prior to use. The routine tests of cable shall be conducted only after delivery at site at his own cost.
12. **Earthing**
The ground Earthing shall be done generally conforming to IS specification of 3043-1966 all the work earth terminal be provided duly crimped/soldered.
13. **Controlling Panels**
The controlling panels such as main panel service pillar box and fuse boxes are to be installed in span. The rubber gasket bedding of high quality rubber is to be provided around all operable parts. The all hard works should be made corrosion resistant giving all chemical treatment before its fabrication and before final coat desired colour painting and red oxide primer should be applied. All internal connectives are to be made with PVC insulated copper conductor with copper lugs duly crimped. The internal wiring shall be arranged with clips the bus bars and connection shall consist of drawn high conductivity copper strip with PVC 3 leaves tops of phase colours.
14. **Submission of drawing by the contractor**
The following two drawings are required to be submitted by the contractor.
 - (i) **Main Panel Drawing:** The Contractor shall submit the drawing of main panel all dimensions all internal connection of diagram, well before its fabrication and obtain prior approval of the drawings from the competent authority.
 - (ii) **Completion drawings:** The contractor shall submit the completion drawings of the project showing the route of the cable and position of panel etc.
15. **Testing**
The following test shall be performed by the contractor at his own cost.
 - (i) **Continuity and installation test of cable:** The contractor shall arrange for the continuity of cable for well use of the length of the cable.
 - (ii) **Megger Testing:** The whole installation shall be arranged to be tested by contractor after its completion shall be in presence of Engineer-In-Charge and results shall be recorded and signed jointly.
16. **Earthing Testing:** Earth test shall be performed by the contractor and results will be used and recorded and signed jointly.
17. Any other test for cable etc. required shall be arranged by the contractor.
18. No condition of any short except as provided in the printed form schedule of quantities will be entertained.
19. Conditions given in the bid form apply in full.
20. The contractor shall have to obey the labour laws. The labour shall have to pay monthly and shall have first line on the bill of contractor, in case of complaint of labour and nonpayment of wages is received to the department.
21. The rate of every item should be quoted against each in figures and in words as well for complete Non BSR Items.
22. In case of any typographical error in nomenclature, unit and rate, the rates as per BSR on which 'G' Schedule is prepared shall be binding on the tenders.
23. In case of any dispute the Executive Engineer (Electrical-III) decision shall be final.
24. The bidders are expected to be fully conversant with the general and special conditions of contract in force in this office. They must see the site of work acquaint themselves of the position of the materials. Fluctuation of the rates in the market, see the schedule and plans in the office and remove doubts, if any, before submitting their tenders.
25. The JDA is not responsible for arranging any material whatsoever any the contractor will have to complete the work within the specified time with specified material and approved accessories, from the stock, non-availability of material or delay in the consignment will not be entertained to as an excuse for extension of time for completion of work.
26. Contractor will not be paid extra for sales or any other tax.
27. Bid must be submitted on the prescribed forms duly signed by the bidder on every page.
28. All entries by the bidder should be in ink only. Erasers and over writings are not permissible. All cancellation correction and insertions must be signed by the bidder.

29. Rate quoted should be given for the work, separately in words and figures in case there is any difference in rates between words and figures the lower of the two will be taken as correct.
30. All the papers signed by the parties to this contract and bond together and sealed shall be deemed to form part of the contract bond and shall be read as conditions of contract.
31. In every case in which by virtue of the provisions of section 12 sub section (1) of the workman's Compensation Act, 1923 cost is obliged to pay compensation to a workman employed by the contractor or by a sub contractor for execution to said work Govt. will recover from the contractor the amount of the compensation paid and without prejudice to the rights of Govt. under section 12 sub section (2) of the said Act, Govt. shall be at liberty to recover such amount or any part thereof by deducting if from the earnest money deposited by the contractor to his credit or any other sum due by Govt. to the contractor whether under this contract or otherwise.
32. The contractor should have submit safety certificate for equipment each year separately in maintenance period.
33. The contractor shall arrange the certificate from electric inspector on completion of the electric installation at his own. However, any fee to be paid on this account shall be paid by the JDA.
34. The entire material should be as per JDA BSR 2016 of Electrical work of Schedule 'G' & specified main materials of schedule 'H' and shall be of ISI marked.

I/We have carefully study the instructions / conditions mentioned above & do hereby undertake to agree for the same.

**SIGNATURE OF CONTRACTOR
WITHFULL ADDRESS:**

**EXECUTIVE ENGINEER (Elect.-III),
JDA, JAIPUR**

Note:-

1. किसी भी निविदा को बिना कारण बताये निरस्त किया जा सकता है।
2. आवेदक / संवेदक को निविदा प्राप्त करने के लिये आवेदन के साथ पंजीयन प्रमाण पत्र की प्रति प्रस्तुत करना अनिवार्य है।
3. आवेदक / संवेदक को निविदा प्रपत्र पर अपना पता एवं दूरभाष नम्बर अंकित करना अनिवार्य है।

Annexure A : Compliance with the code of Integrity and No Conflict of Interest

Any person participating in a procurement process shall –

- (a) Not offer any bribe, reward or gift or any material benefit either directly or indirectly in exchange for an unfair advantage in procurement process or to otherwise influence the procurement process;
- (b) Not misrepresent or omit the misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- (c) Not indulge in any collusion, Bid rigging or anti-competitive behavior to impair the transparency, fairness and progress of the procurement process;
- (d) Not misuse any information shared between the procuring Entity and the Bidders with an intent to gain unfair advantage in the procurement process;
- (e) Not indulge in any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- (f) Not obstruct any investigation or audit of a procurement process;
- (g) Disclose conflict of interest, if any; and
- (h) Disclose any previous transgressions with any Entity in India or any other country during the last three years or any debarment by any other procuring entity.

Conflict of Interest:-

The Bidder participating in a bidding process must not have a Conflict of interest. A conflict of interest is considered to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations.

- i. A Bidder may be considered to be in Conflict of Interest with one or more parties in a bidding process if, including but not limited to:
 - a. Have controlling partners/shareholders in common ; or
 - b. Receive or have received any direct or indirect subsidy from any of them; or
 - c. Have the same legal representative for purposes of the Bid; or
 - d. Have a relationship with each other; directly or through common third parties, that puts them in a position to have access to information about or influence on the Bid of another Bidder, or influence the decisions of the Procuring Entity regarding the bidding process; or
 - e. The Bidder participates in more than one Bid in a bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all Bids in which the Bidder is involved. However, this does not limit the inclusion of the same subcontractor, not otherwise participating as a Bidder, in more than one Bid; or
 - f. The Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the Goods, Works or Services that are the subject of the Bid; or
 - g. Bidder or any of its affiliates has been hired (or is proposed to be hired) by the Procuring Entity as engineer-in-charge/ consultant for the contract.

Annexure B: Declaration by the Bidder regarding Qualifications Declaration by the Bidder

In relation to my/our Bid submitted to for procurement of
..... in response to their Notice inviting Bids No.
.....Dated I/We hereby declare under Section 7 of Rajasthan
Transparency in Public Procurement Act, 2012, that:

1. I/We possess the necessary professional, technical, financial and managerial resources and competence required by the Bidding Document issued by the Procuring Entity;
2. I/We have fulfilled my/our obligation to pay such of the taxes payable to the Union and the State Government or any local authority as specified in the Bidding Document;
3. I/We are not insolvent, in receivership, bankrupt or being wound up, not have my/our affairs administered by a court or a judicial officer, not have my/our business activities suspended and not the subject of legal proceeding for any of the foregoing reasons;
4. I/We do not have, and our directors and officers not have, been convicted of any criminal offence related to my/our professional conduct or the making of false statements or misrepresentations as to my/our qualifications to enter into a procurement Contract within a period of three years preceding the commencement of this procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
5. I/We do not have a conflict of interest as specified in the Act, Rules and the Bidding Document, which materially affects fair competition;

Date :

Signature of bidder

Place :

Name :

Designation:

Address:

Annexure C: Grievance Redressal during Procurement Process

The designation and address of the First Appellate Authority is **ACE (Elect), JDA Jaipur**

The designation and address of the Second Appellate Authority is **JDC, JDA, Jaipur**

(1) Filing an appeal

If any Bidder or prospective bidder is aggrieved that any decision, action or omission of the Procuring Entity is in contravention to the provisions of the Act or the Rules or the Guidelines issued thereunder, he may file an appeal to First Appellate Authority, as specified in the Bidding Document within a period of ten days from the date of such decision or action, omission, as the case may be, clearly giving the specific ground or grounds on which he feels aggrieved: Provided that after the declaration of a Bidder as successful the appeal may be filed only by a Bidder who has participated in procurement proceedings: Provided further that in case a Procuring Entity evaluates the Technical Bids before the opening of the Financial Bids, an appeal related to the matter of Financial Bids may be filed only by a Bidder whose Technical Bid is found to be acceptable.

(2) The officer to whom an appeal is filed under para (1) shall deal with the appeal as expeditiously as possible and shall endeavour to dispose it of within thirty days from the date of the appeal.

(3) If the officer designated under para (1) fails to dispose of the appeal filed within the period specified in para (2), or if the Bidder or prospective bidder or the Procuring Entity is aggrieved by the order passed by the First Appellate Authority, the Bidder or prospective bidder or the Procuring Entity, as the case may be, may file a second appeal to Second Appellate Authority specified in the Bidding Document in this behalf within fifteen days from the expiry of the period specified in para (2) or of the date of receipt of the order passed by the First Appellate Authority, as the case may be.

(4) Appeal not to lie in certain cases

No appeal shall lie against any decision of the Procuring Entity relating to the following matters, namely:-

- (a) Determination of need of procurement;
- (b) Provisions limiting participation of Bidders in the Bid process;
- (c) The decision of whether or not to enter into negotiations;
- (d) Cancellation of a procurement process;
- (e) Applicability of the provisions of confidentiality.

(5) Form of Appeal

- (a) An appeal under para (1) or (3) above shall be in the annexed form along with as many copies as there are respondents in the appeal.
- (b) Every appeal shall be accompanied by an order appealed against, if any, affidavit verifying the facts stated in the appeal and proof of payment of fee.
- (c) Every appeal may be presented to First Appellate Authority or Second Appellate Authority, as the case may be, in person or through registered post or authorized representative.

(6) Fee for filing appeal

- (a) Fee for first appeal shall be rupees two thousand five hundred and for second appeal shall be rupees ten thousand, which shall be non-refundable.
- (b) The fee shall be paid in the form of bank demand draft or banker's cheque of a Scheduled Bank in India payable in the name of Appellate Authority concerned.

(7) Procedure for disposal of appeal

- (a) The First Appellate Authority or Second Appellate Authority, as the case may be, upon filing of appeal, shall issue notice accompanied by copy of appeal, affidavit and documents, if any, to the respondents and fix date of hearing.
- (b) On the date fixed for hearing, the First Appellate Authority or Second Appellate Authority, as the case may be, shall,-
 - (i) Hear all the parties to appeal present before him; and
 - (ii) Peruse or inspect documents, relevant records or copies thereof relating to the matter.
- (c) After hearing the parties, perusal or inspection of documents and relevant records or copies thereof relating to the matter, the Appellate Authority concerned shall pass an order in writing and provide the copy of order to the parties to appeal free of cost.
- (d) The order passed under sub-clause (c) above shall also be placed on the State Public Procurement Portal.

FORM No. 1

[See Rule 83]

**Memorandum of Appeal under the Rajasthan
Transparency in Public Procurement Act, 2012**

Appeal No. of

Before the (First/Second Appellate Authority)

1. Particulars of appellant :

(i) Name of the appellant :

(ii) Official address, if any :

(iii) Residential address :

2. Name and address of the respondent (s) :

(i)

(ii)

(iii)

3. Number and date of the order appealed against and name and designation of the officer/ authority who passed the order (enclose copy), or a statement of a decision, action or omission of the Procuring Entity in contravention to the provisions of the Act by which the appellant is aggrieved:

4. If the Appellant proposes to be represented by a representative, the name and postal address of the representative:

5. Number of affidavits and documents enclosed with the appeal :

6. Grounds of appeal :

(Supported by an affidavit)

7. Prayer :

Place

Date

Appellant's Signature

Annexure D : Additional Conditions of Contract

• Correction of arithmetical errors

Provided that a Financial Bid is substantially responsive, the Procuring Entity will correct arithmetical errors during evaluation of Financial Bids on the following basis:

- i. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected, unless in the opinion of the Procuring Entity there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price shall be corrected;
- ii. If there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected and . If there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (i) and (ii) above.

If the Bidder that submitted the lowest evaluated Bid does not accept the correction of errors, its Bid shall be disqualified and its Bid Security shall be forfeited or its Bid Securing Declaration shall be executed.

2. Procuring Entity's Right to Vary Quantities

- (i) If the Procuring Entity does not procure any subject matter of procurement or procures less than the quantity specified in the Bidding Document due to change in circumstances, the Bidder shall not be entitled for any claim or compensation except otherwise provided in the Conditions of Contract.
- (ii) On repeat order for extra items for additional quantity may be placed if it is provided in the bidding documents on the rates and conditions given in the contract, if the original order was given after inviting open competitive bids. Delivery or completion period may also be proportionately increase. The limits of repeat order shall be as under.
 - (a) 50% of the qty of the individual items and 50% of the value of original contract in case of works and
 - (b) 50% of the value of goods or services of the original contract.

3. Dividing quantities among more than one Bidder at the time of award (In case of procurement of Goods)

As a general rule all the quantities of the subject matter of procurement shall be procured from the Bidder, whose Bid is accepted. However, when it is considered that the quantity of the subject matter of procurement to be procured is very large and it may not be in the capacity of the Bidder, whose Bid is accepted, to deliver the entire quantity or when it is considered that the subject matter of procurement to be procured is of critical and vital nature, in such cases, the quantity may be divided between the Bidder, whose Bid is accepted and the second lowest Bidder or even more Bidders in that order, in a fair, transparent and equitable manner at the rates of the Bidder, whose Bid is accepted.

**SPECIAL CONDITIONS OF CONTRACT REGARDING
DEFECT LIABILITY PERIOD (DLP) FOR ROADS/ ELECTRICALS WORKS**

As per the decision taken in the 201st meeting of Executive Committee held on 23.02.2016 w.r.t. agenda no. 201:22, DLP period of various natures of works amounting more than Rs. 25 lakhs has been revised as per following time periods based on nature of works.

This order will supersede the earlier orders issued in this regard i.e. order No. JDA/TA to D(E)/2010-11/D-317 dated 28.04.2011 including Special Condition No. 2.2.2 & 2.2.3 of Annexure-I related to SD refund & forfeiture (other Special Condition of annexure-I of this order will remain valid) and order No. JDA/Ex.En.(Pr.-5 & TA)/2013/D-43 dated 27.02.2013 and also all pertaining orders, in contract agreements or in PWF&AR having DLP period different than what is being enforced through this present order for concerned type of work.

Table-I

S. No.	Type of work	Existing DLP Period	As per approved in E.C. held on 23.02.2016
1.	Bridge Work	3 years	5 Years
2.	CD Work	3 years	5 Years
3.	CC Road. PQC Work	3 years	5 Years
4.	CC tiles/Kerbs/medians	3 years	5 Years
5.	Drains	6 Months	3 Years
6.	Roads		
	(i)Two layer WBM/GSB	3 years	6 months or one full rainy season which ever is later
	(ii)For Renewal/Strengthening		
	(a)BT upto 30 mm thickness	3 years	1 Years
	(b)BT above 30 mm to upto 40 mm	3 years	2 Years
	(c)BT above 40 mm to upto 90 mm	3 years	3 Years
	(d)BT above 90 mm thickness	3 years	5 Years
	(iii) New Roads		
	(a) BT upto 90 mm	3 years	3 Years
	(b) BT more than 90 mm	3 years	5 Years
7.	Compound wall	6 Months	3 Years
8.	Building Work		
	(i) Work pertaining to Sanitary work electrical works, Joinery works and painting works.	6 Months	2 Years
	(ii) Work pertaining to Building structure and other civil works	6 Months	5 Years
9.	Electric work except maintenance	6 Months	3 years
10.	Sewer/Water supply all including STP and water supply related work except maintenance works.	6 Months	3 Years

The release of SD amount shall be as per following table :-

Table-II

S.No.	DLP Period \ Released SD	1 Year	2 Years	3 Years	5 Years
1.	Upto 1 year	100%	40%	20%	10%
2.	Upto 2 year		60%	20%	10%
3.	Upto 3 year			60%	10%
4.	Upto 4 year				20%
5.	Upto 5 year				50%

Various condition for managing DLP are as under :-

- (i) At the time of completion of work, final componnt shall be worked out for each individual item like BT/CC/tiles/ drains etc (as per different categories in Table-I), DLP shall be operative based upon type of individual item ex:- CC-5 years, BT1/2/3/5 years, Drain-3 years etc.
- (ii) Similarly for all new works, these components should be calculated at the time of TS itself, which should be made part of BID document.
- (iii) If any work, amount is less than Rs. 25 lacs but later on due to extra/excess work, if amount of final work cresses more than Rs. 25 lacs, DLP shall be operative as per rule for each individual items.
- (iv) Similarly if any work is more than Rs. 25 lacs but after finalization amount or work is less than Rs. 25 lacs, DLP should be operative for six months or rainy season whichever is late.
- (v) During DLP period if contractor fails to repair any work even after issue of 7 days written notice, same work shall be got executed by respective Executive Engineer at the contractor's risk and cost. This process shall be applicable throughout the DLP period. After completion of DLP period in such works contractor should be debarred and blacklisted. From JDA for three years as per RTPP rule 2012 and 2013 where he defaults twice in a single agreement or in two different works.
- (vi) Quarterly Inspection as per rules shall be carried out and DLP registers shall be maintained by respective Executive Engineers to monitor the DLP repairs.
- (vii) Special and regular inspection shall also be carried out as per order no. JDA/Ex.En. & TA to DE-I/2014-15/D-223 dated 12.03.2015 and order no. SE (PMGSY) CIRULAR 2006/D-115 dated 04.05.2006 Point no. 3.
- (viii) In case JDA feels to take up work on any existing DLP road due to any reason, following procedure should be adopted:
 - (a) At the time of withdrawal total liability of repairs as per DLP conditions to be carried out and contractor shall be asked to complete the same. After completion of assessed repairs DLP period shall be released after deduction amt. as per table III

Table-III

% Recovery on withdrawal of DLP of work order DLP period	1 Year	2 Year	3 Year	4 Year	5 Year
1 Year	1.12	-	-	-	-
2 Year	2.55	1.43	-	-	-
3 Year	4.38	3.26	1.83	-	-
5 Year	9	7.88	6.45	4.62	2.47

Note :- Calculation is to be done on quarterly basis.

- (b) In case Contractor fails to carry out these repairs, same shall be carried out at his risk and cost. If the total amt. of such repairs works out to be more than total retained amt. of SD same shall be recovered from other works and as per PDR rules. The amount as per Table III is also to be deducted in addition to this amount.
- (ix) Based upon type of work, DLP conditions for works to be carried out during DLP period with their frequency of respective type of work shall be prepared by respective SE"s after approval of these periods.

This order shall come in force with immediate effect and will be applicable on all new works whose NIB is to be called.

**Signature of contractor with
Full address.**

**Executive Engineer (Elect-III)
JDA, Jaipur.**

Bank Guarantee Performa for Bid security deposit

Form of (Bank Guarantee) -En cashable at branch of the bank in Jaipur City.

To
Secretary,
Jaipur Development Authority,
Jaipur

Sub:

- Bank Guarantee No. _____ dated _____ for [amount of Security in figures] [in words] on behalf of _____ [Name of the Bidder] against the Security Deposit for the work of **“Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur”**
- WHEREAS, _____ [name of Bidder with address] (**hereinafter called “the Bidder”**) has submitted his Bid datedfor the work of **“Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur”** (Name of Work) (Hereinafter called “the Bid”).

KNOW ALL PEOPLE by these presents that we _____
_____ (Name of Bank) of having our registered office at
_____ [name of country] having our registered office at
_____ (hereinafter called “the Bank”) are bound unto Secretary, Jaipur Development Authority. (Hereinafter called “the Employer”) in the sum of Rupees _____ [**Amount of Security in figures**] _____ (in words) only for which payment will and truly to be made to the said Employer, the Bank binds itself, its successors, and assigns by these presents. That on demand of JDA, this Bank Guarantee is encashable at following branch in Jaipur City.

1. Name of Bank:
2. Name of the branch with branch code:
3. Address:
4. E-Mail Id:
5. Telephone No.
6. Fax No.:

SEALED with the Common Seal of the said Bank this _____ day of _____ of 20____.

THE CONDITIONS of this obligation are:

- (1) if the Bidder withdraws his Bid during the period of Bid validity specified in the Form of Bid;
- (2) if the Bidder refuses to accept the correction of errors in his bid;
- (3) If the Bidder, having been notified of the acceptance of his Bid by the Employer during the period of Bid validity;
 - (a) fails or refuses to execute the Form of Agreement in accordance with the Instructions to Bidders, or
 - (b) fails or refuses to furnish the Performance Security, in accordance with the Instructions to Bidders;

We undertake to pay to the Employer up to the above amount upon receipt of his first written demand, without the Employer having to substantiate his demand, provided that in his demand the Employer will note that the amount claimed by him is due to him owing to the occurrence of one or more of the above conditions, specifying the occurred condition or conditions.

This Guarantee will remain in force up to and including the date 30 days after the date of expiration of the Bid Validity, as stated in the Instructions to Bidders, or any such extension thereto as may be agreed by the Bidder, notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank not later than the above date.

The amount covered under the above Bank Guarantee shall be automatically be credited in the accounts of JDA in ICICI Bank, JDA Campus, Jaipur through **ISFC code No ICICI 006754. Bank Account No. 675401700518** on the date of expiry or its validity, unless the agencies get it re-validated well before its expiry date or produce NOC from JDA in written for its release.

Date _____ Signature of the Bank _____

Witness _____ Seal _____ [Signature,
Name and Address]

[Note: To be furnished on appropriate non-judicial stamps.]



JAIPUR DEVELOPMENT AUTHORITY

Name of Work: - Electrification work at JDA Multipurpose Scheme
Metro Enclave, B2 bypass, JDA, Jaipur.

TECHNICAL BID

Executive Engineer (Elect.-III)
JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

JAIPUR DEVELOPMENT AUTHORITY JAIPUR

TECHNICAL BID

(Post Assessment)

Envelop-1

FOR

Name of Work: - Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Period of Sale: -	From 03.11.2021, 9.30 AM to 22.11.2021, 6.00 PM
Date of Submission of the tender: -	Upto 22.11.2021, 6.00 PM
Date of opening of Technical bid: -	On 23.11.2021 at 4.00 PM at Room No. JB FF-114, Court Building, Ram Kishore Vyas Bhawan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur- 302004 (Rajasthan)
Cost of tender: -	Rs. 1195.50 Lacs
Completion period: -	09 Months

NAME OF AGENCY -----

**Executive Engineer (Elect.-III)
JDA, Jaipur.**

JAIPUR DEVELOPMENT AUTHORITY JAIPUR

SPECIAL CONDITION OF THE CONTRACT FOR QUALIFICATION OF CONTRACTORS

Name Of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Special conditions of contract for Post Assessment Method as detailed here under, shall be applicable in addition to all other terms and condition already prescribed under standard agreement forms/rules and regulations to contract.

Note: - JV/Consortium are not allowed.

1. Procedure:

Procedure for **QUALIFICATION** would be as follow:

- (a) Tender document shall be submitted on line e-procurement website <http://www.eproc.rajasthan.gov.in> with their digital signature. The bid is to be submitted in 2 envelop which shall comprise of Envelop-1 being for Technical Bid (Post Assessment, EMD, GST, Registration of Contractors, tender document) and Envelop-2 being for Financial Bid, BOQ.
- (b) The Tender fee, processing fee and earnest money will be deposited online on or before **12.11.2021**
- (c) The Technical Bid envelope would be opened on the date 12.11.2021 at 6.00 PM Room No. JB FF-114, Court Building, Ram Kishore Vyas Bhawan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur-302004 (Rajasthan)
- (d) The Financial Bid envelope would be opened only of those bidders who fulfil the **ELIGIBILITY** criteria in technical bid.

2. Criteria:

Criteria for Post Assessment would be as follows:-

- (a) The bidder should have executed following quantities of work in any one financial year during last five financial years. However the bidder may opt current year in the said financial assessment period.

S.No.	Item	Quantity
Major Item of Schedule - G		
1	33 KV XLPE Cable	12000 Mtr
2	11 KV XLPE Cable	2528 Mtr
3	LT Cables	10580 Mtr.
4	11 KV RMU/VCB	7 Nos.
5	SITC of 33/11 KV GSS (Urban Type) having Indoor type VCB, Outdoor type VCB, 33 KV Control & Relay panel Feeder & Transformer type with required CTPT Set & Battery charge etc. Complete in all respect.	1 Nos.
6	33/11 KV Power Transformer	1 No.
7	11/0.4KV Distribution Transformer	1 No.
8	Bogie/HDD	10150 Mtr.

Note:-

- (i) The Bidder should enclose the certificate having quantities financial year wise otherwise the certificate will not be considered.
 - (ii) Quantities of all the items mentioned in criteria 2 (a) should be executed in one financial year.
 - (iii) Certificate issued by Govt. of India, State Govt., Union Territory, Govt. Undertakings, Autonomous Bodies shall only be considered.
- (b) The bidder should have completed at least one similar nature work in any one financial year during last five financial years (including current year, if opted by the bidder) of value not less than 50% of the Estimated Cost of the work (bid cost) updated to present price level)- Attached work order, G-Schedule/BOQ and work completion certificate.

Note:-

- (i) The starting & completion date of the work is to be in between aforesaid financial year. If no then maximum work (70%) is to be completed in aforesaid financial year.
 - (ii) If bidder is submitting certificate having different components / nature of work then proper completion certificate of required similar nature component is to be enclosed.
- (c) The bidder should have achieved an annual financial turnover of at least 60% of the Estimated Cost of the work (bid cost) in any one of last 5 financial years (including current year, if opted by the bidder)

Note:-

- (i) The bidder should enclose certificate of Turn over from Chartered Accountant for last five financial year & audited balance sheet of the year which is considered by the bidder in criteria 2 (c).
- (ii) If current year or last year has been opted by bidder whose balance sheet is not submitted till the submission of bid then certificate from Chartered Accountant should be enclosed.

(a) The bidder should give Affidavit to deploy the machinery and equipment as specified in Schedule - III, for the execution of this work.

(b) Bid Capacity: Bidders who meet the minimum qualification criteria will be qualified only if available bid capacity is equal to or more than the total Bid value.

The available bid capacity will be calculated as under:

$$\text{Bid Capacity} = (A \times N \times 3 - B)$$

Where A = Maximum value of Electrical Engineering work executed in any one year during the last 5 financial years (updated to present Price level) taking in to account the completed as well as works in progress. However, the bidder may opt current year in the five year assessment period

N = Number of year prescribed for completion of the work for which bids

B = are invited.
Value, at present price level of existing commitments and on going Works to be executed during 'N' period (period prescribed for Completion of the works for which the bids are invited)

Note:-

- (i) **Certificate from Chartered Accountant should be enclosed by bidder clearly indicated maximum value of Electrical Engineering Work in one Financial Year.**
- (c) **Litigation History:** - Bidder should provide an accurate information on any litigation or arbitration resulting from contracts completed or under execution by him over the last five years. The maximum value (updated at the present price level) of disputed amount claimed in the litigation / arbitration resulting from contracts executed in last five years shall be deducted from the calculated Bid Capacity of the bidder. The details shall be furnished in Schedule VI. **If schedule-VI is found blank then it will be treated as NIL.**

Note :-

- (i) **The present price level for turnover, cost of completed work & disputed amount of similar nature, the previous years value shall be given weight age of 10% per year as follows :-**

(a)	For current year	1.00
(b)	For last year	1.00
(c)	For one year before	1.10
(d)	For two year before	1.21
(e)	For three year before	1.33
(f)	For four year before	1.46

3. Documentation:

The bidder should furnish the following documents along with the technical bid:

- (a) Information regarding financial resources and capability in Schedule-I.
- (b) Information regarding works executed in the last five years in Schedule-II
- (c) Certificates from the concerned Engineer-In-Charge in support and verification of the information furnished in Schedule-II
- (d) Affidavit regarding machinery and equipment required for deployment, as detailed in scheduled-III.
- (e) Information regarding details of maximum value of electrical engineering works executed in any one year during the last five years taking into account the completed as well as works in progress in schedule-IV.
- (f) Information regarding existing commitments and ongoing works to be completed in schedule-V. **If it is found at any stage that the bidder hides his existing commitments than proper action will be taken as per RTPP act and Rules.**

- (g) Information regarding details of litigation or arbitration contracts to be furnished in schedule-VI. **If schedule-VI is found blank then it will be treated as NIL.**
- (h) Calculation of Bid capacity in schedule-VII.
- (i) Affidavit as per Annexure I.

4. Important:

- (a) The bidder must ensure that all the information required in the Documents is furnished by him complete in all respects. He would not be allowed to withdraw any document, or to rectify any information furnished therein, after submitting the bid.
- (b) The bidder should give an affidavit that the information furnished in schedule I to VII is correct. If any information is found incorrect, the offer of the bidder shall be rejected and action be taken as per rules.
- (c) Bidders must do paging of all enclosure of bid documents.

5. Rejection of bids

The department reserves the rights to reject any bid or to disqualify any or all the bidders, without assigning any reasons at any stage.

- (i) If Bid is not accompanied with the requisite documents mentioned in clauses 3 (a) to 3 (i) or is not in accordance with procedure specified in Para 1, or is not accompanied with earnest money, tender fee, processing fee and registration of contractor in required category it would be liable for rejection.
- (ii) Furnishing of incorrect or incomplete or concealment of any information required in the bid documents would render the bid liable for rejection.
- (iii) If all the copies enclosed in support and affidavit is not duly attested by Notary public/gazetted officer then bid of the bidder is to be rejected.

**Executive Engineer (Elect.-III)
JDA, JAIPUR**

SCHEDULE - I
FINANCIAL RESOURCES AND CAPABILITY

[Reference clause 3 (a)]

1. Name of Bidder
2. Total financial turnover achieved by the bidder in the last five financial years:

S.no.	Year	Turnover
(1)		
(2)		
(3)		
(4)		
(5)		

Note: Balance Sheets and Profit & Loss Accounts is to be enclosed by the bidder which is considered by him as per criteria 2 (a).

3. Total financial Turnover projected in the current financial year
4. Has the bidder ever been debarred from tendering for Central Government / State Government / any Government undertaking?
Yes / No, if yes give details.
5. Has bidder ever been declared insolvent?
Yes/No, if yes give details.
6. Name(s) and Address of Branch/(s) for bidder's Bankers.

I/We hereby certify that the above information is correct to the best of my/our knowledge and belief.

**Signature & Seal
of the Bidders**

SCHEDULE - II

(Reference Clause 3b)

Detail of quantities of work executed during last five financial years

S. No.	Name of Work (with Agreement No. & Date)	Place (District/State)	Financial Year	Principal item of work	

Note: Certificate from concerned Engineer-in-charge should be enclosed in support and verification of the above statement.

To be given on Non-Judicial stamp
Paper of Rs. 10/- only, duly attested by
Notary Public

**Signature & Seal
of the Bidders**

Schedule – III

[Reference Clause 3(d)]

AFFIDAVIT

I/We..... Proprietor/ Partner/ Authorized signatory of M/s under take the oath that I/We will deploy the machinery and equipment listed below as and when required in the execution of this work.

S.No.	Name of Machinery	Minimum Requirement	Availability	
			Owned	Leased
1	Digital Insulation tester 5 KV, with timer	1 No's		
2	HV Test set	1 No's		
3	Hydraulic Crimping tool up to 300 Sqmm	1 No's		
4	Multi-meter	1 No's		

I/We hereby certify that the above information is correct to the best of my/our knowledge and belief.

**Signature & Seal
of the Bidders**

**SCHEDULE -IV
(REFERENCE CLAUSE 3E)**

**Details Of Maximum Value Electrical Engineering Works Executed In Any One Year During The Last Five Years Taking Into Account The Completed As Well As
Works In Progress**

S. No.	Name of works (with agreement no. & date)	Client	Place (district/State)	Financial year	Cost of work as per work order	St. date of commencement	St. date of completion	Value of work done during the year

**Signature & Seal
of the Bidders**

SCHEDULE - V
(Reference Clause 3f)

Details of Existing Commitments & On-Going Works to Be Completed In Next One Year from Date of Submission of Bid

S. No.	Name of Work	Place and State	Ongoing work			Existing Commitments	
			Cost of work	Cost of work Remaining to be executed	Value of remaining work at present price level as on updated @10% per year	Estimated cost (Rs. In lacs)	Value of present price level as on updated @10% per year

Remark:- If it is found at any stage that the bidder hides his existing commitments than proper action will be taken as per RTPP act and Rules.

**Signature & Seal
of the Bidders**

SCHEDULE -VI
(Reference clause 3g)

DETAILS OF LITIGATION OR ARBITRATION CONTRACTS

S.No.	Name of works (with agreement no. & date)	Client	Work order amount	Disputed amount claimed in litigation/ Arbitration	Date of raising disputed amount	Actual award amount, if the case is decided	Cause of litigation & Matter in dispute

Remark: If schedule-VI is found blank then it will be treated as NIL.

**Signature & Seal
of the Bidders**

SCHEDULE-VII
(Reference Clause 3 h)
BID CAPACITY

Name of bidder :-----

<u>1.</u>	<u>A = Maximum value of Electrical Engineering work executed in any one year during the last five finance years (Updated to present price level)</u>	----- Lacs	Certified details enclosed at Page no.....
<u>2</u>	<u>N = Number of years prescribed for completion of the work, for which bids are invited</u>	-----Year	
<u>3</u>	<u>B= Value, at present price level of existing commitments and on going work to be completed during the N period</u>	-----Lacs	Certified details enclosed at Page no.....

Bid capacity = A X N X 3 - B
= -----Lacs

**Signature & Seal
of the Bidders**

ANNEXURE- I

[Reference Clause 3(i)]

To be given on Non-Judicial stamp
Paper of Rs. 10/- only, duly attested by
Notary Public

AFFIDAVIT

I/We..... Proprietor/ Partner/ Authorized
signatory of M/s under take the oath that the
information furnished by me/us in schedule I to VII of the assessment Bid for
..... is correct to the
best of my/our knowledge. If any information is found to be incorrect JDA has right to
reject the Bid and to take action against me/us as per rules.

Signature & Seal of

Proprietor/ Partner/ Authorized signatory

M/s
.....



JAIPUR DEVELOPMENT AUTHORITY

Name of Work:- Electrification work at JDA Multipurpose Scheme
Metro Enclave, B2 bypass, JDA, Jaipur.

Financial Bid

Executive Engineer (Elect.-III)

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur

CONTENTS OF BIDDING DOCUMENT

S. No.	Details	Page No.
1.	General Instructions to contractors	03-06
2.	Special Condition for Post Assessment	07-10
3.	Special condition of contract	11-14
4.	Inspection and testing	15-17
5.	Minimum Safety rules	18-22
6.	Guarantee	23-24
7.	Erection testing and commissioning	25-37
8.	Annexure-A	38
9.	Annexure-B	39
10.	Annexure-C	40-42
11.	Annexure-D	43-46

1-GENERAL INSTRUCTIONS TO CONTRACTOR

- 1.1 The Bidder is expected to examine carefully all instructions, conditions, forms, terms, and performance specification and drawing in the bid Documents. Failure to comply with the requirements of Bid submission shall be at the Bidder's own risk, Bids which are not substantially responsive to the requirements of the bid documents shall be summarily rejected.
- 1.2 At any time prior to the last date for submission of bids, the Employer may, for any reason whether at his own initiative or in response to a clarification requested by a prospective bids, modify the bid Documents but the issuance of an Addendum.
- 1.3 The Addendum will be sent in writing or by Fax/E-mail prospective Bidder who have received Documents, and will be binding unto them, whether the prospective Bidders acknowledge same or not.

2. DOCUMENTS AND INFORMATION TO BE FURNISHED AT THE TIME OF BID SUBMISSION

- 2.1 The bid to be prepared and submitted by the Bidder to the Employer for consideration shall comprise the following.
 - a. Form of bid duly signed along with the complete set of bid Documents. All documents issued for the purpose of bidding as described shall be deemed to have been incorporated in the bid for the work.
 - b. Bid security, Bid fee and processing fee as applicable in form of demand draft of any Nationalised Bank of India in favour of the Secretary Jaipur Development Authority Jaipur', payable at Jaipur.
 - c. Sales Tax or applicable Tax Clearance Certificate from the concerned departments
 - d. Bill of Quantities with the rates (both in figures as well as in words) and amounts for, all items of work duly filled in.

3. BIDED PRICES

- 3.1 Unless explicitly stated otherwise in the Bid Documents, the contract shall be for whole based on the departmental design, Bill of Quantities, rates and prices submitted by the Bidder.
- 3.2 The Bid shall fill in percentage rate (above/below) for the scheduled rates items and rates and rates and prices for all items in Non scheduled category of works describe in the Bill of Quantities in both figures and words, In case, there is any discrepancy in the rates quoted in figures and words, the rates, quoted in words shall be taken as correct. Item

against which no rate of rice is entered by the Bidder will not be paid for the employer when executed and shall be deemed to have been covered by the rates and prices in the Bill of Quantities.

- 3.3 All duties, taxes, fees and other levies (present and future) payable by the contractor under the Contract, or for any other cause, on the date thirty days prior to the closing date for submission of bids, shall be included in the total Contract Price submitted by the Bidder and the evaluation and comparison of bids by the Employer shall be made accordingly.

4. BID SECURITY

- 4.1 The Bidder shall furnish as part of his bid security for the respective amounts as mentioned in the NIT (Annexure 1 and 2). The amount is to be deposited online by bidder. In case the amount exceeds the online payment limit, the payment may be made through RTGS/NEFT in ICICI BANK LTD Bank Account Number 675401700586 IFSC Code ICIC0006754. After successful payment, update the UTR/Instrument number on JDA Tender portal against the tender you want to participate. The amount deposited will be confirmed by JDA and will be updated online.
- 4.2 Any bid not accompanied by bid security, bid fee and processing fee will be summarily rejected by the employer as non-responsive.
- 4.3 The bid security of the unsuccessful Bidder will be discharged/returned without interest as promptly as possible as but not later than 60 days after expiry of the bid validity prescribed by the employer.
- 4.4 The bid security of the successful Bidder will be discharged without interest upon the Bidder signing the agreement and furnishing the Bank Guarantee/ Surety Bond for the performance of the Contract.
- 4.5 There will be no liability on the part of the department towards interest on the Earnest Money paid by the Bidder.
- 4.6 The bid security shall be forfeited:
- a If a Bidder withdraws his bid during the period of bid validity, or
 - b In the case of a successful Bidder, if he fails or refuses within the specified time limit, to:
 - i Sign the agreement, or
 - ii Furnish the required performance security.

5. VARIATIONS OR DEVIATIONS IN BID DOCUMENTS

- 5.1 The bid shall submit an offer which complies fully with the basic requirements of the bid Documents as indicated in Drawing and Specifications.
- 5.2 All Bidders are cautioned that no conditional offers, variations or deviations by the Bidders in respect of any items proposed by the Bidder shall be entertained or considered

further in the process of bid evaluation. Furthermore, any deviation from contract conditions, specification, or other requirements stipulated in these Bid Documents shall be summarily rejected as non-responsive.

6. VALIDITY OF BID

6.1 The Bid shall remain valid and open for acceptance for a period of 4 (four) months after the date of opening of bid.

6.2 In exceptional circumstances, prior to expiry of the original bid validity period, the Employer may request the Bidder for a specified extension in the period of validity. The request and the responses thereto shall be made in writing through post, fax etc. A Bidder may refuse the request without forfeiting his bid security. A Bidder agreeing to the request will neither be required nor permitted to modify his bid, but will be required to extend the validity of his bid security correspondingly. The provision of Clause D regarding discharge and forfeiture of earnest money shall continue to apply during the extended period of bid validity.

7. FORMAT AND SIGNING OF BIDS

The complete bid shall be without alterations, interlineations or erasure, except those to accord with instructions issued by the Employer or as necessary to correct errors made by the Bidder, in which case such corrections shall be initiated by person or persons signing the bid.

8. EMPLOYER'S RIGHT TO ACCEPT ANY BID AND TO REJECT ANY OR ALL BIDS

Notwithstanding, Employer reserves the right to accept or reject any bid, and to annul the bidding process and reject one or all bids, at any time prior to the award of contract, without thereby incurring any liability to the affected or tenderer's or any obligation to inform the affected Bidder or Bidders of the grounds of the Employer's action.

9. NOTIFICATION OF AWARD OF CONTRACT

Prior to the expiry of the period of bid validity prescribed by the Employer, the Employer will notify the successful Bidder by telegram / cable or fax (and subsequently confirm in writing by Registered Letter) that his bid has been accepted. This letter called "Letter of Acceptance" shall name the sum which the Employer will pay to the Contractor in consideration of the execution, completion and maintenance of the work by the Contractor as prescribed by the Contract (called the "Contract Price").

10. The Letter of Acceptance will form part of the Contract and agreement executed between the parties in accordance with the Form of agreement provided in the bid.

11. Upon furnishing by the successful Bidder of a Performance Security in accordance with the provisions of the special conditions of contract, the Employer will promptly notify the

unsuccessful Bidder that their bids have been unsuccessful and will discharge / return without interest their bid security deposits in pursuance with Clause.

12. **SIGNING OF AGREEMENT**

At the same time as he notifies the successful Bidder that his bid has been accepted, the Employer will instruct the successful Bidder to sign and execute the agreement within seven (7) days of issue of the Letter of Acceptance.

Signature of Contractor/Bidder

Executive Engineer (Elect-III)
JDA, Jaipur

2-SPECIAL CONDITION FOR POST ASSESSMENT

Note: - Joint Venture/Consortium will not be allowed.

1. The financial bid shall be opened only of those successful Bidders who qualify the technical Bid criteria.

Documents to be submitted with financial bid are as follows:

Percentage Rates on G-Schedule both in figures and in words duly filled in.

The financial bid will be evaluated on the basis of basic rates of the System (SITC of the Job).

On bid scrutiny, if differences are found in rates given by the bidder in words and figures in individual rates or in sub-total or in grand totals the procedure for deriving the final value shall be as follows:

Before submission of the bids, the bidders are advised to visit the site and get acquainted with site conditions, availability of materials & labour. All clarifications must be sought by the bidders well in time and no extension of time shall be given on this account.

The bidders are advised to account for any fluctuations in market rates of material, equipment cost, labour rates etc. Any claim on these accounts shall not be entertained after the award of work unless specifically agreed to.

Bids not submitted on prescribed form are liable to be rejected.

Bidders are advised to quote original offer as per bill of quantities.

In case drawing and details are not enclosed with bid documents, these can be seen in the office of the department during office hours. Failure to avail of this shall not relieve the bidder of his responsibility of correct interpretation of work involved. Bidders who resort to canvassing in any form shall be liable to rejection.

Printed Conditions of contract: Any printed conditions and conditions contrary to these conditions of contract in contractors offer shall be excluded from the contract and not applicable to this contract.

The bid shall be valid for acceptance for a period of four months from the date of submission of the bid.

2. EXECUTION DRAWINGS

The successful bidder shall have to submit execution drawing to the department within a total period of 1 week from the date of issue of work order for approval by the department

3. TERMS OF PAYMENTS

As given in general Condition of contract in the approved standard agreement amended up to date.

No escalation charges shall be payable to the contractor over and above the rates as agreed to by the department in the detailed bill of quantities.

No advance shall be payable to the contractor.

The department does not bind themselves to accept the lowest or any bid and reserves the right to accept or reject any or all the bids in whole or in part without assigning any reasons for doing so.

The contractor must acquaint, acquire themselves with the site conditions, means to access the work, local conditions and all matters pertaining there to shall be the contractors, responsibility to obtain all necessary information required for quoting the above bid and for entering into a contract. The detailed drawing and specifications available with the documents must be studied and examined carefully by the bidder before submitting their offers.

The successful bidder shall sign the agreement on non judicial stamp paper of requisite value within 10 day from the issue of work order. If the contractor selected fails to sign the agreement within ten days of the issue of work order his bid security shall be forfeited.

The following documents shall form part of the contract agreement: Invitation to bid.

All sections of financial and technical bid, contract (agreement), Bill of Quantities & drawings.

All correspondence between the successful bidder and the department. Any other documents necessary for completion of contract agreement.

The rates quoted in the bid shall include all charges for scaffolding, water, electricity charges, hiring charges for any tools/ equipments etc. required for completion of jobs. The rates shall be inclusive of excise duty, sales tax, octroi duty or any other duties or fees levies by Government or by public or local bodies from time to time.

Necessary documents for import shall be done by the contractor under his own arrangements for equipments of foreign origin. Proof of legal imports! purchase from manufacturer should be submitted at the time of supply, failing which the award may be terminated.

The works contract price quoted shall remain firm till completion of job and handing over the same in working condition to the department. The price should not be subject to exchange rate variations. No foreign exchange and license shall be arranged by Clint and it shall be contractor's responsibility to do so, if required.

It shall be contractor's responsibility to check and ascertain the correct quantities and only these assessed quantities in accordance with the requirement and as per the tentative schedule of work after approval of the Engineer-in-charge shall be brought at site after award of work order.

The contractor shall carry out additional/Reduce work or supply material/ equipments at the same quoted rates up to any increased or decreased quantities specified in detailed bill of quantities. The department shall also be at liberty to ask the contractor to supply, erect and commission rates within four months of stipulated date of commencement of the work order without any price variation.

4 BAR CHART & CASH FLOW CHART

The contractor shall prepare & submit a bar chart & cash flow chart in consultation with the department and shall strictly adhere to the same. The progress and the completion of the work shall be in accordance of the bar chart will form part of this contract agreement. The said schedule of work/ bar-chart will be subject to general conditions of contract related to the extension of time. A weekly progress of site shall be submitted in writing to the department.

5 PERFORMANCE BOUND CONTRACT

The contract shall be a performance bound contract and therefore the contractor shall makes his independent checks for Mounting, selection of equipment, etc. The drawings enclosed with the bid documents are only tentative and for guidance for bidding purposes. The details or execution drawings shall be prepared and submitted for approval to the department by the successful contractor to suit the requirement pertaining to site conditions.

6 TRAINING OF PERSONNEL

The contractor shall impart training to the departmental staff free of cost during erection and commissioning of the plant

7 GUARENTEE

The contractor shall guarantee the complete system & equipments for a period of 12 months from the date of satisfactory handing over of the plant as certified by the department for fault/ bad workmanship, manufacturing defects in equipments etc. The Bidder shall guarantee the System to maintain the sound quality on the basis of Design/ Scheme. They shall also guarantee that the performance of the various equipments individually and jointly and shall not be less than the specified rating when working under operating conditions for the complete installation.

8 The commissioning of system shall be done by the contractor and all tests at site shall be conducted to confirm the bided specification should be submitted to the department for record.

9 REPAIR/ REPLACEMENT OF PARTS DURING GUARENTEE

- Any defects or other faults which may appear within defect liability/guarantee period of twelve months from the date of handing over the system in a satisfactory working conditions to the department arising in the system due to material or workmanship should be corrected and replace with parts of original specifications and makes by the contractor at his own cost.
- 10 Security deposit will be returned to the contractor after 12 month from the date of finalization of work and successful operation of the system as judged by the department.
- 11 POWER SUPPLY FOR ERECTION PURPOSES**
- The contractor shall make his own necessary arrangements for power supply required for erection purposes by applying to JVVNL for a separate connection at his own cost or through his own DG set.
- 12 The contractor shall have to submit original voucher/ bills of various items to be used in execution of work.
- 13 The Octagonal Poles will be dispatch after issuance of certificate from JDA Engineer that the material is fit for dispatch, even after receiving the ornamental poles at site JDA reserve the right to send the material to any Govt. / Semi Govt. / Private lab for testing and if the pole is not found as per specification, the bidder will require to replace the complete material at his own cost.
- 14 All the materials to be used for electrification work must be inspected by Engineer-in-charge or any nominated Engineer of J.D.A. at Factory/ Laboratory before dispatch to the site at the cost of contractor. The contractor shall have to inform seven days in advance for the inspection.

**Signature & Seal of
Contractor/Bidder**

**Executive Engineer (Elect-III)
JDA, Jaipur**

3. SPECIAL CONDITIONS

- The following condition is now the part of the tender document.
- 🚩 "If any bidder quotes a rate below than the schedule "G" rates, i.e. rates below than "at par", then the bidder has to deposit the difference amount i.e. difference amount of the rates as per "at par" and quoted "below", as "work Performance Guarantee." This amount has to be deposited before the commencement of work and will be refund after successful completion of DLP Period. Lowest bidder will be issued LOA (Letter of Acceptance) and within 14 days period he has to deposit difference amount in the form of B.G./FDR/NSC. The validity of these shall be for a period three months beyond the date for completion of DLP Period as per requirement. In case of non-deposition of the same in specified period, the Bid Security will be forfeited. In case work is not completed satisfactorily, the "work performance guarantee" will be forfeited and other action will be taken as per Contract Agreement (Order No. प.01(24)नविवि/1/2020 लूज जयपुर, दिनांक 20.09.2021)."

SCHEDULE 'H'

1. If there is any typographical error or otherwise in the 'G' Schedule the rate given in the relevant BSR on which Schedule 'G' has been prepared, shall prevail.
2. The contractor shall follow the contractor labour regulation and abolition Act 1970 & Rule 1971.
3. The JDA shall have right to cause an audit technical examination of the work and the final bills of the contractor including all supporting vouchers, abstract etc. to be made within two years after payment of the final bills and if as a result such audit any amount is found to have been over paid / excess in respect of any work done by the contractor under the contract or any work claimed by him to have been done under this contract and found not to have been executed the contractor shall be liable to refund such amount and it shall be lawful for the JDA to recover such sum from him in the manner prescribed in special condition no. 8 or any other manner legally permissible and if it is found that the contractor was paid less than that was due to him under the contract in respect of work executed by him under it, the amount of such under payment shall be paid by the JDA to the contractor.
4. The contractor shall not work after the sunset and before sunrise without specific permission of the authority Engineer.
5. Wherever any claim against the contractor for the payment of a sum of money arises out of under the contracts, the JDA shall be entitled to recover the sum by appropriating in part or whole of the security deposit of the contractor, In the event of the security being insufficient or if no security has been taken from the contractor then the balance of the total sum recoverable as the case may shall be deducted from any sum then due or which at any time there contract with the JDA should this sum be sufficient to recover the full

- amount recoverable. The contractor shall pay to JDA on demand the balance remaining due. The JDA shall further have the right to affect such recoveries under P.D.R. Act.
6. The rate quoted by the contractor shall remain valid for a period of 4 (Four) months from the date of opening of the bids.
 7. By submission of this bid the contractor agree to abide with all printed conditions provided in the PWD manual from 64 (Chapter 3-para 36) and subsequent modification.
 8. No conditions are to be added by the contractor and conditional bid is liable to be rejected.
 9. All transaction in this execution of this work and this bid will be liable to Sale-Tax vide section. 2(B) read with sub-clause (4) Sale-tax Rule, 1954.
 10. If any bidder withdraws his bid prior to expiry of said validity period given at S.No. 7 or mutually extended period or makes modifications in the rate, terms and conditions of the bid within the said period which are not acceptable to the department or fails to commence the work in the specified period, fails to execute the agreement and fails to furnish performance guarantee the department shall without prejudice to any, other right or remedy, be at liberty to forfeit the amount of earnest money given in any form absolutely. If any contractor, who having submitted a bid does not execute the agreement or start the work or does not complete the work and the work has to be put to rebidding he will stand debarred for 6 Months from participating of bidding in JDA in addition to forfeiture of Earnest Money / Security Deposit and other action under agreement.
 11. The contractor shall arrange his own machinery required for the work such as Bitumen Mixer, Hot Mix plants and paver, road roller, Tar boiler, sprayer etc.
 12. The contractor shall arrange his own storage tanks up to 10 Tones capacity for storage of bulk bitumen wherever supplied by the department.
 13. Rules regarding enlistment of contractor provide that work up to the times limit for which they are qualified for bidding can be allotted to them, Therefore, before bidding the contractor will keep this in mind, and submit the details of the work. Bids with incomplete or incorrect information are liable to be rejected.
 14. Any material not conforming to the specifications collected at site have to be removed by the contractor within a period of 3 days of the instruction, issued by the Engineer -In charge in writing failing which, such material shall be removed by the Engineer-In charge at risk and cost of the contractor after expiry of 3 days period.
 15. The material collected at site and paid provisionally shall remain under and ward of the contractor till it is consumed, fully on the work.
 16. The rates provided in bid documents are inclusive of all Taxes and royalty.
 17. For paver work at least 3 road rollers shall be simultaneously deployed.

18. No extra lead of earth/material shall be paid over and above as specified in 'G' Schedule Source/borrow pit area for earth shall have to be arranged by the Contractor at his own cost.
19. Undersigned has full right to reject any or all bids without given any reasons.
20. Mortar of Masonry work and lean concrete will be permitted mixer with hopper.
21. As per Supreme Court decision "All contracts with Governments shall require registration of workers under the building and other construction workers (Regulation of Employment and Conditions of Service) Act, 1996 and extension of benefits to such workers under the act.
22. Special Conditions of Contract regarding Defect Liability Period (DLP) for Roads works costing Rs. 25.00 lacs and more shall be applicable
23. The bidders are required to submit copy of their enlistment as contractor.
24. Conditions of RPWA-100 will be mandatory & acceptable to the contractor.
25. Any bid received with unattested cutting/ overwriting in rates shall be rejected and such bidder will be debarred from bidding for three months in JDA.
26. All the provision of THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT 2012 and Rules, 2013 will be applicable. If there is any contradictions in existing special conditions and provisions of THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT 2012 and Rules 2013 provision of THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT 2012 and Rules 2013 shall be applicable.

SIGNATURE OF CONTRACTOR
WITH FULL ADDRESS:

Executive Engineer (Elect.-III)
JDA, Jaipur

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR
Special Terms & Conditions for Electrification work.

1. The Contractor has to give the performance guarantee of the following materials for the period mentioned against them from the date of completion of work:

(a)	Transformers	30 Months
(b)	All types of Insulators	18 Months
(c)	ACSR Conductors	6 Months
(d)	Isolators	6 Months
(e)	Horn gap fuse set	6 Months
(f)	LT Pillar Box	6 Months
(g)	All types of HT/LT cables	18 Months
2. The Contractor has to arrange for the permission for the charging of electrical system from the Electrical Inspector Govt. of Rajasthan. He will have to deposit the necessary fees, which shall be reimbursed by Jaipur Development Authority.
3. The contractor will coordinate for the system handing over and charging process and if any defects, is pointed out by the RSEB/JVVNL, then he will have to rectify the same.
4. The final bill shall be paid after the lines and substations are handed over to RSEB/JVVNL and system is charged.
5. Inspection shall be bear by the contractor it self.
6. The material shall be purchased from the firms, which are also supplying the material to RSEB/JVVNL.
7. All HT/LT cables should be sequentially marked with cable size, IS Code, grade, manufacturer name & length at every per meter duly embossed.
8. The contractor shall return unused material issued to him by the deptt. If desired by the Engineer in-charge and in case, of failure to do so he shall be charged for such unreturned material at double the issue rate including storage and supervision charges or the market rate whichever is higher. The basis of the theoretical consumption and allowing for wastage @ 5% at double the issue rate including storage and supervision charges or market rate which ever is higher.
9. **The contractor shall be fully responsible to follow safety code as per IS 3764:1992 (upto date). The work should be executed without damaging existing water pipe line, LT/HT electric under ground cable, poles, existing surface drain, water connections, Telephone cables etc. In case of any damages the penalty/ liability imposed for such work shall be borne by the contractor and shall be got repaired immediately by arranging material/ labour/ assistance etc. In case of delay JDA reserve right to execute/ get executed the work at the cost and risk of the contractor.**
10. It is a mandatory condition that contractor will get all insulated material tested from CTL of JVVNL or other specified NABL accredited agency by JDA before using it at site.
11. The contractor or his authorized representative shall intimate in advance along-with complete programme of erection & commissioning where ever shunt down of existing line is required, to the Nodal officer / Engineer In-charge of the site for arranging shut downs. The contractor shall have to plan the work in such a way that in minimum duration of shut down maximum work is carried out to avoid repeated and / or longer duration shut downs.

Executive Engineer (Elect-III)
JDA, Jaipur

I carefully study & do agree for above terms & conditions.

Signature & Seal of the Contractor

4-INSPECTION AND TESTING AT MANUFACTURER'S PREMISES

1. The test of the material and workmanship shall be conducted by the JDA/JVVNL Engineers as necessary. The result of such tests should confirm to be standard laid down in the Indian standards and or the standards laid down in the detailed specification of the JVVNL/ .Public Works.
2. Proper quality control is required to be maintained by the contractor. Qualified personnel's having a degree in engineering or as required under the contractor enlistments rules duly approved by the Deptt. Shall have to be engaged at site by the contractor. The Deptt. Reserves the right to engage such staff and recover the expenses from the contractor on such account in case of his failure to do so.
3. The GTP of the material to be used by the contractor shall be submitted 21 days in advance with the Engineer In charge and be got approved by him before use.
4. All inspection and testing shall be carried out in accordance with the Specification and in absence of Specification relevant Indian Standard or internationally approved equivalent standard. After award of contract, Bidder shall furnish QA plan which will be mutually discussed with the Owner and finalized QA plan shall include test and incoming supply of raw materials and bought out items, stage inspections and tests on finished products at manufacturer's works / appropriate testing station. QA plan shall clearly indicate tests which are intended to be witnessed by the Bidder alone and those by both Bidder and Owner.
5. The Contractor shall carry out wherever practical, at the place of manufacture tests of the Plant / Equipment.
6. The Owner shall be entitled to attend the aforesaid inspection and / or tests by his own duly authorized and designated representatives.
7. The Owner and his duly authorized representative shall have access to the Contractor's premises at all suitable times to inspect and examine the material and workmanship of the mechanical and electrical plant and equipment during its manufacture there. If part of the plant and equipment is being manufactured on other premises, the Contractor shall obtain permission for the Owner or his duly authorized representative, to inspect as if the plant and equipment was manufactured on the Contractors own premises. Testing (including testing for chemical analysis and physical properties) shall be carried out by the Contractor and certificates submitted to the Owner who will have the right to witness or inspect the above mentioned inspection / testing at any stage desired by him. Where inspection or testing is to be carried out at a subcontractor's works, a representative of the Contractor shall be present.
8. The procedure for the testing and inspection to be carried out during or following the manufacture of the materials to ensure the quality and workmanship of the materials and to further ensure that they conform to the Contract is whatever place they are specified shall be as described below.
 - (a) The Contractor shall give the Owner at least 21 clear days notice in writing of the date and the place at which any plant or equipment will be ready for inspection/ testing as provided in the Contract. The Owner or his duly authorized representative shall thereupon at his discretion notify the Contractor of his intention either to release such part of the plant and equipment upon receipt of works test certificates or of his intention to inspect. The Owner shall then give notice in writing to the Contractor, and attend at the place so named the said plant and equipment which will be ready for inspection and/or testing. As and when any plant shall have

passed the tests referred to in this section, the Owner shall issue to the Contractor a notification to that effect.

- (b) The Contractor shall forward to the Owner duly certified copies of the test certificates and characteristics performance curves for all equipment.
- (c) If the Owner fails to attend the inspection and/or test, or if it is agreed between the parties that the Owner shall not do so, then the Contractor may proceed with the inspection and/or test in the absence of the Owner and provide the Owner with a certified report of the results thereof as per (b) above.
- (d) If any materials or any part of the works fails to pass any inspection / test, the Contractor shall either rectify or replace such materials or part of the works and shall repeat the inspection and/or test upon giving a notice as per (a) above. Any fault or shortcoming found during any inspection or test shall be rectified to the satisfaction of the Owner before proceeding with further inspection.
- (e) Where the plant and equipment is a composite unit of several individual pieces manufactured in different places, it shall be assembled and tested as one complete working unit, at the maker's works or at site as mutually agreed by the Owner and Contractor.
- (f) Neither the execution of a inspection test of materials or any part of the works, nor the attendance by the Owner, nor the issue of any test certificate pursuant to (c) above shall release the Contractor from any other responsibilities under the Contract.
- (g) The test equipment, meters, instruments etc., used for testing shall be calibrated at recognized test laboratories at regular intervals and valid certificates shall be made available to the Owner's at the time of testing. The calibrating instrument used as standards shall be traceable to National/International standards. Calibration certificates or test instruments shall be produced from a recognized Laboratory for the Owner's consent in advance of testing and if necessary instruments shall be recalibrated or substituted before the commencement of the test.
- (h) Items of plant or control systems not covered by standards shall be tested in accordance with the details and program agreed between the Owner and Contractor.
- (i) Tests shall also be carried out such that due consideration is given to the Site conditions under which the equipment is required to function. The test certificates shall give all details of such tests.
- (j) The Contractor shall establish and submit a detailed procedure for the Inspection of materials or any part of the works to the Owner for approval within the date indicated in the Programme Details. The detailed procedure shall indicate or specify, without limitation, the following:
 - (i) Applicable code, standard and regulations
 - (ii) Fabrication sequence flow chart indicating tests and inspection points
 - (iii) Detailed tests and inspection method, indicating tests and inspection points
 - (iv) All routine tests shall be carried out as per relevant Indian Standard specifications and will be witnessed by the Owner,
 - (v) Acceptance criteria
 - (vi) Test report forms and required code certificates and data records
 - (vii) Method of sampling, if any sampling test to be conducted
 - (viii) Contractor's or Owners witness points.

- (k) The Contractor shall not pack for shipment any part of the Plant until he has obtained from the Owner or his authorized representative his written approval to the release of such part for shipment after any tests required by the Contract have been completed to the Owner's satisfaction.
- (l) The contractor shall be liable to bear all the expenses to carry out the inspection at the manufacture works.

Signature of Contractor/Bidder

Executive Engineer (Elect-III)
JDA, Jaipur

5-MINIMUM SAFETY RULES

The following are Minimum Safety Rules that apply to all contractors and subcontractors associated with this project. All project personnel have a duty and responsibility to ensure familiarization with project safety requirements and to comply with all requirements established by their employer.

1. **REPORTING HAZARDS:** It is part of each employee's job to report all unsafe conditions/practices to his immediate supervisor for corrective action.
2. **BASIC PERSONAL PROTECTION** for this project includes:
 - a) Safety Hats of the approved type which meet Indian Standard shall be worn while on construction sites (hats shall not be Pressed or altered in any way as to make them defective). Hard hats shall be worn the way they are intended to be worn. Metal hard hats are prohibited.
 - b) Industrial grade safety glasses with side shields meeting ANSI standards Z-87 or equivalent Indian Standards will be worn by all personnel. This also applies to all persons wearing prescription glasses. Additional eye protection may be necessary for various work activities such as grinding, chipping, drilling, chemical handling, etc.
 - c) Hearing protection will be worn at posted high-noise areas or work activities generating high-noise levels.
 - d) Shirts are required when working on a construction site. All shirts will have sleeves. Sleeveless shirts are not permitted.
 - e) Full length trousers are required and must fit properly. Loosely fitting clothing will not be worn.
 - f) Safety shoes or safety boots will be worn in the construction area at all times. No sneakers, open-toed shoes or tennis shoes are allowed. All shoes will be suitable to the construction environment.
 - g) Gloves will be worn when handling materials that may cut, tear or burn hands. Gloves will be in good condition and free of excessive oil or grime.
3. **RESPIRATORS:** Persons engaged in work activities requiring breathing apparatus or respirators will be test-fitted to ensure a proper seal and fitting.
4. **FALL PROTECTION:** Safety Belts/Harnesses shall be worn and used when working at two meter heights (or greater), where approved platforms, ladders, or scaffolds are not provided. Lanyards will be no more than six feet in length. Horizontal or vertical lifelines will be provided and used where no tie-off points are provided. Belts/Harnesses shall be worn properly. All fall protection equipment will be inspected for defects by the user before each use. Defective or questionable protection equipments shall not be used.

5. **INJURIES:** All persons must report all injuries to their supervisors and obtain first aid (regardless of degree of severity) at the contractor's first aid facility. Each accident must be documented on the Accident Notification Report.
6. **SMOKING:** Smoking within an establish NO SMOKING AREA is strictly prohibited and is sufficient cause for immediate removal of the person found smoking from the site.
7. **ELECTRICAL EQUIPMENT :** Personnel (except electricians), assigned to work on or around specific electrical jobs, will stay clear of all electrical equipment until it is proven safe by qualified electrical personnel.
8. **UNAUTHORIZED USE:** The unauthorized operation of any tool, equipment, switch, vehicles, valves, etc. is strictly prohibited.
9. **MAKESHIFT DEVICES:** Personnel will not fabricate or use makeshift devices such as lifting devices, tools, etc. Specialized tools/equipment are often necessary, but will be properly designed and tested by authorized engineering personnel before use. The modification of tools/equipment or the overriding of safety devices will not be tolerated.
10. **TRUCK RIDING:** Riding in the bed of trucks is prohibited unless seating arrangements conform to client requirements. Personnel are forbidden to ride on loaded trucks, fenders, running boards, sideboards, tailgates, etc.
11. **SEAT BELTS:** All personnel riding in vehicles will fasten seat belts before the vehicle is placed in motion.
12. **HORSEPLAY:** Running, practical jokes, etc. prohibited. Fighting is sufficient cause for immediate dismissal. "Short cutting" of established safe practices or deliberate chance-taking is strictly prohibited.
13. **WORK PERMITS:** If work to be carried out requires a permit, the permit must be obtained before work commences.
14. **EMERGENCY PROCEDURES:** It is part of everyone's job to thoroughly know plant emergency procedures, emergency alarms, location of assembly areas, etc.
15. **WORKING POSITION:** Personnel must always ensure safe working positions. Any person to position himself between a fixed object and a moving piece of equipment is extremely hazardous. Never place yourself between objects which could roll, shift, fall or be displaced. Stay alert to conditions around you at all times.
16. **SAFE & PRESCRIBED METHODS:** All tools and equipment, including motor vehicles will be operated in a safe and prescribed manner at all times. If any person is not sure of the proper method of tool/equipment use, he must immediately inform his supervisor for the person to receive proper direction.
17. **INSTRUCTIONS FROM SUPERVISORS:** Supervisors are responsible for strict compliance and enforcement of project and client safety rules and regulations, and to

- ensure that workers are made knowledgeable of requirements. All personnel are required to follow instructions from their immediate supervisors. If instructions are not clear or are confusing, the employee has a responsibility to question the supervisor and obtain clear instructions before commencement of work.
18. **CO-OPERATION AND TEAMWORK:** It takes co-operation and teamwork to complete construction projects in a safe, efficient and timely manner. All project personnel are expected to render complete co-operation in the administration and enforcement of the project Safety Program.
 19. **CAMERAS:** Employees must not, under any circumstances, bring cameras onto the work site or use a camera on the work site without written approval of Engineer-In-Charge.
 20. **DRUGS/ALCOHOL:** The use of illegal drugs and alcohol is strictly prohibited and is cause for immediate removal of the person who is found to be under influence of such drugs / alcohol from the site.
 21. **DISCIPLINARY ACTION:** Disciplinary action will be taken against persons violating the stipulations. Serious infractions and/or repeat offenders will be dealt with severely, up to and including permanent removal from the project.
 22. **RESPONSIBILITIES;** All persons have a responsibility to themselves and their co-workers to be physically fit and mentally alert at all times. Conditions on a construction site are always in a state of change. Personnel must be able to react accordingly.
 23. **LADDERS AND SCAFFOLDS:** All ladders and scaffolding shall be of the approved type. Ladders and scaffolding not meeting standards shall be removed from service. Ladders and scaffolding shall meet Indian Safety Standards or British Standards whichever is more stringent.

LADDERS:

- a) Ladders shall be inspected prior to use. Defective ladders shall be removed from service.
- b) Ladders used near energized lines or equipment shall be made of non- conductive materials (wood, fiberglass, etc.)
- c) Ladders shall be placed on solid footing. They shall not be placed on unstable objects such as loose bricks.
- d) Employees shall not carry tools, materials, or objects while climbing ladders. Employees shall face the ladder while climbing and avoid leaning from side to side and away from the ladder.
- e) Employees working from ladders shall wear and utilize proper fall protection equipment.

- f) Straight and extension ladders must be secured at the top when in use. Ladders not in use should be removed from the vertical position.
- g) Ladders must be placed at an angle not to exceed one foot of run for every four feet of rise.
- h) Ladders must extend above their upper support or landing by at least 3 feet.
- i) Step ladders must be secured or held when in use.
- j) Employees shall not work from the top step or next to the top step of step ladders.

SCAFFOLDS:

- a) Employees shall not erect, alter or dismantle scaffolds unless directed by a competent person.
- b) Scaffolds shall be erected, should be in plumb, and on sound foundation. Loose bricks, unstable stacks of lumber, etc. shall not be used to level or support scaffolds.
- c) Scaffold materials shall be free of defects.
- d) Work platforms shall be completely decked. (The decking should overhang its end supports at least 6 inches but not more than 12 inches. The decking shall be secured in place).
- e) Work platforms shall be equipped with standard handrails, midrails, and toe boards when 2 meters or more in height.

24. EXCAVATIONS:

- a) When deeper than 5 feet, excavations shall be sloped or shored to prevent caving-in.
- b) Excavations must be barricaded and barricades shall be maintained till back filling is completed.
- c) Excavated earth and any equipment shall be kept at least 2 feet from the edge of excavations.
- d) Access ladders shall be placed within a distance of 25 feet of location of working in excavations of 4 feet deep or deeper.

25. CONFINED SPACE OR VESSEL ENTRY:

- a) Employees shall not enter any confined space unless it has been tested for oxygen contents, absence of flammable gases and/or substances, or any other hazardous materials, and a written permission has been issued.
- b) A man *way* watch trained in his duties shall be present at any time when personnel are inside confined spaces or vessels.

- c) Portable or hand-held lighting should not exceed 12 volts power source.
 - d) Positive ventilation (air movers or fans) shall be used to provide exchange of fresh air in confined spaces and vessels.
- 26. TAG-OUT, LOCK-OUT PROCEDURES:**
- a) Employees shall not perform any work including repair, changes, attachments on electrical circuits, equipment, or mechanical equipment unless the power supply or source of said equipment is positively disconnected or shut off and the concerned electrical department employee places his lock and tag on the disconnect.
 - b) Only electrical personnel shall be involved in energizing & de-energizing electrical circuits and equipment.

Signature of Contractor/Bidder

Executive Engineer (Elect-III)
JDA, Jaipur

6-Guarantee

1. General

The guarantee is applicable for the performance of individual equipment as well as overall performance of the Project.

In case of any contradiction given in this section with respect to those mentioned elsewhere in this document the below mentioned clauses shall prevail.

2. Manufacturer's Guarantees

The manufacturer's guarantee for design, workmanship and performance for all bought out items shall be made available to the owner and shall be valid at least for the entire defects liability period. In the event of failure of any particular equipment which fails more than three times during the guarantee period as mentioned in clause below, the contractor shall replace at his own cost that equipment. Manufacturer's / Contractor's guarantee, for such replaced equipment shall also be made available to the Owner and should be kept at least for one year from the date of last replacement.

3. Performance Guarantee for Electrical Systems

The Contractor shall give guarantee for a period of one year from the date of successful commissioning of the Electrical system against design, defective materials, workmanship and performance. **The contractor shall give guaranteed for HV and MV Panel and performance, quality of cables, luminaries, DB's, Utility sockets as indicated in the bid and as agreed between the owner and contractor before award of contract.** Any defects found in the workmanship, materials or performance of the unit shall be made good by the Contractor at his own expense within the time specified by Engineer-In-Charge.

In case the parameters vary from what is required, the Contractor shall rectify the equipment at no extra cost so as to achieve the requisite performance guarantee and satisfy commissioning of the equipment to the Engineer-In-Charge. In case the Contractor fails to achieve any of the aforesaid guarantees he will be penalized by an amount as per rule up to 10% (ten percent) of the total contract value. For this purpose any money due to the Contractor shall be forfeited and adjusted against such penalty.

4. Equipment Guarantee

The Contractor shall guarantee for the period of one year from the date of successful commissioning of the Electrical System against defective performance of all equipment / instruments / mechanical or electrical parts under Contractor's scope of supply. Any defects found either in materials or workmanship shall be made good by the Contractor at his own expense within the time specified by the Engineer-In-Charge.

5. Testing and Trial Run

The contractor shall have to try test each process equipment used for the Electrical System for about 48 hours continuous running to the full satisfaction of the Engineer-In-Charge. After satisfactory testing of the individual equipment, the Contractor shall run the whole Electrical System at no extra cost to the owner for at least 30 days as directed by the Engineer-In-Charge and ensure the treated waste water quality. Necessary instruments, gauges, supervisory personnel etc. shall be furnished / provided by the Contractor free of cost for conducting the trial runs.

6. Commissioning and Handing Over

During trial runs as described above, the Contractor shall satisfy the Engineer-In-Charge in all respects regarding the satisfactory quality of materials; equipment and workmanship used in the Electrical System and guaranteed parameters. Only after satisfying himself, regarding the above points, the Engineer-In-Charge will issue the completion certificate and take over the Electrical System and such date of taking over shall be deemed as date of commissioning. The Defects Liability Period described above will start from this date.

Signature of Contractor/Bidder

Executive Engineer (Elect-III)

JDA, Jaipur

7-ERECTION, TESTING AND COMMISSIONING

1. ERECTION - GENERAL

- 1.1 The Contractor's staff shall include adequate and competent erection Engineer with proven, suitable, previous experience on similar contracts to supervise the erection of the Works and sufficient skilled, semi-skilled and unskilled labour to ensure completion of Works in time. The Contractor shall not remove any representative, erector or skilled labour from the Site without prior approval of the Owner.
- 1.2 The Contractor shall ensure that no installation or erection work shall commence until full and unconditionally approved working drawings, signed and stamped by the Owner are available at Site.
- 1.3 The Contractor's erection staff shall arrive on the Site on dates to be agreed by the Owner. Before they proceed to the Site, however, the Contractor shall first satisfy himself, as necessary, that sufficient Electrical System of his (or his sub-contractor's) supply has arrived on Site so that there will be no delay on this account.
- 1.4 One erection engineer who shall be required to be the Contractor's representative shall be conversant with the erection and commissioning of the complete Works. Should there be more than one erector, one shall be in charge and the Contractor shall inform the Owner in writing which erector is designated as his representative and is in charge. Erection engineer is to report to Project Manager.
- 1.5 The Contractor shall be responsible for setting up and erecting the Electrical System to the line and levels of reference and of the positions, levels dimensions and alignment, appliances and labour in connection therewith. The checking of setting out of any line or level by the Owner shall not in any way relieve the Contractor of his responsibility for the correctness thereof.
- 1.6 Erection of Electrical System shall be phased in such a manner so as not to obstruct the work being done by other contractors or operating staff who may be present at the time. Before commencing any erection work, the Contractor shall check the dimension of structures where the various items of Electrical Systems are to be installed and shall bring any deviations from the required position, lines or dimensions to the notice of the Owner. Electrical System shall be erected in a neat and workmanlike manner on the foundations and at the locations shown on the approved drawings. Unless otherwise directed by the Owner, the Contractor shall adhere strictly to the aforesaid approved drawings. If any damage is caused by the Contractor during the course of erection to new or existing Electrical System or buildings or any part thereof, the Contractor shall, at no additional

- cost to the Owner, make good, repair or replace the damage, promptly and effectively as directed by the Owner and to the Owners satisfaction.
- 1.7 The Contractor shall align all equipment and holding down bolts and shall inform the Owner before proceeding with grouting-in. the items concerned. The Contractor shall ensure that all equipment is securely held and remains in correct alignment before, during and after grouting-in.
- 1.8 The approval by the Owner of the Contractors proposals for rigging and hoisting any items of the Electrical System into final positions shall not relieve the Contractor from his responsibility for damage to completed structures, parts or members thereof or other installed equipment. He shall at his own cost make good, repair or replace any damaged or injured items, whether structural, electrical, architectural, or of any other description, promptly and effectively to the satisfaction of the Owner.
- 1.9 No Electrical Systems or other loads shall be moved across the floors of structures without first covering the floors with timber of sufficient size so that applied loads will be transferred to floor beams and girders of steel or concrete. If it is required to reduce bending stresses and deflection, the beams and girders shall be provided with temporary supports. Any movement of Electrical System and other loads over the floor structures shall be subjected to the prior approval of the Owner.
- 1.10 During erection of the Electrical System, the Owner will inspect the installation from time to time in the presence of the Contractor's Site representative to establish conformity with the requirements of the Specification. Any deviations and deficiencies found or evidence of unsatisfactory workmanship shall be corrected as instructed by the Owner.

2 LEVELING AND GROUTING OF MACHINERY

- 2.1 Contractor shall check the civil works, where the Electrical System is to be installed sufficiently in advance, for their conformity to the approved drawings for installing the Electrical System with respect to lines, levels and accuracies of positions embedment, anchorage pockets, cut-outs etc. He shall record all measurements and deviations in prescribed control formats. He shall proceed with the work, with the Owners consent to such preparatory inspection of works.
- 2.2 Contractor shall mark precisely the centre lines and datum reference on the civil works, where the Electrical System is to be installed with reference to bench marks, using indelible means of marking.
- 2.3 He shall undertake sufficiently in advance chipping of any unevenness of concrete on foundations, anchor bolt pockets, cut-outs etc., to achieve uniform level of reference for erection. All concrete surfaces receiving grout shall be hacked as required to ensure better bonding with grouting.

- 2.4 Contractor shall undertake the inspection of all components to be erected sufficiently in advance to check their soundness and conformity to drawings and the inspection records shall be signed by the Owner as approval for undertaking the installation of the components. Any damage, shortfalls etc. shall be made good to the satisfaction of the Owner.
- 2.5 All grout for equipment shall be carried out using non-shrinkable continuous grout materials with suitable framework of at least 12 mm thickness. Surfaces to receive the grout shall be hacked and roughened and laitance shall be removed by wire brushing or blast of air. Concrete surface shall be blown off by compressed air before commencing grouting. Grouting shall be done in one continuous operation from one side such that grout flows in a single wave until grout reaches all confined spaces with no air pockets and air from all confined spaces is expelled. A hydrostatic head of 150 mm shall be maintained during grouting operations hydrostatic head of 150 mm shall be maintained during grouting operations. All grouting shall be carried out in the presence of the Owner. All lines and levels shall be checked up after grout is set. Block outs shall be closed using cement concrete of the same grade as that of the parent structure.

3. RECORDS, PROCEDURES AND REPORTS

- 3.1 The Contractor shall maintain records pertaining to the quality of installation/erection work and inspection, testing, compliance with all technical requirements in respect of all his works as described in the previous paragraphs. The reporting formats shall be in the approved formats. The Contractor shall submit such records to the Owner after the completion of any particular work before submitting the bill of supply/progress of work. Such report shall comprise shop inspection reports, shop testing reports, material test reports, based on which dispatch clearances are provided, all the quality control reports of welding, erection and alignment records.
- 3.2 All the above mentioned records shall be submitted in the final form duly countersigned by the Owner attesting conformity to specifications and his approval of installation, and duly incorporating all the additions, alterations, and information as required by the Owner, on the basis of preliminary reports giving the progress of the work. Such records notwithstanding, any records submitted earlier with bill of supply/progress etc., shall be duly bound and submitted to the Owner in six copies by the Contractor on his notification of the Electrical completion of erection.

4. GENERAL PREPARATIONS BEFORE COMPLETION OF THE ELECTRICAL SYSTEM

4.1 The following documents should be completed in accordance with the Contract schedule before completion of erection. The Owner and the Contractor shall preserve and control these documents in a safe and appropriate place on Site in order that both parties' personnel can make use of them at any time.

(a) Technical Documents

- (i) Operation and Maintenance manual
- (ii) Design documents including the Contractor's design data, drawings and Specifications.
- (iii) Tools and test equipment list
- (iv) Spare parts list

(b) Procedures

- (i) Mechanical testing procedure
- (ii) Electrical testing procedure
- (iii) Instrumentation testing procedure
- (iv) Detailed Pre-commissioning and Commissioning procedure
- (v) Detailed Performance Test procedure

5. COMPLETION OF ERECTION

5.1 The completion of Electrical System under erection by the Contractor shall be deemed to occur, if all the units of the Electrical System are structurally and electrically complete and will include among other such responsibilities the following:

- (a) Electrical System in the Scope of the Contract has been erected, installed and grouted as per specifications.
- (b) Installation checks are completed and approved by the Owner
- (c) The erected Electrical Systems are totally ready for commissioning checks.

5.2 At the stage of completion of erection, the Contractor shall ensure that all the physical, aesthetic and workmanship aspects are totally complete and the Electrical System is fit and sound to undergo tests on completion and subsequent pre-commissioning checks.

5.3 Upon achieving the completion as described above, the Contractor shall notify the Owner by a written notice intimating completion of erection and notify the Owner for inspection. The Owner shall proceed with the inspection of such units within 14 days of such a notice.

- (a) The Owner shall certify completion when there are no defaults in the Works or
- (b) The Owner shall inform the Contractor list of deficiencies for rectification hereinafter referred as Punch list and the Contractor shall complete the rectification work within a jointly agreed period before pre-commissioning activities and obtain the Owner's acceptance or approval of the same before proceeding with the same.

- (c) The Owner may inform the Contractor that the works are accepted with the 'Punch' list (items which do not hamper operability safety or maintainability) and allow the Contractors to proceed with the pre-commissioning checks when the Contractor undertakes to complete such outstanding works within an agreed time during defects liability period. Taking over shall be based on rectification of all deficiencies as advised by Punch lists.
- 5.4 The erection period indicated by the Contractor would be deemed to cover all the activities up to Completion as stipulated in previous paragraphs, notice of completion by the Contractor, inspection by the Owner for Completion, and Contractor rectification of all deficiencies as noticed by the deficiency/Punch list, and acceptance by the Owner of such rectifications, prior to Tests on Completion.
- 5.5 Minor defects, which in the opinion of the Owner which do not hamper operability and maintainability will nor be taken into account for deciding Electrical Completion. Such defects shall be rectified concurrent to commissioning checks before Tests on Completion. However, the Owner's decision in this regard is final.
- 5.6 The commissioning period as notified by the Contractor shall be deemed to occur beyond the date of Completion and shall include all periods of pre-commissioning, trials and Tests on completion.
- 5.7 It is in the Contractor's interest to offer the section/units/systems, progressively under the identified milestones within overall erection period, duly completed for rectification of any deficiencies pointed out by the Owner and to achieve Electrical Completion before undertaking the tests on Completion within the specified erection period. The Owner also reserves the right to withhold the cost as estimated to be equivalent to the rectification of deficiencies pointed out to the Contractor until such a time such deficiencies are rectified to the satisfaction to the satisfaction of the Owner.

6. PRE-COMMISSIONING

- 6.1 After the Completion of erection, Pre-commissioning activities listed below shall be carried out to make the Electrical System ready for Commissioning.
- 6.2 Upon completion of erection of each piece of equipment, facility or discrete part of the Electrical System, Electrical checks and tests shall be carried out according to the Contractor's checklist. The Electrical checks and tests shall be to establish that.
 - (a) The Electrical System is erected in accordance with the Contractor's construction drawings, pipe work drawings, instrument diagrams, etc. issued for the Electrical System.
 - (b) The materials are installed and electrically function in accordance with the Contract and
 - (c) Applicable codes as listed in the Contract are followed for materials and workmanship.

- 6.3 Items such as painting, thermal insulation and final clean up which do not materially affect the operation or safety of the Electrical System will be excluded. All these items shall be listed and completed after the Pre-commissioning or Commissioning at the discretion of the Contractor, but before acceptance.
- 6.4 The Contractor shall prepare and maintain at Site test forms and records that shall include:
- (a) Description of type of test or check
 - (b) Date and time of test or check
 - (c) Identification of equipment and facilities
 - (d) Test pressure, test data and results, including remarks, if any
 - (e) Signature of the Contractor's personnel attesting to data recorded, if any.
- The Contractor's construction forces thereof shall carry out checks, tests and recording.
- 6.5 Wherever the Owner's witness or attesting of the check or test is required, the Owner's personnel shall attend such check and test. For this purpose, the Contractor shall keep the Owner informed of a day-to-day test plan schedule. The test plan schedule may be revised from time to time to reflect the actual progress of the work and test.
- 6.6 Any items found incomplete or requiring repair or adjustment shall be marked as such on the test records and then reported by the Contractor to the Owner and the Contractor's personnel in charge of the relevant construction area.
- 6.7 Checking procedures shall be repeated until all the items on the checklist are cleared
- 6.8 A complete set of test records shall be handed over to the Owner on completion.
- 6.9 The tests on the different Mechanical and Electrical equipment shall include but not limited to:
- (a) Pump motors
Condition of winding insulation be tested and insulation values shall be restored to required level by suitable heating arrangements locally.
 - (b) MV Switch board / Power Distribution Boards
 - (i) Checking of all internal wiring for correctness as per supplier's drawings.
 - (ii) Insulation resistance test.
 - (iii) CT Polarity Test / PT Ratio Test.
 - (iv) Operational check of instruments and testing of relays by primary / secondary injection.
 - (v) Phase sequence test.
 - (vi) Functional simulation test.
 - (vii) Local & Remote Operation.
 - (c) Power and Control Cables

- (i) All cores of cables shall be tested individually for continuity and insulation resistance with earth/sheath/armour as well as between the cores, before as well as after installation.
- (ii) Pressure test as per relevant IS will be carried out on all 11 kV cables together with joints.
- (d) Distribution Boards / Switch Socket Outlets
 - (i) Checking of wiring as per drawing.
 - (ii) Insulation resistance.
 - (iii) Functional test.
- (e) Tests for Earthing System
 - (i) The resistance of each earth pit shall be measured and recorded.
 - (ii) The resistance of the complete earthing system shall be less than 1.0 ohm or values specified by the local Electrical Inspector whichever is less.
 - (iii) Earthing continuity tests shall be carried out for all the equipment.

7. COMMISSIONING

- 7.1 After the completion of Pre-commissioning activities the final checks and preparations necessary for start-up of the Electrical System shall be carried out. The Contractor shall submit to the Owner a written Notice of Electrical Completion that shall include:
- (a) Identity of a part of the Electrical System considered electrically complete
 - (b) A copy of relevant completed test reports
 - (c) The date on which the completion of the tests was achieved
 - (d) Check list and
 - (e) A request for issuance of a Electrical Completion Certificate in respect of that part.
- 7.2 Within fourteen (14) days from the date of receipt of the Contractor's written Notice, the Owner shall:
- (a) In the case of acceptance, issue a Electrical Completion Certificate
 - (b) In the case of Objection, submit a rejection Statement setting forth remaining items to be completed or defects of deficiencies to be corrected before Electrical Completion status can be accepted. When the Owner rejects the Contractor's Notice the Contractor shall take any necessary action to complete or correct the items marked and give the Owner a second Notice of Electrical Completion.
- 7.3 After the issuance by the Owner of a Electrical Completion Certificate, Commissioning activities listed below shall be carried out to enable the start-up and operation of the Electrical System Procedures are described as below:
- (a) Commissioning Procedure shall be carried out in a methodical sequence as follows
 - (i) Warming up
 - (ii) Start-up

- (iii) Initial rearming –
 - (iv) Operability adjustment
 - (v) Stable operation
 - (vi) Final adjustment
- (b) At all stages of commissioning sequence, the Electrical System shall be operated at optimum Electrical System conditions. To ensure this, the Contractor may make minor adjustment to the conditions indicated in the Operation and Maintenance Manual as necessary.
- (c) The Contractor shall check the operating conditions of the Electrical System by constantly monitoring operating data.
- (d) The Contractor shall specify for each discrete part of the Electrical System the operational data to be recorded and the manner in which the data is to be taken.
- (e) All the operating data shall be recorded by the Owner on the forms to be mutually agreed. The Owner shall make a copy of the operating log and analytical data from initial operation through to the completion of Performance Test available to the Contractor for evaluation.

8. PERFORMANCE TEST

- 8.1 After the final operation of the Electrical System, a Performance Test shall be carried out to demonstrate the Contractor's Performance Guarantee.
- 8.2 Prior to conducting Performance Test, the Contractor shall furnish the detailed Performance Test Procedure for approval.
- 8.3 Performance test shall be carried out by the Contractor's personnel according to the instructions set forth in the Contractor's Operation and Maintenance Manual and under the supervision of Owner's operating personnel.
- 8.4 Operating and analytical data recorded during Performance test shall be taken down by the Owner and made available to the Contractor for evaluation.

9. ACCEPTANCE

9.1 Acceptance will occur in any of the three following possible ways:

(a) Fulfillment of Guarantees

When Performance Test has been successfully completed and the Performance Guarantees are met.

(b) Deemed Acceptance

When Performance Test has not been completed or has not been carried out for reasons not attributable to the Contractor within specified date or other mutually agreed period.

10. The material to be utilized in execution of work shall confirm to the following Indian Standards (IS) which shall mean latest revisions, Amendments / changes and published unless otherwise specified herein before.

Sr. No.	Indian Standards	Titles
1.	IS-226	Structural Steel Standard quality
2	IS-2062	Structural steel (fusion welding quality).
3.	IS-802	Code of practice for use of structural steel in over head transmission line towers and part-I loads & permissible stresses.(first revision)
4.	IS-808	Rolled steel beam, channel and angle sections and Part-I Dimensions for hot rolled steel beam Part-I MB series (second revision).
5.	IS-4759	Hot dip zinc coating on structural steel and other allied products.
6.	IS-6639	Hexagonal Bolts for steel Structure.
7.	IS-10238	Step Bolts for steel structures.
8.	IS-1367	Technical supply conditions for threaded fasteners.
9.	IS-2016	Plain washers.
10.	IS-4072	Steel for Spring washers
11.	IS-3063	Single coil rectangular section spring washers for bolts, nuts and screws.(first revision)
12.	IS-6821	Methods for sampling non threaded fasteners.
13.	IS-1573	Electroplated coatings of zinc on iron and steel.
14.	IS-2486	Insulator fittings for overhead power lines of 3.3 KV and above.
15.	IS-2633	Method of testing uniformity of coating on Zinc coated article.(first revision)

16.	IS-2121	Fittings for aluminium and steel cored aluminium conductor for overhead power lines (with amendments No 1 to 3)
17.	IS-731	Porcelain Insulators for overhead power lines with a nominal voltage greater than 1000V.(second revision)
18.	IS-2141	Galvanized Stay strand (first revision) (with amendments No 1 to 3)
19.	IS-398	Part-I Aluminium conductor for overhead Part-II Aluminium conductor, galvanized steel reinforced (second revision) Part-III Aluminium conductor, Aluminium steel reinforced (second revision)
20.	IS-4826	Galvanized coating on round steel wires.
21.	IS-2551	Danger notice plate (with amendments No 1)
22.	IS-2629	Recommended practice for hot dip galvanizing of Iron and steel.
23.	IS-5358	Hot dipped galvanised coating on fasteners.
24.	IS-5613	Code of practice for design, installation and maintenance of over-head power line. (Part-I Sec-I)- Lines upto and including 11 KV, section/design. (Part-I Sec-II)- Lines upto and including 11 KV, section installation and Maintenance.
25.	IS-6745	Method for determination of weight of zinc coating on zinc coated iron and Steel articles.
26.	IS-7215	Tolerance for fabrication of steel structures.
27.	IS-8577	Specification for weldable structures steel (medium and high tensile quality).
28.	IS-338	Varnish ,under coating, exterior, natural resin
29.	IS-800	Code of practice for use of structural steel in general building construction(Revised) with amendments No.1&2.
30.	IS-3034	Code of practice for fire safety of Industrial building. Electrical generating and Distributing stations.
31.	IS-269	Ordinary and low heat Portland cement.
32.	BS-16	Telegraph material (Insulator, pole fitting etc.)
33.	BS-729	Hot dipped Galvanisation
34.	IS-2427	Grading of continuous filament viscose rayon yarn and acetate yarn, bright And dull.
35.	IS-1363	Black Hexagonal bolts, nuts and lock nuts(dia meter 6 to 39mm) and black hexagon screws(dia 6 to 24 mm) first revision with Amendment No.1)
36.	IS-1852	Rolling & cutting tolerance for hot rolled steel products.
37.	IS-1778	Reels and drums for bare wire(with Amendment No. 1 & 2).

38.	IS-4218	ISO metric Screw Threads.(Part.I- Basic and design profiles, Part-II- Pitch diameter combinations, Part.III- Basic dia mensions for design profiles, Part.IV- Tolerancing system, Part. V- Tolerances, Part.VI- Limits of sizes for Commercial bolts and nuts (dia meter range 1 to 39 mm).
39.	IS-7887	Mild steel wire rod for general Engg. Purpose.
40.	IS-280	Mild steel wire for general engineering purpose (Second revision).
41.	IS-5300	Porcelain Guy Strain insulator
42.	IS-5561	Electric power connectors.
43.	IS-5	Colours for ready mixed paints (Second revision).
44.	IS-3972	Methods of Test for vitreous enamel wire.
45.	IS-4711	Methods for sampling of steel pipes, tubes and fittings.
46.	IS-1599	Method for bend test for steel products other than sheet, strip, wire and tube(first revision)
47.	IS-1678	Pre-stressed concrete poles for overhead power traction & Telecommunication lines.
48.	IS-8623	Methods for radio interference tests on high voltage insulators
49.	IS-13947	Specification for low voltage switchgear & controlgear.
50.	IS-14255	Aerial Bunched Cable for working voltages upto and including 400 V – specification.
51.	IS-8130	Conductor for insulated electric cables & flexible cords.
52.	IS-5561	Electric power connectors.
53.	IS-617	Aluminium and aluminium alloy ingots and casting for general engineering purpose (second revision).
54.	IS-2544	Porcelain post insulators for systems with nominal voltages greater than 1000 Volts (First revision) (with Amendment No.1).
55.	IS-7098	LT XLPE insulated (Heavy Duty) electric cables.

56.	IS-5831	PVC insulation and sheath of electric cables (with Amendments No. 1 to 3).
57.	IS-1239	Mild steel tubes, tubulars and other wrought steel fittings.
58.	IS-5039	Distribution pillar for voltages not exceeding 1000 volts.

For 12Kv RMUs:

IEC 62271-200/IS 12729:1988	General requirement for Metal Enclosed Switchgear
IEC62271-102/IS 9921	Alternating Current disconnector's (Load Break Isolators) and Earthing Switch.
IEC 62271-100 / IEC 62271-200	Specification for alternating current circuit breakers
IEC 62 271-1	Panel design, SF6/Vacuum Circuit Breakers
IEC60044-1/IS2705:1992	Current Transformer
IEC 60265/IS 9920:1981	High voltage switches
IEC 376	Filling of SF6 gas in RMU
IEC 60273/IS :2099	Dimension of Indoor & Outdoor post insulators with voltage > 1000 Volts
IEC 60529/IS 13947(Part-1)	Degree of protection provided by enclosures for low voltage switchgear and control gear.
IS 3043-1987	Code of Practice for earthing
Indian Electricity Rules/Bills	

For 33Kv VCBs

IEC56/IS:13118/IS-3427/IS:10118 (Part-III) – 1982/ IS:2165-1977/ IS:3716-1976/ IEC-62271-100/ IEC-62271-200	Circuit Breaker/ metal enclosed Switchgear and control gear.
IS: 3156	Voltage transformers.
IS: 2705	Current transformers.
IS: 3231	Electrical Relays for power system.
IS:1248	Meters and Instruments

IS:14697-1999	Specification for AC static transformer operated watt hour
	and VAR hour meters class 0.2 S & 0.5 S.
IEC-62053-22-2003	Specification for AC Static Watt hour Meters, class 0.2 S &
IEC-62052-11-2003	
CBIP Technical Report No.304	Specification for AC Static Electrical Energy Meter.

Signature of Contractor/Bidder

Executive Engineer (Elect-III)
JDA, Jaipur

Annexure A : Compliance with the code of Integrity and No Conflict of Interest

Any person participating in a procurement process shall –

- (a) Not offer any bribe, reward or gift or any material benefit either directly or indirectly in exchange for an unfair advantage in procurement process or to otherwise influence the procurement process;
- (b) Not misrepresent or omit the misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- (c) Not indulge in any collusion, Bid rigging or anti-competitive behaviour to impair the transparency, fairness and progress of the procurement process;
- (d) Not misuse any information shared between the procuring Entity and the Bidders with an intent to gain unfair advantage in the procurement process;
- (e) Not indulge in any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- (f) Not obstruct any investigation or audit of a procurement process;
- (g) Disclose conflict of interest, if any; and
- (h) Disclose any previous transgressions with any Entity in India or any other country during the last three years or any debarment by any other procuring entity.

Conflict of Interest :-

The Bidder participating in a bidding process must not have a Conflict of interest. A conflict of interest is considered to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations.

- i. A Bidder may be considered to be in Conflict of Interest with one or more parties in a bidding process if, including but not limited to:
 - a. Have controlling partners/shareholders in common ; or
 - b. Receive or have received any direct or indirect subsidy from any of them; or
 - c. Have the same legal representative for purposes of the Bid; or
 - d. Have a relationship with each other; directly or through common third parties, that puts them in a position to have access to information about or influence on the Bid of another Bidder, or influence the decisions of the Procuring Entity regarding the bidding process; or
 - e. The Bidder participates in more than one Bid in a bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all Bids in which the Bidder is involved. However, this does not limit the inclusion of the same subcontractor, not otherwise participating as a Bidder, in more than one Bid; or
 - f. The Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the Goods, Works or Services that are the subject of the Bid; or
 - g. Bidder or any of its affiliates has been hired (or is proposed to be hired) by the Procuring Entity as engineer-in-charge/ consultant for the contract.

Annexure B : Declaration by the Bidder regarding Qualifications

In relation to my/our Bid submitted to for procurement of..... in response to their Notice inviting Bids No.Dated I/We hereby declare under Section 7 of Rajasthan Transparency in Public Procurement Act, 2012, that :

1. I/We possess the necessary professional, technical, financial and managerial resources and competence required by the Bidding Document issued by the Procuring Entity;
2. I/We have fulfilled my/our obligation to pay such of the taxes payable to the Union and the State Government or any local authority as specified in the Bidding Document;
3. I/We are not insolvent, in receivership, bankrupt or being wound up, not have my/our affairs administered by a court or a judicial officer, not have my/our business activities suspended and not the subject of legal proceeding for any of the foregoing reasons;
4. I/We do not have, and our directors and officers not have, been convicted of any criminal offence related to my/our professional conduct or the making of false statements or misrepresentations as to my/our qualifications to enter into a procurement Contract within a period of three years preceding the commencement of this procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
5. I/We do not have a conflict of interest as specified in the Act, Rules and the Bidding Document, which materially affects fair competition;

Date :

Signature of bidder

Place :

Name :

Designation :

Address :

Annexure C : Grievance Redressal during Procurement Process

The designation and address of the First Appellate Authority is **Executive Committee, JDA, Jaipur**

The designation and address of the Second Appellate Authority **ACS/PS, UDH, GOR, Jaipur.**

- **Filing an appeal**

If any Bidder or prospective bidder is aggrieved that any decision, action or omission of the Procuring Entity is in contravention to the provisions of the Act or the Rules or the Guidelines issued thereunder, he may file an appeal to First Appellate Authority, as specified in the Bidding Document within a period of ten days from the date of such decision or action, omission, as the case may be, clearly giving the specific ground or grounds on which he feels aggrieved: Provided that after the declaration of a Bidder as successful the appeal may be filed only by a Bidder who has participated in procurement proceedings: Provided further that in case a Procuring Entity evaluates the Technical Bids before the opening of the Financial Bids, an appeal related to the matter of Financial Bids may be filed only by a Bidder whose Technical Bid is found to be acceptable.

(2) The officer to whom an appeal is filed under para (1) shall deal with the appeal as expeditiously as possible and shall endeavour to dispose it of within thirty days from the date of the appeal.

(3) If the officer designated under para (1) fails to dispose of the appeal filed within the period specified in para (2), or if the Bidder or prospective bidder or the Procuring Entity is aggrieved by the order passed by the First Appellate Authority, the Bidder or prospective bidder or the Procuring Entity, as the case may be, may file a second appeal to Second Appellate Authority specified in the Bidding Document in this behalf within fifteen days from the expiry of the period specified in para (2) or of the date of receipt of the order passed by the First Appellate Authority, as the case may be.

(4) Appeal not to lie in certain cases

No appeal shall lie against any decision of the Procuring Entity relating to the following matters, namely :-

- (a) Determination of need of procurement;
- (b) Provisions limiting participation of Bidders in the Bid process;
- (c) The decision of whether or not to enter into negotiations;
- (d) Cancellation of a procurement process;
- (e) Applicability of the provisions of confidentiality.

(5) Form of Appeal

(a) An appeal under para (1) or (3) above shall be in the annexed form along with as many copies as there are respondents in the appeal.

(b) Every appeal shall be accompanied by an order appealed against, if any, affidavit verifying the facts stated in the appeal and proof of payment of fee.

(c) Every appeal may be presented to First Appellate Authority or Second Appellate Authority, as the case may be, in person or through registered post or authorized representative.

(6) Fee for filing appeal

(a) Fee for first appeal shall be rupees two thousand five hundred and for second appeal shall be rupees ten thousand, which shall be non-refundable.

(b) The fee shall be paid in the form of bank demand draft or banker's cheque of a Scheduled Bank in India payable in the name of Appellate Authority concerned.

(7) Procedure for disposal of appeal

(a) The First Appellate Authority or Second Appellate Authority, as the case may be, upon filing of appeal, shall issue notice accompanied by copy of appeal, affidavit and documents, if any, to the respondents and fix date of hearing.

(b) On the date fixed for hearing, the First Appellate Authority or Second Appellate Authority, as the case may be, shall,-

(i) Hear all the parties to appeal present before him; and

(ii) Peruse or inspect documents, relevant records or copies thereof relating to the matter.

(c) After hearing the parties, perusal or inspection of documents and relevant records or copies thereof relating to the matter, the Appellate Authority concerned shall pass an order in writing and provide the copy of order to the parties to appeal free of cost.

(d) The order passed under sub-clause (c) above shall also be placed on the State Public Procurement Portal.

FORM No. 1

[See Rule 83]

**Memorandum of Appeal under the Rajasthan
Transparency in Public Procurement Act, 2012**

Appeal No. of

Before the (First/Second Appellate Authority)

1. Particulars of appellant :

(i) Name of the appellant :

(ii) Official address, if any :

(iii) Residential address :

2. Name and address of the respondent (s) :

(i)

(ii)

(iii)

3. Number and date of the order appealed against and name and designation of the officer/authority who passed the order (enclose copy), or a statement of a decision, action or omission of the Procuring Entity in contravention to the provisions of the Act by which the appellant is aggrieved:

4. If the Appellant proposes to be represented by a representative, the name and postal address of the representative:

5. Number of affidavits and documents enclosed with the appeal:

6. Grounds of appeal:

(Supported by an affidavit)

7. Prayer:

Place

Date

Appellant's Signature

Annexure D: Additional Conditions of Contract

- **Correction of arithmetical errors**

Provided that a Financial Bid is substantially responsive, the Procuring Entity will correct arithmetical errors during evaluation of Financial Bids on the following basis:

- i. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected, unless in the opinion of the Procuring Entity there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price shall be corrected;
- ii. If there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected; and iii. If there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (i) and (ii) above.

If the Bidder that submitted the lowest evaluated Bid does not accept the correction of errors, its Bid shall be disqualified and its Bid Security shall be forfeited or its Bid Securing Declaration shall be executed.

2. Procuring Entity's Right to Vary Quantities

- (i) If the Procuring Entity does not procure any subject matter of procurement or procures less than the quantity specified in the Bidding Document due to change in circumstances, the Bidder shall not be entitled for any claim or compensation except otherwise provided in the Conditions of Contract.
- (ii) On repeat order for extra items for additional qtys may be placed if it is provided in the bidding documents on the rates and conditions given in the contract, if the original order was given after inviting open competitive bids. Delivery or completion period may also be proportionately increase. The limits of repeat order shall be as under.
 - (a) 50% of the qty of the individual items and 50% of the value of original contract in case of works and
 - (b) 50% of the value of goods or services of the original contract.

3. Dividing quantities among more than one Bidder at the time of award (In case of procurement of Goods)

As a general rule all the quantities of the subject matter of procurement shall be procured from the Bidder, whose Bid is accepted. However, when it is considered that the quantity of the subject matter of procurement to be procured is very large and it may not be in the capacity of the Bidder, whose Bid is accepted, to deliver the entire quantity or when it is considered that the subject matter of procurement to be procured is of critical and vital nature, in such cases, the quantity may be divided between the Bidder, whose Bid is accepted and the second lowest Bidder or even more Bidders in that order, in a fair, transparent and equitable manner at the rates of the Bidder, whose Bid is accepted.

**SPECIAL CONDITIONS OF CONTRACT REGARDING
DEFECT LIABILITY PERIOD (DLP) FOR ROADS/ ELECTRICALS WORKS**

As per the decision taken in the 201st meeting of Executive Committee held on 23.02.2016 w.r.t. agenda no. 201:22, DLP period of various natures of works amounting more than Rs. 25 lakhs has been revised as per following time periods based on nature of works.

This order will supersede the earlier orders issued in this regard i.e. order No. JDA/TA to D(E)/2010-11/D-317 dated 28.04.2011 including Special Condition No. 2.2.2 & 2.2.3 of Annexure-I related to SD refund & forfeiture (other Special Condition of annexure-I of this order will remain valid) and order No. JDA/Ex.En.(Pr.-5 & TA)/2013/D-43 dated 27.02.2013 and also all pertaining orders, in contract agreements or in PWF&AR having DLP period different than what is being enforced through this present order for concerned type of work.

Table-I

S.No.	Type of work	Existing DLP Period	As per approved in E.C. held on 23.02.2016
1.	Bridge Work	3 years	5 Years
2.	CD Work	3 years	5 Years
3.	CC Road. PQC Work	3 years	5 Years
4.	CC tiles/Kerbs/medians	3 years	5 Years
5.	Drains	6 Months	3 Years
6.	Roads		
	(i)Two layer WBM/GSB	3 years	6 months or one full rainy season which ever is later
	(ii)For Renewal/Strengthening		
	(a)BT upto 30 mm thickness	3 years	1 Years
	(b)BT above 30 mm to upto 40 mm	3 years	2 Years
	(c)BT above 40 mm to upto 90 mm	3 years	3 Years
	(d)BT above 90 mm thickness	3 years	5 Years
	(iii) New Roads		
	(a) BT upto 90 mm	3 years	3 Years
	(b) BT more than 90 mm	3 years	5 Years
7.	Compound wall	6 Months	3 Years
8.	Building Work		

	(i) Work pertaining to Sanitary work electrical works, Joinery works and painting works.	6 Months	2 Years
	(ii) Work pertaining to Building structure and other civil works	6 Months	5 Years
9.	Electric work except maintenance	6 Months	3 years
10.	Sewer/Water supply all including STP and water supply related work except maintenance works.	6 Months	3 Years

The release of SD amount shall be as per following table:-

Table-II

S.No.	DLP Period \ Released SD	1 Year	2 Years	3 Years	5 Years
1.	Upto 1 year	100%	40%	20%	10%
2.	Upto 2 year		60%	20%	10%
3.	Upto 3 year			60%	10%
4.	Upto 4 year				20%
5.	Upto 5 year				50%

Various condition for managing DLP are as under :-

- (i) At the time of completion of work, final componnt shall be worked out for each individual item like BT/CC/tiles/ drains etc (as per different categories in Table-I), DLP shall be operative based upon type of individual item ex:- CC-5 years, BT1/2/3/5 years, Drain-3 years etc.
- (ii) Similarly for all new works, these components should be calculated at the time of TS itself, which should be made part of BID document.
- (iii) If any work, amount is less than Rs. 25 lacs but later on due to extra/excess work, if amount of final work cresses more than Rs. 25 lacs, DLP shall be operative as per rule for each individual items.
- (iv) Similarly if any work is more than Rs. 25 lacs but after finalization amount or work is less than Rs. 25 lacs, DLP should be operative for six months or rainy season whichever is late.
- (v) During DLP period if contractor fails to repair any work even after issue of 7 days written notice, same work shall be got executed by respective Executive Engineer at the contractor's risk and cost. This process shall be applicable throughout the DLP period. After completion of DLP period in such works contractor should be debarred and blacklisted. From JDA for three years as per RTPP rule 2012 and 2013 where he defaults twice in a single agreement or in two different works.
- (vi) Quarterly Inspection as per rules shall be carried out and DLP registers shall be maintained by respective Executive Engineers to monitor the DLP repairs.
- (vii) Special and regular inspection shall also be carried out as per order no. JDA/Ex.En. & TA to DE-I/2014-15/D-223 dated 12.03.2015 and order no. SE (PMGSY) CIRULAR 2006/D-115 dated 04.05.2006 Point no. 3.
- (viii) In case JDA feels to take up work on any existing DLP road due to any reason, following procedure should be adopted:
 - (a) At the time of withdrawal total liability of repairs as per DLP conditions to be carried out and contractor shall be asked to complete the same. After completion of assessed repairs DLP period shall be released after deduction amt. as per table III

Table-III

% Recovery on withdrawal of DLP of work order DLP period	1 Year	2 Year	3 Year	4 Year	5 Year
1 Year	1.12	-	-	-	-
2 Year	2.55	1.43	-	-	-
3 Year	4.38	3.26	1.83	-	-
5 Year	9	7.88	6.45	4.62	2.47

Note: - Calculation is to be done on quarterly basis.

- (b) In case Contractor fails to carry out these repairs, same shall be carried out at his risk and cost. If the total amt. of such repairs works out to be more than total retained amt. of SD same shall be recovered from other works and as per PDR rules. The amount as per Table III is also to be deducted in addition to this amount.
- (ix) Based upon type of work, DLP conditions for works to be carried out during DLP period with their frequency of respective type of work shall be prepared by respective SE"s after approval of these periods.

This order shall come in force with immediate effect and will be applicable on all new works whose NIB is to be called.

Signature of contractor with
Full address.

Executive Engineer (Elect-III)
JDA, Jaipur.

Percentage BoQ

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	P/Laying P.V.C. / XLPE insulated & P.V.C. sheathed cable of 1.1 KV grade with aluminium conductor of IS:1554 P-I / IS :7098 P - I of Group 1 of approved make in ground as per IS:1255 including excavation of 30cmx75cm size trench, 25 cm thick under layer of sand,IInd class bricks covering, refilling earth,compaction of earth, making necessary connection, testing etc. as required of size. Complete Rate Group-1					
	3.5 Core x 185.0 Sqmm	800.000	Mtr.	733.60	586880.00	INR Five Lakh Eighty Six Thousand Eight Hundred & Eighty Only
	3.5 Core x 300.0 Sqmm	260.000	Mtr.	1093.60	284336.00	INR Two Lakh Eighty Four Thousand Three Hundred & Thirty Six Only
	P & Laying XLPE insulated IS:7098/II/85 of Group1 and approved make H.T.cable for working voltage 11 K.V.Earthed direct in ground including excavation of 30cmx100cm size trench, 25cm layer of river sand, IInd class bricks covering, refilling earth, compaction of earth, making necessary connection testing etc.as required of size.Complete Rate Group-1					
	3.0 Core x 185.0 Sqmm	3955.000	Mtr.	1012.80	4005624.00	INR Forty Lakh Five Thousand Six Hundred & Twenty Four Only
	Providing & making heat shrinkable type indoor/outdoor/straight through terminations/joint kit of Group1 and approved make suitable for XLPE insulated 11 KV / 33 KV cable, with required components, prepration of cable ends,testing etc. as required of following sizes. Complete Rate Group-1					
	11 KV End Termination Kit Outdoor type					
	3.0 Core x 120/150/185/225 Sq.mm	39.000	Per Set	4000.00	156000.00	INR One Lakh Fifty Six Thousand Only
	11 KV End Termination Kit Outdoor type					
	3.0 Core x 120/150/185/225 Sq.mm	42.000	Per Set	5200.00	218400.00	INR Two Lakh Eighteen Thousand Four Hundred Only
	11 KV Straight Through Joint Kit					
	3.0 Core 120/150/185/225 Sq.mm	23.000	Per Set	12000.00	276000.00	INR Two Lakh Seventy Six Thousand Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	SITC of 11 KV, 400/630 A, 20kA / 3 sec, Out door, Extensible type Ring main unit (RMU) in suitable RCC foundation with 2 no. Load break switch & 1 no. VCB / SF6 circuit breaker with over load, Earth fault, short circuit relay, copper bus bar, earthing switch, mechanical ON / OFF / Earth indication, Voltage presence indicator, Ring core protection CT 2.5 VA, 10P10 as per transformer rating, Shunt trip coil, Anti reflex operating handle, right angle boots etc. as required. Complete Rate Group-1	13.000	Per Set	331648.00	4311424.00	INR Forty Three Lakh Eleven Thousand Four Hundred & Twenty Four Only
	Supply & fabrication steel structure with MS channel / angle /joist / ISMB / sheet etc. including welding, rivetting, cutting, nut & bolt , Painting etc. as required. Complete Rate Group-1	11000.000	KG	67.20	739200.00	INR Seven Lakh Thirty Nine Thousand Two Hundred Only
	Supply and installation of spike of M.S. rod 20mm dia 3.0mtr. long for earthing of (tower/pole) drive into earth by mechanical means sturcture connection the spike with cross arm top hamper PCC pole, lattics tower to earth etc. complete as per technical specification of DISCOM. Complete Rate Group-1	129.000	Per Set	520.00	67080.00	INR Sixty Seven Thousand &Eighty Only
	S & Laying following size earth wire/strip in horizontal or vertical run in ground/surface/recess including riveting, soldering, saddles, making connection etc. as required.. Complete Rate Group-1					
	8 SWG G.I. (Hot Dipped) Wire	645.000	Mtr.	7.20	4644.00	INR Four Thousand Six Hundred & Forty Four Only
	S & Laying following size' B ' class G.I. Pipe confirming to IS : 1239 P - 1 (1990) with accessories for laying earth conductor/strip / cable in ground/surface/recess as required. Complete Rate Group-1					
	125 mm dia.	60.000	Mtr.	740.00	44400.00	INR Forty Four Thousand Four Hundred Only
	SITC of Cutting back up surface up to 2 Mtr. Depth by digging by Bogi including all layers of crust for laying pipe line etc. and making good to original condition (excluding cost of bitumen). Complete Rate Group-1	1800.000	Per Set	288.00	518400.00	INR Five Lakh Eighteen Thousand Four Hundred Only
	Supplying and making one end termination with heavy duty single compression brass gland SIBG type, heavy duty aluminium lugs duly crimped with crimping tool, PVC tape etc for following size of Armoured PVC insulated & PVC sheathed/ XLPE aluminium conductor cable of 1100 volt grade as required of size. Complete Rate Group-1					
	3.5 X 300.0 Sqmm	20.000	Per Set	490.40	9808.00	INR Nine Thousand Eight Hundred & Eight Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Supply and fixing of piller box made of 2 mm thick powder coated CRCA sheet of 415 volts 3 phase 4 wire triple pole and neutral type, complete in all respect as required. Including knife switch of 400 amp. rating , HRC fuses with copper one piece U contacts base, brass studs and nuts, copper busbar for main and interconnection, MS angle frame of 50 x 50 x 6 mm. grouted with C.C. of M-10 grade to achieve the height of 1.5 feet above the road level suitable for four outgoing. Complete Rate Group-1					
	11 KV cross arms (75 x 40 x 6.8 kg/mtr)	13.000	Each	34000.00	442000.00	INR Four Lakh Forty Two Thousand Only
	S I T C of BEE 3 star rated Aluminium wound Transformer conforming to IS: 2026 & Losses as per Discom's CTL (CTL Test certificate to be attached) of rating 11/0.433KV Delta-Star Connected, Vector Group Dyn 11, standard accessories like conservator, silica gel breather, radiator, fins, HT bushing & LT cableboxes, Off -LTC (+/- 5% in steps of 2.5%) winding temperature rise of 50/55 C, ISI marked drain valve, Dial type Temperature gauge, first fill of oil, Epoxy based paint, including carrying of pre-commission Testing & Charging of Transformer. (See table - 08 for CTL Losses). Complete Rate Group-1					
	100 KVA	3.000	Each	149600.00	448800.00	INR Four Lakh Forty Eight Thousand Eight Hundred Only
	160 KVA	6.000	Each	189904.00	1139424.00	INR Eleven Lakh Thirty Nine Thousand Four Hundred & Twenty Four Only
	S I T C of Copper wound Transformer conforming to IS: 2026 & Losses as per Discom's CTL (CTL Test certificate to be attached) of rating 11/0.433KV Delta-Star Connected, Vector Group Dyn 11, standard accessories like conservator, silica gel breather, radiator, fins, HT bushing & LT cableboxes, Off -LTC (+/- 5% in steps of 2.5%) winding temperature rise of 50/55 C, ISI marked drain valve, Dial type Temperature gauge, first fill of oil, Epoxy based paint, including carrying of pre-commission Testing & Charging of Transformer. (See table - 08 for CTL Losses). Complete Rate Group-1					
	315 KVA	4.000	Each	402930.00	1611720.00	INR Sixteen Lakh Eleven Thousand Seven Hundred & Twenty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Providing, fixing, testing and commissioning of LT Distribution box with HR fuse/MCCB type weather proof box of size 650x500x250mm, made out of smoke grey colour sheet moduling compound (S.M.C. Electrical grade 3) confirming IS 13410 amended upto date, front and back both side openable completely hinged door with doors shall be centrally closed triple position locking arrangement and shall be operational with common handle from outside the door and base of box to avoid penetration of dust and ingress of water. Rubber gasket shall be fitted with suitable adhesive. The enclosure shall be anti corrosive, dust & rust proof. Vermin & water proof, ultra-violet stabilized cable termination arrangement & necessary fixing arrangement shall be provided with fuse link in spare should be invariably provided with each box comparing of as per following with embossed JVVNL/JDA with month & year of manufacturing. a. Switch disconnecter 250 AMP TP b. HRC Fuse base made of DMC 250 Amp c. HRC Fuse link 250 Amp d. Copper wire PVC insulated 50 Sq.mm 4 Core e. Aluminium bus bar insulated with DMC/SMC f. Top and Base made of SMC g. MS Angle Frame for Box 50x50x6mm h. Copper Lugs 50 Sq.mm i. M10 grade Nominal Mix 1:3:6 (1 cement : 3 coarse sand : 6 graded stone aggregate 20mm nominal size).	5.000	Each	17820.00	89100.00	INR Eighty Nine Thousand One Hundred Only
	P & Laying XLPE insulated IS:7098/II/85 of Group1 and approved make H.T.cable for working voltage 33 K.V.Earthed direct in ground including excavation of 30cmx120cm size trench, 25cm layer of river sand, IInd class bricks covering, refilling earth, compaction of earth, making necessary connection testing etc.as required of size. Complete Rate Group-1					
	3.0 X 300.0 Sqmm	24000.000	Mtr.	1988.80	47731200.00	INR Four Crore Seventy Seven Lakh Thirty One Thousand Two Hundred Only
	Providing & making heat shrinkable type indoor/outdoor/straight through terminations/joint kit of Group1 and approved make suitable for XLPE insulated 11 KV / 33 KV cable, with required components, prepration of cable ends,testing etc. as required of following sizes . Complete Rate Group-1					
	33 KV End Termination Kit Outdoor type					
	3 core 240/400 Sq.mm	52.000	Per Set	8085.12	420426.24	INR Four Lakh Twenty Thousand Four Hundred & Twenty Six and Paise Twenty Four Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	33 KV Straight Through Joint Kit					
	3 core 240/400 Sq.mm	96.000	Per Set	24229.44	2326026.24	INR Twenty Three Lakh Twenty Six Thousand & Twenty Six and Paise Twenty Four Only
	Supply & fabrication steel structure with MS channel / angle /joist / ISMB / sheet etc. including welding, rivetting, cutting, nut & bolt , Painting etc. as required	1850.000	KG	67.20	124320.00	INR One Lakh Twenty Four Thousand Three Hundred & Twenty Only
	Supply & Erection of lattice structure of height 11 mtr in alignment, including excavation of pit and Providing and laying of cement concrete in ratio 1:3:6 using 43 grade cement, river sand and 12 mm to 20 graded blast crusher broken in pit/ found cement plaster upto 0.50mtr. from top to bottom in 1:3:6 ratio and paint of tower of approved make two coat of red oxide paint and one coat of aluminium paint before installation and one coat of paint after irrection work completed as per technical specifications & drawing of DISCOM. Complete Rate Group-1	24.000	Each	24400.00	585600.00	INR Five Lakh Eighty Five Thousand Six Hundred Only
	Supply and fixing of 11kV, 400 Amp 3pole, central pot rotating double break type isolator (IS:9921 part I toV) without earth blade operating mechanism with GI spring loaded reverse loop type fixed contact, solid hard drawn electrolytic copper tubular moving contact with silver/ nickel plated at end points, 9 nos post insulator of 12 kV (IS:2554 & IS 5350 part III), hot dipped galvanising hard ware, nut, bolts etc complete in all respect as per specification of Discom.(Type tested by ERDA/CPRI.). Complete Rate Group-1	24.000	Each	10520.00	252480.00	INR Two Lakh Fifty Two Thousand Four Hundred & Eighty Only
	Providing and fixing of single pole mounted structure set for isolator as per Discom specification complete in all respect with nuts and bolts as required MS flat 50 x 6mm, MS angle 65 x 65 x6mm, MS channel 100 x 50 x 6mm. (Excluding cost of pole). Complete Rate Group-1	24.000	Each	1908.00	45792.00	INR Forty Five Thousand Seven Hundred & Ninety Two Only
	Supply and installation of spike of M.S. rod 20mm dia 3.0mtr. long for earthing of (tower/pole) drive into earth by mechanical means sturcture connection the spike with cross arm top hamper PCC pole, lattices tower to earth etc. complete as per technical specification of DISCOM. Complete Rate Group-1	24.000	Per Set	520.00	12480.00	INR Twelve Thousand Four Hundred & Eighty Only
	S & Laying following size earth wire/strip in horizontal or vertical run in ground/surface/recess including riveting, soldering, saddles, making connection etc. as required). Complete Rate Group-1					

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	8 SWG G.I. (Hot Dipped) Wire	120.000	Mtr.	7.20	864.00	INR Eight Hundred & Sixty Four Only
	S & Laying following size' B ' class G.I. Pipe confirming to IS : 1239 P - 1 (1990) with accessories for laying earth conductor/strip / cable in ground/surface/recess as required). Complete Rate Group-1					
	125 mm dia	240.000	Mtr.	740.00	177600.00	INR One Lakh Seventy Seven Thousand Six Hundred Only
	SITC of Cutting back up surface up to 2 Mtr. Depth by digging by Bogi including all layers of crust for laying pipe line etc. and making good to original condition (excluding cost of bitumen). Complete Rate Group-1	15500.000	Mtr.	288.00	4464000.00	INR Forty Four Lakh Sixty Four Thousand Only
	Supply & Fixing of HD Galvanised M.S. Rod type earthing set made up of M.S. Rod 20 mm dia. 3 meter long alongwith earthing clamp driven by mechanical means into earth hole (made by augering) and connecting the M.S. Rod with required equipment/material complete in all respect as per latest specifications of Discoms.	94.000	Each	510.00	47940.00	INR Forty Seven Thousand Nine Hundred & Forty Only
	Supply and erection of 7.5 Mtr. "AB-1" type sub-station structure fabricated from M.S. Angle 65 × 65 × 6 mm with bracing of M.S. Flat 50 × 6 mm including excavation of pits of size 1 × 1 × 1.25 meter (as per specification & drawing approved by Nigam) Steel Wt. 350 Kg. Each structure.	10.000	Each	19000.00	190000.00	INR One Lakh Ninety Thousand Only
	Supply and erection of 6.0 Mtr. "AB-1" type sub-station structure fabricated from M.S. Angle 65 × 65 × 6 mm with bracing of M.S. Flat 50 × 6 mm including excavation of pits of size 0.9 × 0.9 × 1 meter (as per specification & drawing approved by Nigam) Steel Wt. 280 Kg. Each structure.	2.000	Each	16000.00	32000.00	INR Thirty Two Thousand Only
	Supply and erection of 4.3 meter long "C" type beam fabricated from ISA M.S. Angle 65 × 65 × 6 mm with bracing of M.S. Flat 50 × 6 mm on "AB" and AB structure with Nut & Bolt 5" dia (as per specification & drawing approved by Nigam) Steel Wt. 195 Kg. Each structure.	22.000	Each	13000.00	286000.00	INR Two Lakh Eighty Six Thousand Only
	Supply and fixing of lightening arrestors on the existing brackets in all respect as required including hardware, nut, bolt & washer etc. for O&M works complete in all respect as per latest specifications of Discoms					
	33 KV Sub-station type (30KV 10 KA Sub-station Class)	4.000	Per Set	17995.00	71980.00	INR Seventy One Thousand Nine Hundred & Eighty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Constn. of 33/11 KV Transformers plate form 2.4 × 2.4 × 2.0 Mtrs. including excavation in all type of soil up to the depth of 900 mm, foundation concrete in C.C. - 1 : 5 : 10 for 150 mm thickness brick masonry in cement mortar of mix. 1:8 with top of the plate form finished with 100 mm layer of C.C. 1:2:4 alongwith 2 Nos. M.S. Rails 90 Pounds of 2.4 Mtr. length each, alongwith cement plaster - 20 mm thick of mix ration 1 : 6, on all the exposed surfaces of the plate form - complete in all respect.	2.000	Each	20000.00	40000.00	INR Forty Thousand Only
	Constn. of 33 KV Kiosk/VCB Plate form 3.0 × 1.3 × 1.3 Mtrs Including excavation in all type of soil up to the depth of 900 mm, foundation concrete in C.C. - 1 : 5 : 10 for 150 mm thickness, stone masonry in cement mortar of mix. 1:8 with top of the plate form finished with 100 mm layer of C.C. 1:2:4 including fixing of foundation bolts and cement plaster - 20 mm thick of mix ration 1 : 6, on all the exposed surfaces of the plate form - complete in all respect.	4.000	Each	7000.00	28000.00	INR Twenty Eight Thousand Only
	Supply and fixing of 11 KV porcelain Disc insulators (B&S) type on existing brackets complete including all accessories like hardwares, fitting nut, bolt & washer etc. complete in all respect as per latest specifications of Discoms.					
	One H/w with 3 Disc insulator (120KN) for Panther	42.000	Per Set	3700.00	155400.00	INR One Lakh Fifty Five Thousand Four Hundred Only
	Supply and laying/stringing of Bus bar with ACSR and jumber connection using tie rod, 11 KV insulator string, required hardware, PG clamps/T-clamps etc., as per requirement including Y-connection at bus bar jumpering point complete in all respect as per latest specifications of Discoms					
	PG Clamp for ACSR Panther to Panther	60.000	Nos	317.00	19020.00	INR Nineteen Thousand &Twenty Only
	T/Clamp for Panther to Panther	60.000	Nos	230.00	13800.00	INR Thirteen Thousand Eight Hundred Only
	ACSR panther conductor	350.000	Mtr.	228.00	79800.00	INR Seventy Nine Thousand Eight Hundred Only
	SITC of VCB out door type complete with accessories including use of special tools & conducting all pre commissioning tests before energisation, l etc. complete in all respect with erection & grouting of structure (excluding civil works). complete in all respect as per latest specifications of Discoms. The relays will be tested by Discom.					
	36 KV VCB, 1250 Amp.	4.000	Per Set	351815.00	1407260.00	INR Fourteen Lakh Seven Thousand Two Hundred & Sixty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	SITC of 12KV VCB indoor type with one incomer of 630Amp. and two outgoing of 630 Amp. each complete with accessories including use of special tools & conducting all pre commissioning tests before energisation, etc. complete in all respect with erection & grouting of structure (excluding civil works). complete in all respect as per latest specifications of Discoms. (including CTs,PT with metering equipment)					
	12 KV VCB, 630 Amp. (Indoor Type)	2.000	Per Set	1130000.00	2260000.00	INR Twenty Two Lakh Sixty Thousand Only
	SITC of 33 KV oil filled current / potential transformers on supporting structure including wiring and conducting all pre commissioning tests before energisation, including making necessary terminal connections complete in all respect as per latest specifications of Discoms. (The CT/PT set will be tested by Discom). The work include installation of structure and foundation as per latest Discom specifications					
	33KV CT (1 Set of 3 Nos.) 240-120-60/5A-5A	2.000	Per Set	160000.00	320000.00	INR Three Lakh Twenty Thousand Only
	33KV CT (1 Set of 3 Nos.) 400-200-100/5A-5A	2.000	Per Set	180000.00	360000.00	INR Three Lakh Sixty Thousand Only
	33KV PT, 33 KV/110 V	1.000	Per Set	90834.00	90834.00	INR Ninety Thousand Eight Hundred & Thirty Four Only
	SITC of 12KV VCB indoor type with one out going only of 630Amp complete with accessories including use of special tools & conducting all pre commissioning tests before energisation, etc. complete in all respect with erection & grouting of structure (excluding civil works). complete in all respect as per latest specifications of Discoms. (including CTs,PT with metering equipment)					
	12 KV VCB, 630 Amp. (Indoor Type)	2.000	Per Set	376667.00	753334.00	INR Seven Lakh Fifty Three Thousand Three Hundred & Thirty Four Only
	SITC of control and relay panel including checking of wiring and conducting all pre commissioning tests before energisaion, satisfactory operation of all equipment existing thereof complete in all respect as per latest specifications of Discoms.					
	33 KV Control Panel Feeder Type	2.000	Per Set	182500.00	365000.00	INR Three Lakh Sixty Five Thousand Only
	33 KV Control Panel Transformer Type	2.000	Per Set	235565.00	471130.00	INR Four Lakh Seventy One Thousand One Hundred & Thirty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Supply and fixing of X-15 type structure for isolator made of M.S. Angle of size 75×75×6 mm for main and 65×65×6 mm M.S. Angle for bracing including execution of pit of required size complete in all respect as per latest pecification of JVVNL approximate weight 150 Kg.	8.000	Cum	12140.00	97120.00	INR Ninety Seven Thousand One Hundred & Twenty Only
	Providing & laying cement concrete for all type of foundation as per latest ISS 456 including cement, sand stone aggregate 20mm nominal size, water etc. preparing surface shuttering mixing, placing ramming, curing, finishing as per specification and drawing. Ratio of 1:3:6	100.000	Cum	1890.00	189000.00	INR One Lakh Eighty Nine Thousand Only
	Plate earthing with GI earth plate of size 600mm × 600mm ×6mm by embodying 8 meter below the ground level with 2 MS Channels of 50×50×6 mm duly welded with each other of length 8 m long with 10 m long perforated GI pipe of dia 40 mm including all accessories like nut, bolts, reducer, nipple etc. complete with alternate layers of slat and coke/charcoal, testing of earth resistance as required.	12.000	Per Set	3240.00	38880.00	INR Thirty Eight Thousand Eight Hundred & Eighty Only
	Providing and fixing of G.I. Pipe of 125 mm diameter. B-Class (IS:1239 mark), at the starting and finishing point of 11 KV underground cables and to lay & clamp vertically with the existing support including labour charges.	100.000	Mtr.	950.00	95000.00	INR Ninety Five Thousand Only
	P & F in position frame made out of M.S. angle (riveted or welded) finished with two coats of red oxide and enamel paint including cutting, welding, holes etc.of following sizes as required.					
	50mm x 50mm x 6mm	8.000	Mtr.	250.40	2003.20	INR Two Thousand &Three and Paise Twenty Only
	P & F paper phenolic resin bonded laminates confirming to IS : 2036 - 1995 for boxes/ frames including making holes for switches etc, with brass screws, washers/ zinc plated nut and bolts as required.					
	6.4 mm thick	2.000	Sqm	712.80	1425.60	INR One Thousand Four Hundred & Twenty Five and Paise Sixty Only
	Supplying and drawing FR PVC insulated & unsheathed flexible copper conductor ISI marked (IS:694) of 1.1 kV grade and approved make in existing surface or recessed conduit/casing capping including making connections etc. as required.					
	1 x 1.5 sq.mm	1000.000	Mtr.	11.20	11200.00	INR Eleven Thousand Two Hundred Only
	1 x 2.5 sq.mm	500.000	Mtr.	16.80	8400.00	INR Eight Thousand Four Hundred Only
	3 x 2.5 sq.mm	80.000	Mtr.	48.00	3840.00	INR Three Thousand Eight Hundred & Forty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	SITC of wall/ free standing floor mounted dust and vermin proof compartmentalised cubical panel made out of CRCA sheet , required hardware ,duly treated for derusting in 7 tank process with dephosphating and with powder coating on both side of panel in desired shade The panel having PU/ Neoprene rubber gasket of not less than 3mm thickness , separate detachable gland plate M.S. base channel ,hinged door with locking arrangement for quipment/switchgear . Thickness of sheet shall not be less than 1.6 mm up to 600 mm length / width of any compartment and be of 2.0 mm above 600 mm. Load bearing structure shall be of 2.0 mm thick sheet supported by base M.S. channel if required . Side walls and cable alley compartments having bolted type doors with / without detachable extension type structure. (only outer area on all sides shall be measured & panel to be fabricated from CPRI approved fabricator)	8.000	Sqm	2201.60	17612.80	INR Seventeen Thousand Six Hundred & Twelve and Paise Eighty Only
	Supplying and fixing of Aluminium / Copper bus bar by means of SMC / DMC type insulator, high tensile nuts and bolts spring washers in existing panel including bending , cutting in required shape and size and colour coding with heat shrinkable PVC sleeves.					
	Electrolytic grade Aluminium bus bar	4.000	KG	336.00	1344.00	INR One Thousand Three Hundred & Forty Four Only
	P & F of ac operated heavy duty 230 /440 Volt power contactor conforming to IS:13947-4-1/IEC:947-4-1 having provision of mechanical interlocking, auuxiliary contacts, Din rail mounting type including making connections, testing etc. as required.					
	4 pole Power contactors with following AC 1 Rating 64 AMP	1.000	Each	2828.80	2828.80	INR Two Thousand Eight Hundred & Twenty Eight and Paise Eighty Only
	SITC of quick make and quick break 3 pole current limiting MCCB having following current rating, short circuit breaking capacity at 440/415 V, 50 Hz; O/L & S/C settings and conforming to IS 60947-2 / IEC 60947-2 with front face and centralised adjustable, line load interchangeability, having positive isolation capability, provision for UVR , shunt trip , earth fault trip, push (test) to trip, including making connections with lugs & spreaders, etc. as required. With Thermal Magnetic release					
	up to 100 Amp , 16 kA, adjustable O/L & fixed S/C setting, Ics = 100 % Icu	2.000	Each	3400.00	6800.00	INR Six Thousand Eight Hundred Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	SITC of quick make and quick break 4 POLE current limiting MCCB having following current rating, short circuit breaking capacity at 440/415 V, 50 Hz; O/L & S/C settings and conforming to IS 60947-2 / IEC 60947-2 with front face and centralised adjustable, line load interchangeability, having positive isolation capability, provision for UVR , shunt trip ,earth fault trip, push (test) to trip , including making connections with lugs & spreaders, etc. as required. With Thermal Magnetic release					
	up to 100 Amp , 16 kA, adjustable O/L & fixed S/C setting, Ics = 100 % Icu	1.000	Each	4640.00	4640.00	INR Four Thousand Six Hundred & Forty Only
	P/Laying P.V.C. / XLPE insulated & P.V.C. sheathed cable of 1.1 KV grade with aluminium conductor of IS:1554 P-I / IS :7098 P - I of Group 1 of approved make in ground as per IS:1255 including excavation of 30cmx75cm size trench, 25 cm thick under layer of sand,IIInd class bricks covering, refilling earth,compaction of earth, making necessary connection, testing etc. as required of size.					
	2.0 x 10.0 Sqmm	440.000	Mtr.	109.60	48224.00	INR Forty Eight Thousand Two Hundred & Twenty Four Only
	3.5 x 25.0 Sqmm	150.000	Mtr.	166.40	24960.00	INR Twenty Four Thousand Nine Hundred & Sixty Only
	P&F of mechanical / digital time switch having following day / week programme and minimum 100 hours reserve and AC1 rating of 16-20 amperes including making connection, programming etc. as required					
	One day & week reserve (digital type)	1.000	Each	4596.80	4596.80	INR Four Thousand Five Hundred & Ninety Six and Paise Eighty Only
	Supplying and making one end termination with heavy duty single compression brass gland SIBG type, heavy duty aluminium lugs duly crimped with crimping tool, PVC tape etc for following size of Armoured PVC insulated & PVC sheathed/ XLPE aluminium conductor cable of 1100 volt grade as equired of size.					
	2.0 x 10.0 Sqmm	16.000	Per Set	44.00	704.00	INR Seven Hundred & Four Only
	3.5 x 25.0 Sqmm	2.000	Per Set	91.20	182.40	INR One Hundred & Eighty Two and Paise Forty Only
	3.5 x 35.0 Sqmm	2.000	Per Set	95.20	190.40	INR One Hundred & Ninety and Paise Forty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	3.5 x 185.0 Sqmm	30.000	Per Set	316.00	9480.00	INR Nine Thousand Four Hundred & Eighty Only
	Pipe Earthing as per IS:3043 with perforated 3.0 Mtr. Long, 40 mm dia. ' B ' class G.I. Pipe including all accessories like nut, bolts, reducer, nipple, wire meshed funnel, and C.C. finished chamber covered with hinged type with locking arrangement C.I. Cover, C.I. Frame of size 300mm x 300 mm and embodying the pipe complete with alternate layers salt and coke/ charcoal, testing of earth resistance as required.	6.000	Per Set	1320.00	7920.00	INR Seven Thousand Nine Hundred & Twenty Only
	S & Laying following size earth wire/strip in horizontal or vertical run in ground/surface/recess including riveting, soldering, saddles, making connection etc. as required.					
	8 SWG G.I. (Hot Dipped) Wire	150.000	Mtr.	7.20	1080.00	INR One Thousand &Eighty Only
	8 SWG copper Wire	160.000	Mtr.	63.20	10112.00	INR Ten Thousand One Hundred & Twelve Only
	25mm x 3mm copper strip	20.000	Mtr.	390.40	7808.00	INR Seven Thousand Eight Hundred & Eight Only
	50mm x 6mm copper strip	40.000	Mtr.	1452.00	58080.00	INR Fifty Eight Thousand &Eighty Only
	50mm x 6mm G.I. (Hot Dipped) Strip	900.000	Mtr.	170.40	153360.00	INR One Lakh Fifty Three Thousand Three Hundred & Sixty Only
	P&F 240/415 V AC MCB with positive isolation of breaking capacity not less than 10 KA (B/ C/ D tripping characteristic) ISI marked IS 8828(1996)]/ conforming to IEC 60898 in existing board/sheets including making connections, testing etc. as required.					
	Single pole MCB, 6 A to 32 A rating	16.000	Each	120.80	1932.80	INR One Thousand Nine Hundred & Thirty Two and Paise Eighty Only
	P/Laying P.V.C. / XLPE insulated & P.V.C. sheathed cable of 1.1 KV grade with Copper conductor of IS:1554 P-I / IS :7098 P - I of Group 1 of approved make in ground as per IS:1255 including excavation of 30cmx75cm size trench, 25 cm thick under layer of sand,IInd class bricks covering, refilling earth,compaction of earth, making necessary connection, testing etc. as required of size.					
	2.0 x 2.5 Sq.mm	400.000	Mtr.	97.60	39040.00	INR Thirty Nine Thousand &Forty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	4.0 X 2.5 Sqmm	400.000	Mtr.	162.40	64960.00	INR Sixty Four Thousand Nine Hundred & Sixty Only
	8.0 X 2.5 Sqmm	360.000	Mtr.	243.20	87552.00	INR Eighty Seven Thousand Five Hundred & Fifty Two Only
	4.0 X 2.5 Sqmm	400.000	Mtr.	306.40	122560.00	INR One Lakh Twenty Two Thousand Five Hundred & Fifty Nine and Paise One Hundred Only
	Providing & making heat shrinkable type indoor/outdoor/straight through terminations/joint kit of Group1 and approved make suitable for XLPE insulated 11 KV /33 KV cable, with required components, preperation of cable ends,testing etc. as required of following sizes .					
	11 KV Straight Through Joint Kit					
	3 core 240/300 Sq.mm	5.000	Per Set	13200.00	66000.00	INR Sixty Six Thousand Only
	11 KV End Termination Kit Indoor type					
	3 core 120/150/185/225 Sq.mm	12.000	Per Set	4000.00	48000.00	INR Forty Eight Thousand Only
	3 core 240/300 Sq.mm	4.000	Per Set	4360.00	17440.00	INR Seventeen Thousand Four Hundred & Forty Only
	11 KV End Termination Kit Outdoor type					
	3 core 120/150/185/225 Sq.mm	12.000	Per Set	5200.00	62400.00	INR Sixty Two Thousand Four Hundred Only
	3 core 240/300 Sq.mm	4.000	Per Set	5600.00	22400.00	INR Twenty Two Thousand Four Hundred Only
	P & Laying XLPE insulated IS:7098/II/85 of Group1 and approved make H.T.cable for working voltage 11 K.V.Earthed direct in ground including excavation of 30cmx100cm size trench, 25cm layer of river sand, IInd class bricks covering, refilling earth, compaction of earth, making necessary connection testing etc.as required of size.					
	3 core 300.0 Sq.mm	400.000	Mtr.	1359.20	543680.00	INR Five Lakh Forty Three Thousand Six Hundred & Eighty Only
	3 core 185.0 Sq.mm	700.000	Mtr.	1012.80	708960.00	INR Seven Lakh Eight Thousand Nine Hundred & Sixty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	S & Laying following size' B ' class G.I. Pipe confirming to IS : 1239 P - 1 (1990) with accessories for laying earth conductor/strip / cable in ground/surface/recess as required					
	125 mm dia.	18.000	Mtr.	740.00	13320.00	INR Thirteen Thousand Three Hundred & Twenty Only
	Supply and fixing of pillar box made of 2 mm thick powder coated CRCA sheet of 415 volts 3 phase 4 wire triple pole and neutral type, complete in all respect as required. Including knife switch of 400 amp. rating , HRC fuses with copper one piece U contacts base, brass studs and nuts, copper busbar for main and interconnection, MS angle frame of 50 x 50 x 6 mm grouted with C.C. of M-10 grade to achieve the height of 1.5 feet above the road level suitable for four outgoing.	1.000	Each	34000.00	34000.00	INR Thirty Four Thousand Only
	Supply and fixing of 11kV, 400 Amp 3pole, central pot rotating double break type isolator (IS:9921 part I toV) without earth blade operating mechanism with GI spring loaded reverse loop type fixed contact, solid hard drawn electrolytic copper tubular moving contact with silver/ nickel plated at end points, 9 nos post insulator of 12 kV (IS:2554 & IS 5350 part III), hot dipped galvanising hard ware, nut, bolts etc complete in all respect as per specification of Discom.(Type tested by ERDA/CPRI.)	30.000	Each	10520.00	315600.00	INR Three Lakh Fifteen Thousand Six Hundred Only
	Supply & Erection of lattice structure of height 11 mtr in alignment, including excavation of pit and Providing and laying of cement concrete in ratio 1:3:6 using 43 grade cement, river sand and 12 mm to 20 graded blast crusher broken in pit/ found cement plaster upto 0.50mtr. from top to bottom in 1:3:6 ratio and paint of tower of approved make two coat of red oxide paint and one coat of aluminium paint before installation and one coat of paint after irrection work completed as per technical specifications & drawing of DISCOM	14.000	Each	24400.00	341600.00	INR Three Lakh Forty One Thousand Six Hundred Only
	SITC of battery bank of min 150 AH capacity comprising SMF/VRLA batteries , MS / Teakwood battery stand , interconnect wiring etc as required complete in all respect of rating:					
	110 V DC	1.000	Each	153000.00	153000.00	INR One Lakh Fifty Three Thousand Only
	SITC of FCBC (Float cum boost charger)suitable for 415V +/-10%, 50 Hz , 1-? / 3 -? Input & 24/ 48 /110 V DC OutputNatural Cooled, free standing in Sheet Steel enclosure,SCR controlled , regulation +/-1% , Efficiency > 75% on FLAC/ DC Instruments, Selector Switch ,Built in DC Distribution Board (6 No MCB), indication , control as required of following rating:					

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	25 A + 25 A	1.000	Each	67500.00	67500.00	INR Sixty Seven Thousand Five Hundred Only
	Supply & fabrication steel structure with MS channel / angle /joist / ISMB / sheet etc. including welding, rivetting, cutting, nut & bolt , Painting etc. as required	8000.000	KG	67.20	537600.00	INR Five Lakh Thirty Seven Thousand Six Hundred Only
	P & F of IP 65 protected LED Street Light Luminaire on existing brackets. Fixture made of powder coated single piece pressure die cast aluminium housing with heat dissipation fins on housing with UV stablized PC/ Toughened glass cover and lens/ reflector. Input power (including driver loss) range from 20-25W/30-40W/80-90W/ 110-120W with luminous Efficacy > 80 Lumen/W (warm white) & > 85 lumen/W (cool white) (As per LM79). LEDs of Cree/Nichia/OSram/Philips make is to be used at 1W/2W per LED, CRI > 70 and CCT 2700 K - 6500K. The integral SMPS based electronic driver must have efficiency > 85%, Power factor > 0.95, THD < 20% and input Voltage range of 90-270 VAC at 50 Hz. System life of 25000 Burning Hours with 70% of initial Lumens maintained. Fixtures must be in compliance with IS/CE Standards. Approved make : Philips, Bajaj, Surya IP - 65 Protected LED Street Light Luminaire					
	LED Street Light fixture 110-120 Watt	16.000	Each	18920.00	302720.00	INR Three Lakh Two Thousand Seven Hundred & Twenty Only
	Providing and laying in position cement concrete including curing, compaction etc. complete in specified grade excluding the cost of centering and shuttering - All work up to plinth level.					
	M15 grade Nominal Mix 1: 2: 4 (1 cement : 2 coarse sand : 4 graded stone aggregate 40mm nominal size)	200.000	Cum	4192.00	838400.00	INR Eight Lakh Thirty Eight Thousand Four Hundred Only
	S & F of Street light bracket made out from following size of ' B ' class GI pipe with heavy duty pole clamp, Saddles suitable fastners etc. as required					
	32 mm Dia.	24.000	Mtr.	328.00	7872.00	INR Seven Thousand Eight Hundred & Seventy Two Only
	P & F energy efficient direct fit (Retrofit) LED tube system (with integral driver), on existing fixture. Power Consumption of 18W / 36W 1500-3000 lumens, system lumen efficiency 80 lm/Watt output, life time of 50,000 burning hours with 70% initial lumen maintained. CCT 3000°K, 4000°K & 6000°K. Approved Make:- Philips, CG, Bajaj, Wipro, Surya, Havell's, HPL, K-Lite, Lighting Science.					

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	4' LED Tube shape fixture 18W	20.000	Each	1120.00	22400.00	INR Twenty Two Thousand Four Hundred Only
	P & F Star rated double ball bearing capacitor start, aluminium body & blade ceiling fan with down rod up to 30 cm with 3 x 1.5 sq.mm pvc insulated flexible copper conductor making connection testing etc. as required.					
	1200 mm Sweep 5 Star rated	8.000	Each	1516.80	12134.40	INR Twelve Thousand One Hundred & Thirty Four and Paise Forty Only
	Supply and erection of GI Octagonal / Conical pole of following length and dimension as per table E-10 with base plate on the cement concrete foundation of M-20 grade (1:1.5:3) with the help of anchor bolts of grade 6.8 (IS: 1367 P III). The pole shall have a weatherproof flush door and locking arrangements. The complete work shall be supervised and certified by the manufacturers for satisfactory supply, erection, testing and commissioning.					
	Octagonal MS Poles made of S-355JO grade steel sheet , folded lengthwise to obtained Octagonal shape, having single longitudinal seam weld and hot dipped galvanised internally & externally in accordance with IS 2629. (See Table E - 10 for specs.)					
	9 Mtr.	8.000	Each	13440.00	107520.00	INR One Lakh Seven Thousand Five Hundred & Twenty Only
	Supply, Erection and Fixing of hot dipped galvanised Overhang (48.3 X 3.25 mm) with cap (400 x 88.9 / 114.3 x 3.25 mm) over the existing poles					
	Single arm overhang	12.000	Mtr.	712.00	8544.00	INR Eight Thousand Five Hundred & Forty Four Only
	Providing and fixing of single pole mounted structure set for isolator as per Discom specification complete in all respect with nuts and bolts as required MS flat 50 x 6mm, MS angle 65 x 65 x6mm, MS channel 100 x 50 x 6mm. (Excluding cost of pole).	10.000	Each	1908.00	19080.00	INR Nineteen Thousand & Eighty Only
	SITC of 33/11 KV, 5 MVA star delta transformer on existing platform with one bucholdg, MOG, winding and oil temperature indicator complete in all respect as per latest specifications of Discoms including making necessary connection etc. (The Transformer will be tested by Discom).	2.000	Nos	3704025.00	7408050.00	INR Seventy Four Lakh Eight Thousand & Fifty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Supplying and drawing FR PVC insulated & unsheathed flexible copper conductor ISI marked (IS:694) of 1.1 kV grade and approved make in existing surface or recessed conduit/casing capping including making connections etc. as required.					
	2 x 2.5 sq.mm	1520.000	Mtr.	32.80	49856.00	INR Forty Nine Thousand Eight Hundred & Fifty Five and Paise One Hundred Only
	P & F in position frame made out of M.S. angle (riveted or welded) finished with two coats of red oxide and enamel paint including cutting, welding, holes etc.of following sizes as required.					
	50mm x 50mm x 6mm	105.000	Mtr.	250.40	26292.00	INR Twenty Six Thousand Two Hundred & Ninety Two Only
	P & F paper phenolic resin bonded laminates confirming to IS : 2036 - 1995 for boxes/ frames including making holes for switches etc, with brass screws, washers/ zinc plated nut and bolts as required.					
	6.4 mm thick	6.400	Sqm	712.80	4561.92	INR Four Thousand Five Hundred & Sixty One and Paise Ninety Two Only
	SITC of wall/ free standing floor mounted dust and vermin proof compartmentalised cubical panel made out of CRCA sheet , required hardware ,duly treated for derusting in 7 tank process with dephosphating and with powder coating on both process with dephosphating and with powder coating on both side of panel in desired shade The panel having PU/ Neoprene rubber gasket of not less than 3mm thickness , separate detachable gland plate M.S. base channel ,hinged door with locking arrangement for equipment/switchgear . Thickness of sheet shall not be less than 1.6 mm up to 600 mm length / width of any compartment and be of 2.0 mm above 600 mm. Load bearing structure shall be of 2.0 mm thick sheet supported by base M.S. channel if required . Side walls and cable alley compartments having bolted type doors with / without detachable extension type structure. (only outer area on all sides shall be measured & panel to be fabricated from CPRI approved fabricator)	105.000	Sqm	2201.60	231168.00	INR Two Lakh Thirty One Thousand One Hundred & Sixty Eight Only
	Supplying and fixing of Aluminium / Copper bus bar by means of SMC / DMC type insulator, high tensile nuts and bolts spring washers in existing panel including bending , cutting in required shape and size and colour coding with heat shrinkable PVC sleeves					

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Electrolytic grade Aluminium bus bar	23.000	KG	336.00	7728.00	INR Seven Thousand Seven Hundred & Twenty Eight Only
	SF of 110/220 V, LED (22.5 mm dia) Indicating lamp with integral circuit, terminal block, including connection etc. as required.					
	Red/yellow/Green colour	15.000	Each	120.00	1800.00	INR One Thousand Eight Hundred Only
	P & F of ac operated heavy duty 230 /440 Volt power contactor conforming to IS:13947-4-1/IEC:947-4-1 having provision of mechanical interlocking, auxiliary contacts, Din rail mounting type including making connections, testing etc. as required					
	4 pole Power contactors with following AC 1 Rating					
	63 Amp	5.000	Each	2828.80	14144.00	INR Fourteen Thousand One Hundred & Forty Four Only
	SITC of quick make and quick break 3 pole current limiting MCCB having following current rating, short circuit breaking capacity at 440/415 V, 50 Hz; O/L & S/C settings and conforming to IS 60947-2 / IEC 60947-2 with front face and centralised adjustable, line load interchangeability, having positive isolation capability, provision for UVR , shunt trip , earth fault trip, push (test) to trip, including making connections with lugs & spreaders, etc. as required. With Thermal Magnetic release					
	up to 100 Amp , 16 kA, adjustable O/L & fixed S/C setting, Ics = 100 % Icu	161.000	Each	3400.00	547400.00	INR Five Lakh Forty Seven Thousand Four Hundred Only
	SITC of quick make and quick break 4 POLE current limiting MCCB having following current rating, short circuit breaking capacity at 440/415 V, 50 Hz; O/L & S/C settings and conforming to IS 60947-2 / IEC 60947-2 with front face and centralised adjustable, line load interchangeability, having positive isolation capability, provision for UVR , shunt trip ,earth fault trip, push (test) to trip , including making connections with lugs & spreaders, etc. as required. With Thermal Magnetic release					
	up to 100 Amp , 16 kA, adjustable O/L & fixed S/C setting, Ics = 100 % Icu	5.000	Each	4640.00	23200.00	INR Twenty Three Thousand Two Hundred Only
	P&F of mechanical / digital time switch having following day / week programme and minimum 100 hours reserve and AC1 rating of 16-20 amperes including making connection, programming etc. as required					

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	One day & week reserve (digital type)	5.000	Each	4596.80	22984.00	INR Twenty Two Thousand Nine Hundred & Eighty Four Only
	Supplying and drawing of XLPE insulated LT Aerial bunched Aluminium conductor cable confirming to IS 14255/1995 and IS 398 (Pt-4)/ 1994 on existing cross arms through I hook with all necessary T&P required including binding and twisting etc. complete in all respect as required as per Discom specification					
	3 X 25 sq. mm. + 1X25 sq. mm. (insulated)	1500.000	Mtr.	70.40	105600.00	INR One Lakh Five Thousand Six Hundred Only
	Supply and installation of spike of M.S. rod 20mm dia 3.0mtr. long for earthing of (tower/pole) drive into earth by mechanical means sturcture connection the spike with cross arm top hamper PCC pole, lattics tower to earth etc. complete as per technical specification of DISCOM	36.000	Per Set	520.00	18720.00	INR Eighteen Thousand Seven Hundred & Twenty Only
	S & Laying following size earth wire/strip in horizontal or vertical run in ground/surface/recess including riveting, soldering, saddles, making connection etc. as required					
	8 SWG G.I. (Hot Dipped) Wire	108.000	Mtr.	7.20	777.60	INR Seven Hundred & Seventy Seven and Paise Sixty Only
	Supply and erection of GI Octagonal / Conical pole of following length and dimension as per table E-10 with base plate on the cement concrete foundation of M-20 grade (1:1.5:3) with the help of anchor bolts of grade 6.8 (IS: 1367 P III). The pole shall have a weatherproof flush door and locking arrangements. The complete work shall be supervised and certified by the manufacturers for satisfactory supply, erection, testing and commissioning.					
	Octagonal MS Poles made of S-355JO grade steel sheet , folded lengthwise to obtained Octagonal shape, having single longitudinal seam weld and hot dipped galvanised internally & externally in accordance with IS 2629. (See Table E - 10 for specs.)					
	8 Mtr.	160.000	Each	9840.00	1574400.00	INR Fifteen Lakh Seventy Four Thousand Four Hundred Only
	S & Laying following size' B ' class G.I. Pipe confirming to IS : 1239 P - 1 (1990) with accessories for laying earth conductor/strip / cable in ground/surface/recess as required					
	80 mm dia	50.000	Mtr.	443.20	22160.00	INR Twenty Two Thousand One Hundred & Sixty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Supply, Erection and Fixing of hot dipped galvanised Overhang (48.3 X 3.25 mm) with cap (400 x 88.9 / 114.3 x 3.25 mm) over the existing poles Single arm overhang	240.000	Mtr.	712.00	170880.00	INR One Lakh Seventy Thousand Eight Hundred & Eighty Only
	P & F of IP 65 protected LED Street Light Luminaire on existing brackets. Fixture made of powder coated single piece pressure die cast aluminium housing with heat dissipation fins on housing with UV stablized PC/ Toughened glass cover and lens/ reflector. Input power (including driver loss) range from 20-25W/30-40W/80-90W/ 110-120W with luminous Efficacy > 80 Lumen/W (warm white) & > 85 lumen/W (cool white) (As per LM79). LEDs of Cree/Nichia/OSram/Philips make is to be used at 1W/2W per LED, CRI > 70 and CCT 2700 K - 6500K. The integral SMPS based electronic driver must have efficiency > 85%, Power factor > 0.95, THD < 20% and input Voltage range of 90-270 VAC at 50 Hz. System life of 25000 Burning Hours with 70% of initial Lumens maintained. Fixtures must be in compliance with IS/CE Standards. Approved make : Philips, Bajaj, Surya IP - 65 Protected LED Street Light Luminaire					
	LED Street Light fixture 80-90 Watt	160.000	Each	10120.00	1619200.00	INR Sixteen Lakh Nineteen Thousand Two Hundred Only
	SITC of Cutting back up surface up to 2 Mtr. Depth by digging by Bogi including all layers of crust for laying pipe line etc. and making good to original condition (excluding cost of bitumen)	3000.000	Mtr.	288.00	864000.00	INR Eight Lakh Sixty Four Thousand Only
	S & F of Street light bracket made out from following size of ' B ' class GI pipe with heavy duty pole clamp, Saddles suitable fastners etc. as required.					
	32 mm Dia.	45.000	Mtr.	328.00	14760.00	INR Fourteen Thousand Seven Hundred & Sixty Only
	P&F 240/415 V AC MCB with positive isolation of breaking capacity not less than 10 KA (B/ C/ D tripping characteristic) ISI marked IS 8828(1996)]/ conforming to IEC 60898 in existing board/sheets including making onnections, testing etc. as required. Single pole MCB					
	6 A to 32 A rating	320.000	Each	120.80	38656.00	INR Thirty Eight Thousand Six Hundred & Fifty Six Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	P/Laying P.V.C. / XLPE insulated & P.V.C. sheathed cable of 1.1 KV grade with aluminium conductor of IS:1554 P-I / IS :7098 P - I of Group 1 of approved make in ground as per IS:1255 including excavation of 30cmx75cm size trench, 25 cm thick under layer of sand, IInd class bricks covering, refilling earth, compaction of earth, making necessary connection, testing etc. as required of size.					
	2.0 x 10.0 Sqmm	12000.000	Mtr.	109.60	1315200.00	INR Thirteen Lakh Fifteen Thousand Two Hundred Only
	4.0 x 16.0 Sqmm	6760.000	Mtr.	142.40	962624.00	INR Nine Lakh Sixty Two Thousand Six Hundred & Twenty Four Only
	3.5 x 25.0 Sqmm	750.000	Mtr.	166.40	124800.00	INR One Lakh Twenty Four Thousand Eight Hundred Only
	Supplying and making one end termination with heavy duty single compression brass gland SIBG type, heavy duty aluminium lugs duly crimped with crimping tool, PVC tape etc for following size of Armoured PVC insulated & PVC sheathed/ XLPE aluminium conductor cable of 1100 volt grade as required of size.					
	2.0 x 10.0 Sqmm	156.000	Per Set	44.00	6864.00	INR Six Thousand Eight Hundred & Sixty Four Only
	3.5 x 25.0 Sqmm	10.000	Per Set	91.20	912.00	INR Nine Hundred & Twelve Only
	4.0 x 16.0 Sqmm	52.000	Per Set	86.40	4492.80	INR Four Thousand Four Hundred & Ninety Two and Paise Eighty Only
	Supply and fixing in cement mortar welded hand railing made out of MS round or square bars, flats etc. for staircase or verandah as per design complete in all respect (wooden or PVC hand railing to be paid extra) with priming coat of red oxide.	208.460	KG	61.20	12757.75	INR Twelve Thousand Seven Hundred & Fifty Seven and Paise Seventy Five Only
	Extra 10% for providing D type pipe head as top of hand railing	208.450	KG	0.00	0.00	INR Zero Only
	Supplying and fixing fixed wire gauge of 14 mesh x 24 gauge to the metal frame of rolled section by metal beading 20x3mm with suitable screw at not exceeding 150mm distance	20.415	Sqm	385.20	7863.86	INR Seven Thousand Eight Hundred & Sixty Three and Paise Eighty Six Only
	Providing and fixing Square bars or other flat welded to window, ventilations etc.	92.050	KG	55.80	5136.39	INR Five Thousand One Hundred & Thirty Six and Paise Thirty Nine Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Providing and fixing 1st quality standard white, grey, ivory, fume red brown, light green, light blue and other light shades glazed tiles confirming to IS : 13753	31.634	Sqm	462.60	14633.89	INR Fourteen Thousand Six Hundred & Thirty Three and Paise Eighty Nine Only
	Providing and fixing 1st quality MAT finished ceramic tile size 300x300mm confirming to IS : 13755 and IS : 15622 colour such as white, grey, ivory, fume red brown, light green, light blue and other light shades in floors, steps, pillars etc. laid on a bed of neat cement slurry finished with flush pointing in the white cement mixed with pigment to match the shade of the tile complete (including the cost of cement mortar bed 1:4).	10.000	Sqm	506.70	5067.00	INR Five Thousand & Sixty Seven Only
	Providing and fixing 100mm brass locks (best make of approved quality) for aluminium doors including necessary cutting and making good etc. complete.	2.000	Each	216.00	432.00	INR Four Hundred & Thirty Two Only
	Earth work in excavation by mechanical means (Hydraulic excavator)/ manual means over areas (exceeding 30cm in depth. 1.5m in width as well as 10 sum on plan) including disposal of excavated earth, lead upto 50m and lift upto 1.5 m , disposed earth to be levelled and neatly dressed: All kinds of soil	367.714	Cum	109.80	40375.00	INR Forty Thousand Three Hundred & Seventy Four and Paise One Hundred Only
	Structural steel work riveted, bolted or welded in built up sections, trusses and framed work, including cutting, hoisting (height upto 10 m) , fixing in position and applying a priming coat of approved steel primer all complete	900.000	KG	59.40	53460.00	INR Fifty Three Thousand Four Hundred & Sixty Only
	Providing and fixing steel gate, grating , and grills made of angles, tees, square bars, flats, or black pipe with holdfast and fittings complete as per design and drawing including cutting welding and fabrication with priming coat of red oxide	1050.000	KG	66.60	69930.00	INR Sixty Nine Thousand Nine Hundred & Thirty Only
	Extra 10% if square, rectangular hollow tubular sections are used or grill made by flats only	1050.000	KG	0.00	0.00	INR Zero Only
	Filling available excavated earth (excluding rock) in trenches plinth side of foundation etc. in layers not exceeding 20 cm. in depth, consolidating each deposited layer by ramming and watering including lead up to 50 meter and with all lift.	357.714	Cum	40.50	14487.42	INR Fourteen Thousand Four Hundred & Eighty Seven and Paise Forty Two Only
	Providing and fixing T-iron frames for doors, windows and ventilators of mild steel Tee-sections, joints mitred and welded with 15x3 mm lugs 10cm long embedded in cement concrete blocks 15x10x10 cm of 1:3:6 (1 cement : 3 coarse sand : 6 graded stone aggregate 20 mm nominal size) or with wooden plugs and screws or rawl plugs and screws or with fixing clips or with bolts and nuts as require including fixing of necessary butt hinges and screws and applying a priming coat of approved steel primer	126.875	KG	63.90	8107.31	INR Eight Thousand One Hundred & Seven and Paise Thirty One Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Providing and fixing 1mm thick M.S. sheet sliding-shutters with frame & diagonals braces of 40 x 40 x 6mm. angle iron 3mm M.S. gusset plates at the junction and corners, 25mm dia pulley 40x40x6mm angle and T-iron guide at the top and bottom respectively including applying a priming coat of approved steel primer	2.205	Sqm	2595.60	5723.30	INR Five Thousand Seven Hundred & Twenty Three and Paise Thirty Only
	All kinds of soil	196.459	Cum	21.60	4243.51	INR Four Thousand Two Hundred & Forty Three and Paise Fifty One Only
	M15 grade Nominal Mix 1: 2: 4 (1 cement : 2 coarse sand : 4 graded stone aggregate 20mm nominal size).	2.594	Cum	2882.70	7477.72	INR Seven Thousand Four Hundred & Seventy Seven and Paise Seventy Two Only
	1:4:8 (1 cement : 4 coarse sand : 8 graded stone aggregate 40 mm nominal size).	62.739	Cum	2058.30	129135.68	INR One Lakh Twenty Nine Thousand One Hundred & Thirty Five and Paise Sixty Eight Only
	Cement Mortar 1:6 (1-Cement : 6-Sand).	181.939	Cum	1770.30	322086.61	INR Three Lakh Twenty Two Thousand & Eighty Six and Paise Sixty One Only
	Cement mortar 1 : 6 (1 cement : 6 coarse sand)	339.849	Cum	3183.30	1081841.32	INR Ten Lakh Eighty One Thousand Eight Hundred & Forty One and Paise Thirty Two Only
	Cement mortar 1 : 4 (1 cement : 4 coarse sand)	37.170	Sqm	369.90	13749.18	INR Thirteen Thousand Seven Hundred & Forty Nine and Paise Eighteen Only
	Providing and laying in position specified grade of cement concrete for all RCC structural elements upto plinth level including curing, compaction, finishing with rendering in including curing, compaction, finishing with rendering in cement sand mortar 1:3 (1 cement: 3 coarse sand) and making good the joints and cost of plastizers(if required) excluding the cost of centering, shuttering and reinforcement. M20 grade Nominal Mix / Design Mix	12.953	Cum	2961.00	38353.83	INR Thirty Eight Thousand Three Hundred & Fifty Three and Paise Eighty Three Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Providing and laying in position specified grade of cement concrete for RCC structural elements upto floor five level including curing, compaction, finishing with rendering in cement sand mortar 1:3 (1 cement: 3 coarse sand) and making good the joints and cost of plastizers (if required) excluding the cost of centering, shuttering and reinforcement for Walls (any thickness) including attached pilasters, buttresses, plinth and string courses, fillets, columns, pillars, piers, abutments, posts and struts etc.M20 grade Nominal Mix / Design Mix	12.074	Cum	3673.80	44357.46	INR Forty Four Thousand Three Hundred & Fifty Seven and Paise Forty Six Only
	Providing and laying in position Ready mix concrete manufactured in fully automatic Batching Plant and transported to site in transit mixer for having continous agitated mixer, manufactured as per approved mix design of specified grade of RCC work including pumping of R.M.C. from transit mixer to site of laying , excuding the cost of centering, shuttering and reinforcement with all lead and lift including cost of admixtures in recommended portion as per IS 9103 to accelerate/ retard setting of concrete, improve workability without impairing strength and durability as per direction of Engineer in charge . All works upto floor V floorM20 grade Design Mix by using min 400 Kg of cement per cum of concrete	66.426	Cum	3902.40	259220.82	INR Two Lakh Fifty Nine Thousand Two Hundred & Twenty and Paise Eighty Two Only
	Providing M-25 grade concrete by using min 410 kg of cement per cum instead of M-20 grade design mix.	91.450	Cum	51.30	4691.39	INR Four Thousand Six Hundred & Ninety One and Paise Thirty Nine Only
	Centering and Shuttering with plywood or steel sheets including strutting, propping bracing both ways and removal of formwork for foundation , footings, strap beam, raft , bases of columns etc	190.256	Sqm	99.00	18835.34	INR Eighteen Thousand Eight Hundred & Thirty Five and Paise Thirty Four Only
	Suspended floors, roofs, landings, staircases, balconies, girders, cantilevers, bands, coping bed plates, anchor blocks, sills, chhajjas, lintel, beam, plinth beam etc.	414.732	Sqm	212.40	88089.08	INR Eighty Eight Thousand &Eighty Nine and Paise Eight Only
	Columns, pillars, posts and struts etc.	113.916	Sqm	234.00	26656.34	INR Twenty Six Thousand Six Hundred & Fifty Six and Paise Thirty Four Only
	Thermo-mechanically Treated bars (Conforming of relevent IS code)	11454.000	Sqm	62.10	711293.40	INR Seven Lakh Eleven Thousand Two Hundred & Ninety Three and Paise Forty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	12 mm thick	713.814	Sqm	94.50	67455.42	INR Sixty Seven Thousand Four Hundred & Fifty Five and Paise Forty Two Only
	20 mm thick	1308.136	Sqm	107.10	140101.37	INR One Lakh Forty Thousand One Hundred & One and Paise Thirty Seven Only
	6 mm thick cement plaster to ceiling of mix 1:3 (1cement : 3-fine sand)	810.328	Sqm	67.50	54697.14	INR Fifty Four Thousand Six Hundred & Ninety Seven and Paise Fourteen Only
	Using M.S. angles 40 x 40 x 6mm for diagonal braces.	4.410	Sqm	2133.90	9410.50	INR Nine Thousand Four Hundred & Ten and Paise Fifty Only
	For area of each slab from 901 to 2000 Sq.Cm :	131.460	Sqm	593.10	77968.93	INR Seventy Seven Thousand Nine Hundred & Sixty Eight and Paise Ninety Three Only
	For area of each slab upto 2001 Sqcm	12.657	Sqm	568.80	7199.30	INR Seven Thousand One Hundred & Ninety Nine and Paise Thirty Only
	For area of each slab from 2001 to 5000 Sqcm	35.224	Sqm	625.50	22032.61	INR Twenty Two Thousand & Thirty Two and Paise Sixty One Only
	Window openable	2.160	Sqm	2371.50	5122.44	INR Five Thousand One Hundred & Twenty Two and Paise Forty Four Only
	Window fixed.	1.620	Sqm	2215.80	3589.60	INR Three Thousand Five Hundred & Eighty Nine and Paise Sixty Only
	Providing	80.276	Sqm	229.50	18423.34	INR Eighteen Thousand Four Hundred & Twenty Three and Paise Thirty Four Only
	With float glass panes of 5.0 mm thickness (weight not less than 13.50 kg/sqm)	34.650	Sqm	613.80	21268.17	INR Twenty One Thousand Two Hundred & Sixty Eight and Paise Seventeen Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	With stainless steel cover plate	2.000	Sqm	991.80	1983.60	INR One Thousand Nine Hundred & Eighty Three and Paise Sixty Only
	Anodised aluminum (anodised transparent 81 dyed to required shade according to IS : 1868. (Minimum anodic coating of grade AC 15, Anodizing to be got done from approved Anodizer)	34.650	Sqm	1332.00	46153.80	INR Forty Six Thousand One Hundred & Fifty Three and Paise Eighty Only
	40mm thick with 20mm thick nominal size aggregate	12.300	Sqm	172.80	2125.44	INR Two Thousand One Hundred & Twenty Five and Paise Forty Four Only
	75mm thick with 20mm thick nominal size aggregate	12.300	Sqm	286.20	3520.26	INR Three Thousand Five Hundred & Twenty and Paise Twenty Six Only
	Random rubble dry stone Kharanja under floor.	20.467	Sqm	581.40	11899.51	INR Eleven Thousand Eight Hundred & Ninety Nine and Paise Fifty One Only
	Commercial Veneer both side	13.230	Sqm	1106.10	14633.70	INR Fourteen Thousand Six Hundred & Thirty Three and Paise Seventy Only
	Providing and applying white cement based putty over plastered surface to prepare the surface even and smooth complete	1308.136	Sqm	64.80	84767.21	INR Eighty Four Thousand Seven Hundred & Sixty Seven and Paise Twenty One Only
	Finishing walls with Acrylic Smooth exterior paint of required shade including all scaffolding. New work (Two or more coat applied @ 1.67 ltr/10 sqm over and including base coat of water proofing cement paint applied @ 2.20 kg/ 10 sqm).	713.814	Sqm	54.00	38545.96	INR Thirty Eight Thousand Five Hundred & Forty Five and Paise Ninety Six Only
	New work (Two or more coats applied @ 3.84 kg/10 sqm).	1308.136	Sqm	33.30	43560.93	INR Forty Three Thousand Five Hundred & Sixty and Paise Ninety Three Only
	Two or more coats on new work	192.474	Sqm	39.60	7621.97	INR Seven Thousand Six Hundred & Twenty One and Paise Ninety Seven Only
	For 1 Km.	163.735	Cum	36.63	5997.61	INR Five Thousand Nine Hundred & Ninety Seven and Paise Sixty One Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Cement concrete 1:2:4 (1 cement : 2 coarse sand : 4 graded stone aggregate 20 mm nominal size)	13.939	Cum	2934.00	40897.03	INR Forty Thousand Eight Hundred & Ninety Seven and Paise Three Only
	Providing gola 75x75 mm in cement concrete 1:2:4 (1 cement : 2 coarse sand : 4 stone aggregate 10mm and down gauge) including finishing with cement mortar 1:3 (1 cement : 3 fine sand) as per standard design :	176.310	Mtr.	72.90	12853.00	INR Twelve Thousand Eight Hundred & Fifty Two and Paise One Hundred Only
	Kota stone 25 to 30mm thick.	80.000	Sqm	305.10	24408.00	INR Twenty Four Thousand Four Hundred & Eight Only
	Square or Rectangular pillars	7.918	Cum	135.00	1068.93	INR One Thousand &Sixty Eight and Paise Ninety Three Only
	110 mm dia	15.000	Mtr.	156.60	2349.00	INR Two Thousand Three Hundred & Forty Nine Only
	P & F European type white glazed vitreous china 1st quality W.C pan (IS : 2556 Mark) with P or S trap including cutting and making good the wall and floor	12.000	Each	1165.50	13986.00	INR Thirteen Thousand Nine Hundred & Eighty Six Only
	Size 580x440mm.	8.000	Each	1585.80	12686.40	INR Twelve Thousand Six Hundred & Eighty Six and Paise Forty Only
	Flat Back (large) or half stall size 610x400x80mm	8.000	Each	2774.70	22197.60	INR Twenty Two Thousand One Hundred & Ninety Seven and Paise Sixty Only
	Makrana `Adanga` or Raj Nagar 1St Quality White or Andhi Indo-Italian marble.	8.000	Each	560.70	4485.60	INR Four Thousand Four Hundred & Eighty Five and Paise Sixty Only
	PVC with PVC bend of make Commander champion	26.000	Each	1030.50	26793.00	INR Twenty Six Thousand Seven Hundred & Ninety Three Only
	Size 580 mm x 450 mm	12.000	Mtr.	1667.70	20012.40	INR Twenty Thousand &Twelve and Paise Forty Only
	B' Class	78.000	Mtr.	126.90	9898.20	INR Nine Thousand Eight Hundred & Ninety Eight and Paise Twenty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	B' Class	78.000	Mtr.	158.40	12355.20	INR Twelve Thousand Three Hundred & Fifty Five and Paise Twenty Only
	B' Class	30.000	Mtr.	99.00	2970.00	INR Two Thousand Nine Hundred & Seventy Only
	B' Class	30.000	Mtr.	165.60	4968.00	INR Four Thousand Nine Hundred & Sixty Eight Only
	Brass 400 grm,15mm nominal bore.	24.000	Each	198.90	4773.60	INR Four Thousand Seven Hundred & Seventy Three and Paise Sixty Only
	Brass 400 gm. 15mm nominal bore.	4.000	Each	207.00	828.00	INR Eight Hundred & Twenty Eight Only
	Brass 1350gm. 25 mm nominal bore	4.000	Each	530.10	2120.40	INR Two Thousand One Hundred & Twenty and Paise Forty Only
	C.P. Inlet connection 15mm.Brass (IS : 8931 marked)	38.000	Each	475.20	18057.60	INR Eighteen Thousand & Fifty Seven and Paise Sixty Only
	CP brass push type concealed 25mm nominal bore.	26.000	Each	688.50	17901.00	INR Seventeen Thousand Nine Hundred & One Only
	500 litres capacity.	6.000	Each	2700.00	16200.00	INR Sixteen Thousand Two Hundred Only
	For items 2.26.1 to 2.26.4	6.000	Each	63.00	378.00	INR Three Hundred & Seventy Eight Only
	Gun-metal 15mm nominal bore.	2.000	Each	223.20	446.40	INR Four Hundred & Forty Six and Paise Forty Only
	Gun-metal 25mm nominal bore.	26.000	Each	391.50	10179.00	INR Ten Thousand One Hundred & Seventy Nine Only
	15mm dia nominal bore	2.000	Each	79.20	158.40	INR One Hundred & Fifty Eight and Paise Forty Only
	25mm dia nominal bore	2.000	Each	126.90	253.80	INR Two Hundred & Fifty Three and Paise Eighty Only
	75 mm dia	198.000	Mtr.	99.00	19602.00	INR Nineteen Thousand Six Hundred & Two Only
	110 mm dia	258.000	Mtr.	198.00	51084.00	INR Fifty One Thousand & Eighty Four Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	75 mm dia	6.000	Each	40.50	243.00	INR Two Hundred & Forty Three Only
	110 mm dia	6.000	Each	61.20	367.20	INR Three Hundred & Sixty Seven and Paise Twenty Only
	75 mm dia	6.000	Each	53.10	318.60	INR Three Hundred & Eighteen and Paise Sixty Only
	110 mm dia	20.000	Each	88.20	1764.00	INR One Thousand Seven Hundred & Sixty Four Only
	75 mm dia	4.000	Each	45.00	180.00	INR One Hundred & Eighty Only
	110 mm dia	4.000	Each	75.60	302.40	INR Three Hundred & Two and Paise Forty Only
	75 mm dia	4.000	Each	70.20	280.80	INR Two Hundred & Eighty and Paise Eighty Only
	110 mm dia	26.000	Each	109.80	2854.80	INR Two Thousand Eight Hundred & Fifty Four and Paise Eighty Only
	75 mm dia	4.000	Each	81.90	327.60	INR Three Hundred & Twenty Seven and Paise Sixty Only
	110 mm dia	4.000	Each	157.50	630.00	INR Six Hundred & Thirty Only
	75 mm dia	20.000	Each	10.80	216.00	INR Two Hundred & Sixteen Only
	110 mm dia	40.000	Each	17.10	684.00	INR Six Hundred & Eighty Four Only
	75 mm dia	6.000	Each	67.50	405.00	INR Four Hundred & Five Only
	110 mm dia	6.000	Each	119.70	718.20	INR Seven Hundred & Eighteen and Paise Twenty Only
	75 mm dia	12.000	Each	388.80	4665.60	INR Four Thousand Six Hundred & Sixty Five and Paise Sixty Only
	110 mm dia	36.000	Each	86.40	3110.40	INR Three Thousand One Hundred & Ten and Paise Forty Only
	75 mm dia	4.000	Each	27.90	111.60	INR One Hundred & Eleven and Paise Sixty Only
	110 mm dia	4.000	Each	33.30	133.20	INR One Hundred & Thirty Three and Paise Twenty Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Complete Rate Group 1	180.000	Point p point	172.00	30960.00	INR Thirty Thousand Nine Hundred & Sixty Only
	Complete Rate Group 1	90.000	Point p point	270.40	24336.00	INR Twenty Four Thousand Three Hundred & Thirty Five and Paise One Hundred Only
	Complete Rate Group 1	55.000	Point p point	379.20	20856.00	INR Twenty Thousand Eight Hundred & Fifty Six Only
	Complete Rate Group 1	80.000	Point p point	72.00	5760.00	INR Five Thousand Seven Hundred & Sixty Only
	Complete Rate Group 1	200.000	Point p point	200.80	40160.00	INR Forty Thousand One Hundred & Sixty Only
	Complete Rate Group 1	90.000	Point p point	294.40	26496.00	INR Twenty Six Thousand Four Hundred & Ninety Five and Paise One Hundred Only
	Complete Rate Group 1	60.000	Point p point	398.40	23904.00	INR Twenty Three Thousand Nine Hundred & Four Only
	Complete Rate Group 1	250.000	Mtr.	42.40	10600.00	INR Ten Thousand Six Hundred Only
	Complete Rate Group 1	250.000	Mtr.	61.60	15400.00	INR Fifteen Thousand Four Hundred Only
	Complete Rate Group 1	250.000	Mtr.	71.20	17800.00	INR Seventeen Thousand Eight Hundred Only
	Complete Rate Group 1	150.000	Each	120.80	18120.00	INR Eighteen Thousand One Hundred & Twenty Only
	Complete Rate Group 1	36.000	Each	320.80	11548.80	INR Eleven Thousand Five Hundred & Forty Eight and Paise Eighty Only
	Complete Rate Group 1	36.000	Each	444.00	15984.00	INR Fifteen Thousand Nine Hundred & Eighty Four Only
	Complete Rate Group 1	60.000	Each	16.00	960.00	INR Nine Hundred & Sixty Only
	Complete Rate Group 1	42.000	Each	76.00	3192.00	INR Three Thousand One Hundred & Ninety Two Only

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Complete Rate Group 1	42.000	Each	301.60	12667.20	INR Twelve Thousand Six Hundred & Sixty Seven and Paise Twenty Only
	Mild Steel Tower Bolt 6" long	10.000	Each	27.90	279.00	INR Two Hundred & Seventy Nine Only
	Steel Locking Bolt	10.000	Each	37.80	378.00	INR Three Hundred & Seventy Eight Only
	Steel Handle 6" size	10.000	Each	17.10	171.00	INR One Hundred & Seventy One Only
	Brick masonry with F.P.S. bricks of class designation 75 in 'foundation and plinth with bricks					
	Cement mortar 1 : 4 (1 cement : 4 coarse sand)	85.000	Cum	2767.50	235237.50	INR Two Lakh Thirty Five Thousand Two Hundred & Thirty Seven and Paise Fifty Only
	RIGID PVC SOIL					
	Construction of manhole in all type of soil inner size 90 X 60 Cm. 300 mm thick masonry in CM 1:6, 10 Cm. thick cement concrete 1:5:10 in foundation, 20 mm thick inside plaster in CM 1:6, finished with floating neat cement, 50mm thick M-15 grade C.C. flooring, making channels, 80mm thick stone slab covering with 40mm thick M-15 grade C.C. flooring, Cement cover with frame of 450mm dia, earthwork etc. complete as per design including disposal of surplus earth within 50 mtr. lead.					
	Add extra if R.C.C slab of designed thickness & reinforcement 20.000 145.80 sqm 2,916.00 is provided on manhole in place of stone slab(Actual area of R.C.C slab to be measured).	20.000	Cum	145.80	2916.00	INR Two Thousand Nine Hundred & Sixteen Only
	Supplying & Fixing R.C.C. Manholes covers with frame of approved make (Light duty). Size 600 X 600mm (Double seal)	10.000	Each	284.40	2844.00	INR Two Thousand Eight Hundred & Forty Four Only
	Construction of Man hole, in all types of soil, inner size 1.5 x 1.2 M, with 450mm thick masonry in CM 1:6, 10 Cm. thick cement concrete 1:5:10 in foundation, 20mm thick inside plaster in CM 1:6, finished with floating neat cement, 50 mm thick M-15 grade C.C. flooring making channels, 80 mm thick stone slab covering with 40 mm thick M-15 grade C.C. flooring, Ferro Cement cover with frame of 450mm dia, earthwork etc. complete including disposal of surplus earth within 50 mtr. lead as per design :					

Tender Inviting Authority: JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Electrification work at JDA Multipurpose Scheme Metro Enclave, B2 bypass, JDA, Jaipur.

Contract No: EE (Elect-III)/12/2021-22

Bidder Name :						
PRICE SCHEDULE						
Sl. No.	Item Description	Quantity	Units	Estimated Rate	TOTAL AMOUNT	TOTAL AMOUNT In Words
	Depth up to 1.5 M	1.000	Each	12890.70	12890.70	INR Twelve Thousand Eight Hundred & Ninety and Paise Seventy Only
	Add extra over item 3.21.1 for every additional 0.10m depth above 1.5 m depth	10.000	Each	453.60	4536.00	INR Four Thousand Five Hundred & Thirty Six Only
	Construction of septic Tank in all types of soil with 40 Cm .thick masonry in CM 1:6, 15 Cm thick C.C bed of 1:5:10, M-15 grade C.C flooring & over stone slab covering ,80 mm thick slab ,jointing of slab in CM 1:3. Ralthal, Kharanja, 50 mm thick stone partition walls, 20 mm thick plaster in CM 1:6 finished with neat floating cement, 4 Nos C.I foot rests of approved design ,two No. 450 mm dia each Ferro cement cover with frame, earth work etc. complete as per approved drawing including disposal of surplus earth within a lead of 50 mtr:- Size 400 x140x150 cm.(for 50 users)					
		1.000	Each	36873.00	36873.00	INR Thirty Six Thousand Eight Hundred & Seventy Three Only
Total in Figures					103261940.59	INR Ten Crore Thirty Two Lakh Sixty One Thousand Nine Hundred & Forty and Paise Fifty Nine Only
Quoted Rate in Figures			Select		0.00	INR Zero Only
Quoted Rate in Words		INR Zero Only				