



No.: JDA/EE-Drainage/2022-23/D- 755

Dated: 21/6/2022

## PRE-BID MEETING MINUTES

Name of Work: - "Construction of Major Drain on Vandematram Road - Muhana Mandi Road under master drainage zone 8 and PRN (South) JDA, jaipur".

NIT of tender of Construction of Major Drain on Vandematram Road - Muhana Mandi Road under master drainage zone 8 and PRN (South) JDA, jaipur was issued on 26/05/2022 with Pre-Bid meeting to be held on 17/06/2022 at 03:00 PM in MANTHAN Hall of JDA. The last date of submitting the tender online is 01/07/2022 up to 06:00 PM. The tender (Technical Bid) will be opened on 07/07/2022 at 03:00 PM. Following are the proceedings of Pre-Bid meeting.

Pre-Bid meeting held on 17/06/2022 in MANTHAN Hall of JDA which was attended by officers of JDA and Prospective bidder as per attendance sheet enclosed at Annexure-1.

After briefing about the project the Pre-Bid queries were started to be made by the participants representing their organization/firm. The queries made and decisions so given are as follows which will become the part of tender document.

S. No.	Name of Firm	Query	As per Original	Reply/ As Proposed
1	Prospective bidder-1	Escalation Factor is not given please provide us.	--	Price Escalation Factors as mention below:- (i) Labour (P <sub>1</sub> ): 14.38% (ii) Cement (P <sub>c</sub> ): 20.22% (iii) Steel (P <sub>s</sub> ): 43.70% (iv) Bitumen(P <sub>b</sub> ): 3.90% (v) POL-P: 3.18% (vi) Other Material (P <sub>m</sub> ):14.62% Total: 100.00%
2	Prospective bidder-1	Time Period for completion period for work is 12 months but I request you please that time is not sufficient for complete the project please extend for 18 months .	Time Period 12 months	No change as per Bid document
3	Prospective bidder-1	In Special condition of contract regarding	Special Condition of contract 10. Ordinary	No change as per agreement



# JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

www.jda.urban.rajasthan.gov.in

S. No.	Name of Firm	Query	As per Original	Reply/ As Proposed
		drainage work its given that the OPC Grade 43 is use for all concrete but I request you please allow the PPC for low concretes that is M-10 to M-20 .	Portland cement 43 grade conforming to IS:8112 shall be used.	
4	Prospective bidder-1	You have given in Conflict of Interest that the bidder should submit the undertaking that the bidder have not Blacklisted or Rescinded by the client in last 10 Years but in RTPP Annexure A you given that the bidder have not debarred in last 3 Years. Please it also consider in our undertaking that 3 years in place of 10 years .	"We do hereby undertake that we have not been Blacklisted or Deregistered by any Central/State Government or Public Sector Undertaking, Autonomous Bodies etc., and also that none of our work has rescinded by the client after award of contract during last 10 years"	Corrigendum letter already uploaded for this point as mentioned below.  "We do hereby undertake that we have not been Blacklisted or Deregistered by any Central/ State Government or Public Sector Undertaking, Autonomous Bodies etc., and also that none of our work has rescinded by the client after award of contract during last 03 years"
5	Prospective bidder-1	In Schedule H , Point No. 30 & 31 you have given the price variation decision shall be applicable as per order no . D - 352 dated 29/8/2018, the order copy is not enclosed please provide us .		Price variation shall be given as per contract agreement.
6	Prospective bidder-1	In EMD - Please reduce the EMD amount 1% in place of 2 % .	Amount (INR) : 2% for registered in other department and 0.5% for contractor enlisted in JDA.	No change. As per bid document.




# JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

www.jda.urban.rajasthan.gov.in

S. No.	Name of Firm	Query	As per Original		Reply/ As Proposed	
7	Prospective bidder-2	As per Note(i) Page. 10 of RFP, quantity of steel has been asked financial year wise, but client has issued our completion certificate with total quantity mentioned on it.	(i) The Bidder should enclose the certificate having quantities financial year wise otherwise the certificate will not be considered.		Bidder has to submit the cumulative certificate of executed qty. in last 7 year, in case work is executed in more then last 7 financial year then breakup of qty. during the desire period or before that has to be given.	
8	As per discussion in pre bid meeting	As discussed in meeting that in Schedule-III at S.No.(7) capacity of batch mix plant to be changed from 30Cum/Hr to 15Cum/Hr.	7	Batch mix concrete Plant Capacity 30 Cum/Hr	01 Nos.	Computerized fully automatic Batch mix concrete Plant of minimum Capacity 15 Cum/Hr
					7	01 Nos.


Enclosed:-

- (i) Attendance Sheet Flag-1,
- (ii) The copy of order no: D-352 dated 29.08.2018

  
 Executive Engineer-(Drainage)  
 JDA, Jaipur

Copy to:-

1. P.S. to JDC, JDA, Jaipur,
2. Director (Engg.-III), JDA, Jaipur,
3. Director (Finance), JDA, Jaipur,
4. Additional Chief Engineer-I, JDA, Jaipur,
5. Superintending Engineer-VI, JDA, Jaipur,
6. Sr. A.O.-(Works-III), JDA, Jaipur,
7. Prospective Bidders,
8. Notice Board E-Procurement Portal.

  
 Executive Engineer-(Drainage)  
 JDA, Jaipur