

Clarification – 1

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of Work:- Providing Laying and Jointing of Main Trunk Sewer Line of size 800 mm to 1200 mm dia with construction of Manholes for PRN (North) area to 30 MLD STP Nevta, under Jurisdiction of EE PHE-II, JDA, Jaipur.

MINUTES OF PRE-BID MEETING

1. NIT, of tender of "Providing Laying and Jointing of Main Trunk Sewer Line of size 800 mm to 1200 mm dia with construction of Manholes for PRN (North) area to 30 MLD STP Nevta, under Jurisdiction of EE PHE-II, JDA, Jaipur" was issued on 25.09.2024. The pre-bid conference was to be held on 14.10.2024 and date of receipt of tender as 04.11.2024. The sale of bid documents as published are on from 25.09.2024 onwards and is up to 04.11.2024.

Following are proceeding of pre-bid meeting:-

2. Pre-bid meeting was held on 14.10.2024 at 3.00 PM in 'Manthan Hall of JDA'. The meeting was attended by prospective bidders and officers of JDA as per attendance sheet (Annex-1).
3. The pre-bid meeting was started with the welcome note by Executive Engineer (PHE-II), JDA and brief introduction of the participants/officers. Thereafter the pre-bid queries were started to be made by the participants representing their organization/firm. The queries made and decisions so given are as follows which will become the part of tender document and references of sections/ paras/clauses are as per the RFP documents put to sale.

Sr. NO.	ISSUE NO.	CLAUSE NO. CHAPTER NO.	AS PER TENDER DOCUMENT	PARTICIPANT'S QUERY	Decision
Participant:-1					
1.	1	Pre-qualification criteria 2 (b), Page-43	The bidder should have completed/executed at least ONE similar work in last SEVEN financial years (including current year, if opted by the bidder) of the value minimum 50% of the	-	-

Signature valid

Digitally signed by Binayash Kumar
 Designation: Executive Engineer
 Date: 2024.10.21 17:28:23 IST
 Reason: Approve



209

Sr. NO.	ISSUE NO.	CLAUSE NO. CHAPTER NO.	AS PER TENDER DOCUMENT	PARTICIPANT'S QUERY	Decision
2.	2	Pre-qualification criteria 2 (c), Page-43	<p>estimated cost of the work (bid cost) i.e. Rs. 1708.00 Lakh updated to present price level.</p> <p>The bidder should have achieved an annual financial turnover of at least 60% of the estimated cost of the work (bid cost) in any one of last SEVEN financial years (including current year, if opted by the bidder) i.e. Rs. 2049.60 Lakh.</p>	-	-
3.		Pre-qualification criteria 2 (a), Page-43	<p>The bidder should have executed following quantities of work in last five financial year.</p> <p>However the bidder may opt current year in the said financial assessment period.</p>	<p>In the work of main trunk line at PRN South Sangner adjoining area under EE PHE-I, JDA, Jaipur vide NIT no. EE (PHE-I)/19/2023-24 dated 12.03.2024 the experience of quantities should be in last SEVEN years was mentioned by EE PHE-I, JDA, Jaipur.</p> <p>In the work of construction of remaining pipe line of SEPD at Sangner under EE PHE-I, JDA, Jaipur vide NIT no. EE (PHE-I)/16/2023-24 dated 31.01.2024 the experience of quantities should be in last SEVEN years was mentioned by EE PHE-I, JDA, Jaipur.</p>	<p>No Change.</p> <p>Financial Years of experience of quantities shall be as per Bid Document.</p> <p>But, in 2 (a), P/L/J of sewer lines 800 mm & above dia (In R. Mtr) to be read as under:-</p> <p>P/L/J of sewer lines 400 mm & above dia (In R. Mtr)</p>

Signature Valid

Since single work completed dia of is higher size with

Digitally signed by Dinesh Kumar
 Designation: Executive Engineer
 Date: 2024.10.21/11:28:23 IST
 Reason: Approved

Sr. NO.	ISSUE NO.	CLAUSE NO. CHAPTER NO.	AS PER TENDER DOCUMENT	PARTICIPANT'S QUERY	Decision
4.		BOQ item no.-15, Page no. 181	Providing and fabricating reinforcement for R.C.C. work including straightening, cutting, bending, placing in position and binding (including cost of binding wire) all complete up to floor five level. Hot rolled deformed bars (IS:1139)	4863.00 Rmt. i.e. large quantity. For healthy competition this experience also be considered in last SEVEN years & oblige us. Since hot rolled deformed bars IS:1139 is available by special order & normally not available in small quantities, this should be replaced by Thermo-mechanically treated bars (IS:1786).	No Change, As per Tender Document.
Participant:-2					
1	5	Pre-qualification criteria 2 (a), Page-43	1. P/L/J of sewer lines 800 mm & above dia (In R.Mtr).	उक्त निविदा के Criteria 2 (a) में क्रम संख्या-1 में अंकित निविदा शर्त P/L/J of Sewer Line 800 mm & above dia लगाई गई है जबकि जविग्रा की पूर्व निविदाओं में बी.ओ.क्यू. में लिए गए पाईपों का 50 प्रतिशत dia के पाईप की शर्त लगाई जाती है। (पूर्व निविदा की शर्त की कॉपी संलग्न है)। अतः उपरोक्त टेण्डर की शर्त को पूर्व शर्तों के अनुसार	It should be read as under:- 2 (a) 1. P/L/J of sewer lines 400 mm & above dia (In R. Mtr).

Signature में शर्तों के अनुसार

Digitally signed by Dinesh Kumar
Designation: Executive Engineer
Date: 2024.10.21/17:28:23 IST
Reason: Approver

211

212

Sr. NO.	ISSUE NO. CHAPTER NO.	CLAUSE NO. CHAPTER NO.	AS PER TENDER DOCUMENT	PARTICIPANT'S QUERY	Decision
<p>लगाया जावे।</p>					
<p>Participant:-3</p>					
	<p>Bid Security Deposit, Page 5.</p>	<p>Bid Security Deposit:- If a joint Venture is allowed in the Bid then 2% (Rs. 68,32,000/-) shall be deposited by bidders (Joint Venture firm)</p>	<p>Please allow BG in the name of any partner in Joint Venture.</p>	<p>It should be read as under:- Bid Security Deposit: If a joint Venture is allowed in the Bid then 2% (Rs. 68,32,000/-) in form of BG shall be deposited by bidders (Joint Venture firm) only.</p>	
	<p>Pre-qualification criteria 2 (a), Page-43</p>	<p>The bidder should have executed following quantities of work in last five financial year. However the bidder may opt current year in the said financial assessment period.</p>	<p>Please allow bidder should have executed following quantities of work in last SEVEN financial year.</p>	<p>If any one of the partners of JV wish to deposit 2 % earnest money (Bid Security) than it shall be deposited in the form of DD/any online method as per bid document.</p>	<p>No Change, As per Bid Document.</p>

Signature valid

Digitally signed by Dinesh Kumar
Designation: Executive Engineer
Date: 2024.10.21 17:28:23 IST
Reason: Approved

Sr. NO.	ISSUE NO.	CLAUSE NO. CHAPTER NO.	AS PER TENDER DOCUMENT	PARTICIPANT'S QUERY	Decision
Participant:-4					
1		Pre-qualification criteria 2 (a), Page-43	1. P/L/J of sewer lines 800 mm & above dia (In R.Mtr).	उक्त निविदा के Criteria 2 (a) में कम संख्या-1 में अंकित निविदा शर्त P/L/J of Sewer Line 800 mm & above dia लगाई गई है जबकि जविप्रा की पूर्व निविदाओं में बी.ओ.व्यू में लिए गए पाईपों का 50 प्रतिशत dia के पाईप की शर्त लगाई जाती है। (पूर्व निविदा की शर्त की कॉपी संलग्न है)। अतः उपरोक्त टेण्डर की शर्त को पूर्व टेण्डरों में निर्धारित शर्तों के अनुसार लगाया जावे।	It should be read as under:- 2 (a) 1. P/L/J of sewer lines 400 mm & above dia (In R. Mtr).

This bears the approval from competent authority

(Dinesh Kumar Kukana)
Executive Engineer (PHE-II)
JDA, Jaipur

Copy to:-

1. Director Engineering-I, JDA, Jaipur.
2. Director Finance, JDA, Jaipur.
3. Additional Chief Engineer-III, JDA, Jaipur.
4. Superintending Engineer-X, JDA, Jaipur.

Signature valid

Digitally signed by Dinesh Kumar
Designation: Executive Engineer
Date: 2024.10.21 17:28:23 IST
Reason: Approve

Executive Engineer (PHE-II)
JDA, Jaipur

213



जयपुर विकास प्राधिकरण, जयपुर

www.jda.urban.rajasthan.gov.in

214

क्रमांक:जविप्रा/अधि.अभि./पीएचई-11/2024/डी-435

दिनांक 25/10/2024

संशोधित सूचना बिड संख्या 07/2024-25

अधिशायी अभियंता (पीएचई-11), जयपुर विकास प्राधिकरण, जयपुर द्वारा जारी बिड सूचना अधि.अभि. (पीएचई-11)/07/2024-25 डी-373 दिनांक 25.09.2024 में निम्नानुसार संशोधन किया जाता है:-

1. General Condition of Contract Section-2 के Clause-45A बिन्दु संख्या-2 में निम्नानुसार संशोधन किया जाता है:-

Factor for Price Escalation

Labour (PL)	25.72 %
Cement (Pc)	1.28 %
Steel (Ps)	1.96 %
Bitumen - (Pb)	8.90 %
POL-P	15.30 %
Other materials (Pm)	46.84 %
Total	100.00 %

निविदा की शर्तों पूर्व में अपलोड निविदा प्रपत्र एवं प्री-बिड मीटिंग दिनांक 14.10.2024 में संवेदको द्वारा पूछे गये प्रश्नों के Clarification में किये गये संशोधन अनुसार रहेगी।


अधिशायी अभियंता (पीएचई-11)
जविप्रा, जयपुर

प्रतिलिपि:-

1. जन सम्पर्क अधिकारी, जविप्रा को तकनीकी सहायक (निदेशक अभियांत्रिकी-1) के मार्फत समाचार पत्र में प्रकाशन हेतु।

Job No. JDA/EE PHE-II/A & F/2024-2025/Jul/132 dt. 31.07.2024

राम किशोर व्यास भवन, इन्दिरा सर्किल, जवाहर लाल नेहरू मार्ग, जयपुर - 302004
दूरभाष : +91-141-2563234: ईपीवीएक्स - +91-141-2569696 : एक्सटें.: 5004 :
फैक्स +91-141-2574555



जयपुर विकास प्राधिकरण, जयपुर

www.jda.urban.rajasthan.gov.in

215

NO. JDA/EE (PHE-II)/2024/D-435

Dated:- 21/10/2024

CORIGENDUM TO NIT NO. 07/2024-25

25 The following corrections have been made in NIB No. EE (PHE-II)/07/2024-D-373 dated 25.09.2024

1. The General Condition of Contract Section-2 Clause-45A Point no.2 has been amended as per below table:-

Factor for Price Escalation

Labour (PL)	25.72 %
Cement (Pc)	1.28 %
Steel (Ps)	1.96 %
Bitumen - (Pb)	8.90 %
POL-P	15.30 %
Other materials (Pm)	46.84 %
Total	100.00 %

The all conditions of the tender will be as per Pre-uploaded tender document and clarification issued on questions/doubts asked by contractors presented in pre-bid meeting held on 14.10.2024.


Executive Engineer (PHE-II)
JDA, Jaipur

Copy to :-

1. PRO Cell, JDA, Jaipur through TA to DE (I) for publication in News paper.
Job No. JDA/EE PHE-II/A & F/2024-2025/Jul/132 dt. 31.07.2024

राम किशोर व्यास भवन, इन्दिरा सर्किल, जवाहर लाल नेहरू मार्ग, जयपुर - 302004
दूरभाष : +91-141-2563234: ईपीवीएक्स - +91-141-2569696 : एक्सटें.: 5004 :
फैक्स +91-141-2574555