

# JAIPUR DEVELOPMENT AUTHORITY



## Bid Document

For

Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.

**Cost : Rs. 20.00 Lacs**

**NIB No. 06/2024-25**

**Executive Engineer (PHE-I)  
Jaipur Development Authority  
Jaipur**

t ;ig fdkl ik/dj.k t ;ig

jle fl %s Qkl Hou] dejkua135] iDe&ry] eq; Hou]

bfnjkl f%z tolgj yk ug: ek%T ;ig%302004

xela t foik@vf/vfk-(ih,pb%ZA)/2024-25/D-638

fnula %18-02-2025

fufonkl puk

fufonkl puk la vf/vfk »ih,pb%ZA/06@ 2024&25

t ;ig fdkl ik/dj.k }jk "Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur." flldhvufur ykr : 20.00 yk[kdsfy, v%ykb% fm% fnula 03.03.2025 dslk;a%00 ct srd v%r dh tkhg% fufonk ds% dk v%ykb% v%ou o H%rk t foik ik% ij d%usdh v%re fr%h 03.03.2025 dslk;a%00 ct srd g% fufonk ds% n%r%os%a dk f%l%r% fojk www.sppp.rajasthan.gov.in, www.eproc.rajasthan.gov.in and [www.jda.urban.rajasthan.gov.in](http://www.jda.urban.rajasthan.gov.in) ij n%k tkldr% g%

fufonk es%k yasdsfy n%r%os%a 'n%r%dhiv%zdjuh%g%la

- 1- fufonk n%rk t ;ig fdkl ik/dj.k dh os%l%b% [www.jda.urban.rajasthan.gov.in](http://www.jda.urban.rajasthan.gov.in) ij ia%l%r% g%a,afufonk es%k yasdsfy, ds% n%rk d%sv%ou d%usdsfy, n%r%os%a 'n%r%dhiv%zdjuh%g%la' v%r j%k% v%k%v%b%l%y-ik%sa 'n%r%dhiv%zdjuh%g%la' tek%dj%h%g%la
- 2- v%ykb% fufonk iz%q d%usdsfy, fufonk n%rk%a dk j%t%l%k% l%j%k% ds% b%z%id%v% ik% [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) ij ia%l%r% g%

»fnuskde%k d%q%uk%  
vf%k%k%h%v%fk%ak%»ih,pb%ZA%  
t foik t ;ig

## JAIPUR DEVELOPMENT AUTHORITY

Room No. 135, Main Building, First Floor, Ram Kishore Vyas Bhavan, Indira Circle, JawaharLal Nehru Marg, Jaipur – 302 004

Telephone: +91-141-2569696 E.mail: [zephe1jda@yahoo.in](mailto:zephe1jda@yahoo.in)

No: - JDA/EE/PHE-I/2024-25/D-638

Dated: 18.02.2025

### NOTICE INVITING BID

NIB No. : JDA/EE (PHE-I)/06/2024-25

Online Bids are invited up-to 6.00 PM of 03.03.2025 for **“Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.”**. Estimated cost of 20.00 Lacs. The last date for Applying Bid and making online payment on JDA portal is up-to 6.00 PM of 03.03.2025 Details may be seen in the Bidding Document at our office or the State Public Procurement Portal website [www.sppp.rajasthan.gov.in](http://www.sppp.rajasthan.gov.in), [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) and [www.jda.urban.rajasthan.gov.in](http://www.jda.urban.rajasthan.gov.in).

To participate in the bid, bidder has to be:

1. Registered on JDA website [www.jda.urban.rajasthan.gov.in](http://www.jda.urban.rajasthan.gov.in), For participating in the Bid, the Bidder has to apply for the Bid and pay the Bidding Document Fee, RISL Processing Fee and Bid Security Deposit, online only.
2. Registered on e-Procurement Portal of Government of Rajasthan [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) for online e-Bid submission.

(Dinesh Kumar Kukna)  
Executive Engineer (PHE-I)  
JDA, Jaipur

**JAIPUR DEVELOPMENT AUTHORITY**

Room No. 135, Main Building, First Floor, Ram Kishore Vyas Bhavan, Indira Circle, JawaharLal Nehru Marg, Jaipur – 302 004

Telephone: +91-141-2569696 E.mail: [zepheljda@yahoo.in](mailto:zepheljda@yahoo.in)

Bid No: - JDA/EE/PHE-I/2024-25/D-638

Dated: 18.02.2025

**NOTICE INVITING BID**

NIB No. : JDA/EE(PHE-I)/06/2024-25

<b>Name &amp; Address of the Procuring Entity</b>	<ul style="list-style-type: none"> <li>➤ Name: Executive Engineer (PHE-I), Jaipur Development Authority</li> <li>Address: Room No. 135, Main Building, First Floor, Ram Kishore Vyas Bhavan, Indira Circle, JawaharLal Nehru Marg, Jaipur – 302 004</li> <li>Telephone: +91-141-2569696 E.mail: <a href="mailto:zepheljda@yahoo.in">zepheljda@yahoo.in</a></li> </ul>
<b>Subject Matter of Procurement</b>	<ul style="list-style-type: none"> <li>➤ Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&amp;M for 1 year, Jagatpura PHE-I, JDA, Jaipur.</li> <li>➤ Job No. : 306/2024-25</li> </ul>
<b>Bid Procedure</b>	<ul style="list-style-type: none"> <li>➤ Single-Stage tender (eg. Single-envelope) open competitive eBid procedure at <a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a></li> </ul>
<b>Bid Evaluation Criteria (Selection Method)</b>	<ul style="list-style-type: none"> <li>➤ L1 (eg. Least Cost Based Selection (LCBS)-L1)</li> </ul>
<b>Websites for downloading Bidding Document, Corrigendum's, Addendums, etc.</b>	<ul style="list-style-type: none"> <li>➤ Websites: <a href="http://www.sppp.rajasthan.gov.in">www.sppp.rajasthan.gov.in</a>, <a href="http://www.eproc.rajasthan.gov.in">www.eproc.rajasthan.gov.in</a>, <a href="http://www.jda.urban.rajasthan.gov.in">www.jda.urban.rajasthan.gov.in</a></li> </ul>
<b>Website for online Bid application participation and payment *</b>	<ul style="list-style-type: none"> <li>➤ Website: <a href="http://www.jda.urban.rajasthan.gov.in">www.jda.urban.rajasthan.gov.in</a></li> <li>➤ For participating in the Bid, the Bidder has to apply for this Bid and pay the Bidding Document Fee, RISL Processing Fee and Bid Security Deposit, online only. <ul style="list-style-type: none"> <li>○ Bidding document fee: Rs. 500/- (Rupees Five Hundred Only)</li> <li>○ RISL Processing Fee: Rs. 500/- (Rupees Five Hundred Only)</li> </ul> </li> <li>➤ Requisite Bid Security Deposit</li> </ul>
<b>Estimated Procurement Cost</b>	<ul style="list-style-type: none"> <li>➤ INR 20,00,659.00/- (Rupees Twenty Lacs Six Hundred Fifty Nine Rupees Only)</li> </ul>
<b>Bid Security Deposit</b>	<ul style="list-style-type: none"> <li>➤ Amount (INR) : 2% (Rs. 40,013.00/-) for A &amp; Above contractor registered in other department and 0.5% (10,003.00/-) for D &amp; above Class contractor enlisted in JDA.</li> <li>➤ Eligibility: Bidder who is A and AA class contractor registered in other Government Department and Bidder registered as contractor AA, A, B, C &amp; D in JDA.</li> </ul>
<b>Date/Time/Place of Pre-Bid</b>	<ul style="list-style-type: none"> <li>➤ NA</li> </ul>
<b>Applying Bid and making Online Payment on JDA portal (<a href="http://www.jda.urban.rajasthan.gov.in">www.jda.urban.rajasthan.gov.in</a>)</b>	<ul style="list-style-type: none"> <li>➤ Bid Start Date: 22.02.2025 at 9.30 AM</li> <li>➤ Bid End Date: 03.03.2025 at 06.00 PM</li> <li>➤ In case EMD in form BG Original Bank Guarantee is to be submitted in Room No. <u>CCC-TF-307</u> of Citizen Care Centre JDA, Jaipur by 04.03.2025 10.00 AM to 06.03.2025 up to 2.00 PM</li> </ul>
<b>Bid Submission on e-Procurement Portal of GOR</b>	<ul style="list-style-type: none"> <li>➤ Start Date: 22.02.2025 at 9.30 AM</li> <li>➤ End Date: 03.03.2025 at 06.00 PM</li> </ul>
<b>Date/Time/Place of Technical Bid Opening</b>	<ul style="list-style-type: none"> <li>➤ NA</li> </ul>
<b>Date/ Time/ Place of Financial Bid Opening</b>	<ul style="list-style-type: none"> <li>➤ 07.03.2025 at 3:00 PM</li> <li>➤ Room No. 135, Main Building, First Floor, Ram Kishore Vyas Bhavan, Indira Circle, Jawaharlal Nehru Marg, Jaipur-302 004 (Rajasthan)</li> </ul>
<b>Bid Validity</b>	<ul style="list-style-type: none"> <li>➤ 120 days from the date of opening of bid</li> </ul>
<b>Completion period of work</b>	<ul style="list-style-type: none"> <li>➤ 02 Months</li> </ul>

\* Jaipur Development Authority has decided to receive Earnest Money Deposit (EMD) (Bid Security), Tender Fee and RISL processing fee online through JDA Portal. The bid security options available in tender for participants are as mentioned below:

**A. Payment Options:**

**Option-1: Bank Guarantee (BG) against EMD / Bid Security**

Bidder may opt Bank Guarantee (BG) against EMD (Bid Security), for which bidder requires to prepare BG before applying in the tender. The details of BG requires to be fed on JDA portal before paying balance amount (Tender Fee + RISL Processing Fee). This amount will be paid through Payment Gateway only, option to make balance payment through EFT (RTGS/NEFT) will not be available.

If bidder does not opt for BG against EMD, options of making complete payment through Payment Gateway or through EFT (NEFT / RTGS) will be available.

**Option-2: Electronic Fund Transfer (EFT: NEFT/RTGS)**

If the bidder selects payment mode as EFT (NEFT/RTGS), "Paying Slip for EFT (NEFT/RTGS)" will be generated by the system for the complete amount. The payment can be made from any Bank any Branch using this Paying Slip through NEFT/RTGS (Claim against payment made through EFT in any other JDA bank account will not be acceptable and bidder stands disqualified from participation in the bid applied for). After successful transaction through NEFT/RTGS, as per the standard procedures it may take 4 to 24 hours in process of confirmation of EFT through Auto-Process depending on the time of EFT done. Therefore, option to make payment through EFT (NEFT/RTGS) will be available till 48 hours prior to closing date of bid participation.

**Option-3: Payment Gateway (Aggregator)**

The facility to make payment through Debit Card, Credit Card, Net banking etc., will be available. User can use this facility from anywhere any time till the closing date & time of bid participation.

**B. Bid Participation Receipt**

After confirming payment, the bidder will get Bid Participation Receipt on the basis of which user will get the payment details along with other details for bidding on e-Procurement portal of GOR.

- In case of BG as the remaining payment will be done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis.
- In case complete payment is done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis.
- In case complete payment is done through EFT (NEFT/RTGS), on confirmation of payment from ICICI Bank (Auto Process) "Bid Participation Receipt" will be available on Login of Bidder on JDA portal.

**Note:**

Bidder (authorised signatory) shall submit their offer on-line in Electronic formats both for technical and financial proposal.

In case, any of the bidders fails to pay the Tender Fee, BSD, and RISL Processing Fee, online (subject to confirmation), its Bid shall not be accepted.

To participate in online bidding process, Bidders must procure a Digital Signature Certificate (Type III) as per Information Technology Act-2000 using which they can digitally sign their electronic bids. Bidders can procure the same from any CCA approved certifying agency, i.e. TCS, Safecrypt, Ncode etc. Bidders who already have a valid Digital Signature Certificate (DSC) need not procure a new DSC. Also, bidders must register on <http://eproc.rajasthan.gov.in> (bidders already registered on <http://eproc.rajasthan.gov.in> before 30-09-2011 must register again).

JDA will not be responsible for delay in online submission due to any reason. For this, bidders are requested to upload the complete bid well advance in time so as to avoid 11th hour issues like slow speed; choking of web site due to heavy load or any other unforeseen problems.

Bidders are also advised to refer "Bidders Manual Kit" available at eProc website for further details about the e-Tendering process.

Training for the bidders on the usage of e-Tendering System (eProcurement) is also being arranged by DoIT&C, GoR on a regular basis. Bidders interested for training may contact e-Procurement Cell, DoIT&C for booking the training slot.

Contact No: 0141-4022688 (Help desk 10 am to 6 pm on all working days) e-mail: [eproc@rajasthan.gov.in](mailto:eproc@rajasthan.gov.in) Address : e-Procurement Cell, JDA, Yojana Bhawan, Tilak Marg, C-Scheme, Jaipur

The procuring entity reserves the complete right to cancel the bid process and reject any or all of the Bids.

No contractual obligation whatsoever shall arise from the bidding document/ bidding process unless and until a formal contract is signed and executed between the procuring entity and the successful bidder.

Procurement entity disclaims any factual/ or other errors in the bidding document (the onus is purely on the individual bidders to verify such information) and the information provided therein are intended only to help the bidders to prepare a logical bid-proposal.

The provisions of RTPPA Act 2012 and Rules 2013 thereto shall be applicable for this procurement. Furthermore, in case of any inconsistency in any of the provisions of this bidding document with the RTPP Act 2012 and Rules thereto, the later shall prevail.

**(Dinesh Kumar Kukna)**  
Executive Engineer (PHE-I)  
JDA, Jaipur

---

### Process for Participation & Depositing Payment Online

JAIPUR DEVELOPMENT AUTHORITY, has decided to receive Bidding document fee, RISL Processing Fee and Bid Security Deposit (BSD) through online mode only for which the bidder has to get registered himself on JDA portal [www.jaipurjda.org](http://www.jaipurjda.org).

#### To participate in the bid, bidder has to be:

1. Registered on JDA website [www.jaipurjda.org](http://www.jaipurjda.org) (by depositing Rs. 500.00 online, the validity of which remains 3 (three) years).  
For participating in the Bid, the Bidder has to apply for this Bid and pay the Bid Document Fee, RISL Processing Fee and Bid Security Deposit, online only.
2. Registered on e-Procurement Portal of Government of Rajasthan [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) for online e-Bid submission.

#### Methods for depositing on line amount

- Online through Internet Banking, Debit Card or Credit Card.
- In case the amount exceeds the online payment limit, the payment may be made through RTGS / NEFT / Transfer in Bank Account Number **675401700586** IFSC Code **ICIC0006754** of ICICI BANK Limited, JDA Campus  
Jaipur.

In case of RTGS / NEFT / Transfer the bidder is required to deposit the requisite amount in the dedicated bank account number as mentioned above and has to get the UTR / Reference number from the bank. This number requires to be updated while applying the bid on JDA portal.

While participation in the bid, a receipt will be generated through the system showing the submission details as per **Annexure-4**. The bidder is required to fill the instrument numbers for various heads on e-Procurement portal [www.eproc.rajasthan.gov.in](http://www.eproc.rajasthan.gov.in) as mentioned in the receipt.

More details about Registration Process, Terms and Conditions and FAQ along with contact detail is available on JDA website [www.jaipurjda.org](http://www.jaipurjda.org) under [eServices](#)>>JDA Tender

# **Section A-1**

## **Instructions to Bidders**

# JAIPUR DEVELOPMENT AUTHORITY JAIPUR

## SCHEDULE AND SPECIFICATIONS

**Name of work:- "Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur."**

- |                                     |   |
|-------------------------------------|---|
| 1. NIB No.                          | : - E.E.(PHE-I)/06/2024-25  |
| 2. Bid cost                         | : - Rs. 20.00 Lacs  |
| 3. Cost of the tender documents     | : - Rs 500/-  |
| 4. Earnest Money                    | : - Amount (INR) : 2% (Rs. 40,013.00/-) for A & Above contractor registered in other department and 0.5% (10,003.00/-) for D & Above Class contractor enlisted in JDA.<br>Eligibility: Bidder who is A and AA class contractor registered in other Government Department and Bidder registered as contractor AA, A, B, C & D in JDA |
| 5. Bid Submission Start date & Time | : - 22.02.2025 (9:30 AM)  |
| 6. Bid Submission End date & Time   | : - 03.03.2025 (upto 6:00 P.M.)   |
| 7. Bid Opening date & Time          | : - 07.03.2025 at 03:00 P.M.  |
| 8. Completion period of work        | : - 02 Months   |

### SCHEDULE 'A' : INFORMATION USEFUL FOR THE CONTRACTORS :

The tenderer should see the site and fully understand the condition of the site before tendering and include all lead, lifts etc. **Percentage above/Below on the rates as given in the 'G'-Schedule.** The work shall be carried out in accordance with the Rajasthan PWD, PHED and JDA detailed specification and to the entire satisfaction of the Engineer-In charge of the work.

**The bid will be opened only of those bidders deposit proper bid security, processing fee, tender fee, GST registration, clearance certificate and copy of registration of contractor in required category are found to be in order. The Bid security, tender fee will be accepted through online payment only.**

### SCHEDULE 'B' : LIST OF THE DRAWING TO BE SUPPLIED BY THE DEPARTMENT:

The drawings may also be seen in the office of undersigned.

### SCHEDULE 'C' : LIST OF THE DRAWING TO BE SUPPLIED BY THE CONTRACTOR:

List of the drawing to be supplied by the contractor NIL. But the contractor shall have to arrange at his own cost drawings required for the work after depositing necessary cost within JDA.

### SCHEDULE 'D' : TEST OF THE MATERIALS :

The test of the material and workmanship shall be conducted by the JDA staff as necessary, The result of such tests should confirm to the standard laid down in the Indian standards and or the standards laid down in the detailed specification of the Public Works Deptt,. Proper quality control is required to be maintained by the contractor. Qualified personnel as required under the contractor enlistments rules duly approved by the Deptt.

shall have to be engaged at site by the contractor. The deptt. reserves the right to engage such staff and recover the expenses from the contractor on such account in case of his failure to do so.

**SCHEDULE 'E' : SAMPLES OF THE MATERIALS :**

The samples of the material to be used by the contractor shall be deposited 15 days in advance with the Engineer In charge and be got approved by him before use.

**SCHEDULE 'F' : TIME OF COMPLETION :**

The work should start within Ten days of issue of work order and complete within **02** months.

**SCHEDULE 'H' :** Special condition Attached separately.

- 1. In case of single bid system Annexure "B" enclosed by the bidder regarding qualification of RTPP Act 2012 & Rule 2013 along with bid document, should be signed by the participating bidder before uploading the tender document otherwise the bid of the bidder will be rejected.**
- 2. After dated 31.12.2022 contractor cannot participate in bid without Review Registration.**

**Annexure A : Compliance with the code of Integrity and No Conflict of Interest**

**Annexure B : Declaration by the Bidder regarding Qualifications**

**Annexure C : Grievance Redressal during Procurement Process**

**Annexure D : Additional Conditions of Contract**

**Annexure E : DLP period for various type of works. Office order D-29 dated 11.03.2016**

**Annexure F : Payment mechanism for participating in tender: Office order D-399 dated 04.10.2016.**

**Annexure G : GST Circular for participating in tender: Office order D-172 dated 12.07.2017.**

**Annexure H : Finance (G&T) department, notification dated 22.10.2021**

**Annexure I : JDA Order D-75 dated 26.08.2021**

**Annexure J : Finance (G&T) department, notification dated 12.01.2022**

**Annexure K : JDA Office Order No. JDA/EE & (TA to Dir. Engg.-I)/2022/D-194 dated 06.09.2022**

**SIGNATURE OF CONTRACTOR**

**Executive Engineer (PHE-I)  
Jaipur Development Authority,  
Jaipur**

**with full address & Mobile No. :**

## TENDER FOR WORKS

I/We hereby tender for the execution for the Jaipur Development Authority, Jaipur of the work specified in the underwritten memorandum within the time specified in such memorandum at the rates, (in figure) .....% (as well as in words) ..... Percent below/above the amount, entered in the schedule G in all respects in accordance with the specifications, designs, drawings and instructions in writing referred to in Rule I in all respects in accordance conditions with such conditions so far as applicable. I/We have visited the site of work and am/are fully aware of all the difficulties and conditions likely to affect carrying out the work, I/We have fully acquainted myself/ourselves about the conditions in regard to accessibility of site and quarries/kilns nature and the extent of ground, working conditions including stacking, of materials, installation of tools & plant, conditions effecting accommodation and movement of labour etc. required for the satisfactory execution of contract.

### Memorandum

- (a) **General description of work..-** : **Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.**
- (b) **Estimated cost** : **Rs. 20.00 Lacs**
- (c) **Earnest money** : Amount (INR) : 2% (Rs. 40,013.00/-) for A & Above contractor registered in other department and 0.5% (10,003.00/-) for D & above Class contractor enlisted in JDA.  
Eligibility: Bidder who is A and AA class contractor registered in other Government Department and Bidder registered as contractor AA, A, B, C & D in JDA
- (d) **Security Deposit :**
- (i) "The security deposit @ 10% of the gross amount of the running bill shall be deducted from each running bill and shall be refunded as per rules on completion of the contract as per terms and conditions. However, the amount of security deposit deducted from running bills shall not be converted into any mode of securities like bank guarantee. FDR etc. The earned money deposited shall however be adjusted while deducting security deposit from first running bill of the contractor. There will be no maximum limit of security deposit.  
However, a contractor may elect to deposit of full amount of 10% security deposit in the shape of bank guarantee or any acceptable form of security before or at the time of executing agreement. In that case earnest money may be refunded only after deposition of full 10% as above. However, in case during execution cost of works exceeds as shown at the time of depositing 10% as above, balance security deposit shall be deducted from the Running Account Bills."
- (ii) Bank Guarantee shall in all cases be payable at the headquarter of the Division or the nearest District Headquarters.
- (e) Time allowed for the completion of work (to be reckoned from the 10th day after the date of written order to commence the work) in **02 months**. Should this tender be accepted in whole or in Part, I/We hereby agree to abide by and fulfill all the terms and provisions of the conditions of contract annexed here to and of the Notice Inviting Tender, or in default thereof, to forfeit and pay to the Governor of Rajasthan or his successors in office, the sum of money mentioned in the said conditions.

### **Validity of rates 120 days.**

A sum of Rs. .... is forwarded herewith in the form of Cash, Bank Draft, Bankers Cheque as Earnest Money. This amount of earnest money shall absolutely be forfeited to the Governor of Rajasthan or his successor in office without prejudice to any other right or remedies of Governor of Rajasthan or his successor in his office, should I/We fail to commence the work specified in the above memorandum.

Signature of Witness  
Witness's address & Occupation

Signature of Contractor  
Address of Contractor

Date:

The above tender is hereby accepted by me on behalf of the Governor of Rajasthan

Date:

Executive Engineer (PHE-I)

## **Section A-2**

# **General Conditions of Contract**

(Appendix XI of PWF & AR. Govt. of Rajasthan  
effective up to date shall be applicable)

# **Section A-3**

## **Scope of work & Special Conditions of Contract**

**SCHEDULE 'I'**

**Name of work:- Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.**

**Scope of work:-**

The scope of work under this Contract includes Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.

**SPECIAL CONDITIONS OF THE CONTRACT (Part-A)****CONTRACT****1.1 Type of Contract**

**THE WORK DESCRIBED IN THIS TENDER DOCUMENTS CONSIST OF TWO PARTS;**

<b>PART "A"</b>	NON BSR Items.
<b>PART "B"</b>	BSR Items.
<b>PART "C"</b>	O&M

**1.2 Priority of contract**

The documents forming part of the agreement are to be taken as mutually explanatory documents of one another. In case of discrepancies they shall be explained and adjusted by the Engineer In Charge. The priority of the Contract documents shall be as follows:

1. Letter of award
2. Special Conditions of Contract Part A & Part B

**Instructions to Bidders**

3. General Conditions of Contract
4. Work description/ Scope of works
5. Technical specifications
6. Drawings
7. Bill of quantities

**Design And Drawings****2.1 General Design Obligations**

The Contractor shall be deemed to have scrutinized, prior to submission of bid, the JDA Requirements (including design criteria and calculations, if any). The Contractor shall be responsible for the design of the following works and for the accuracy of such designs-

**3. COMPLETION OF THE WORK****3.1 Time for completion**

The whole of the work, including mobilization, reconnaissance, construction, installation, testing, commissioning and trial runs, and demobilization has to be completed within a period of **02 months** calculated from the commencement date, which is 10 days after the written order to commence the Work.

**3.2 Completion of work and fully commissioning**

Once the entire system has been successfully tested and commissioned, and removal of all visible defects to the satisfaction of Engineer In Charge-in-Charge, the work shall be treated as **"Completed"**.

Unless otherwise provided in the contract, after the successful completion Engineer In Charge shall issue a certificate of "Completion of Work". The date of Certificate notifying "Completion of Work" will be used for the final payment as per clause 6 and 7 of General Conditions of Contract.

**8. Refund of Performance Guarantee & Security Deposit**

**The Security Deposit (SD) and Performance Guarantee (PG) shall be refunded after successfully completion for defect liability period as per JDA DLP norms.**

- 8.1 The contractor/firm or company while executing the above work will adopt all safety measures on his cost to safeguard from any loss of life & damage of public & private property. if any loss & damage occurred then they will pay the full compensation from their own pocket. all the consequence will be born by them & JDA will not be responsible in any way.
- 8.2 The contractor/firm or company will display necessary signboards & lights from safety point of view during nights at site of work on his own cost as directed by the authorized Engineer In Charge.
- 8.3 The contractor shall not work after the sunset & before sunrise without specific permission of the Engineer In Charge in-charge.

- 8.4 Contractor shall provide sufficient number of boards at site of work indicating 'JDA AT WORK" at his own cost as required by Engineer In Charge-In Charge.
- 8.5 The contractor will pay compensation to the house owner or to the owner of any adjoining property or any other works for the damaged sustained on account of this work while in progress or complete from his own pocket.

**9. Price Variation Clause:**

**No Price Escalation shall be payable in work.**

## SPECIAL CONDITIONS OF THE CONTRACT

1. Contractor shall get the D.I. pipe inspected from the third party (CEIL, SGS, RITES) before bringing the material at site. The inspection charges shall be born by the contractor. No payment of these items shall be made before the third party inspection.
2. In case of pipe line testing shall be done as per the relevant Code and the leakage level shall not be more than as per IS 8329. Only 80% of the payment shall be released after providing, laying and jointing of pipes and special in trenches, 20% of the payment shall be released after testing as above.
3. The quantity of work can be increased or decreased. However, no guarantee is given about the actual quantity of work.
4. No extra payment shall be made to the contractor on account of excavation in collapsible strata or in hard or rocky strata. The tenderers shall have to make their own arrangement for completing the work and no claim in this respect will entertained.
5. On collection of complete material for each section the same shall be got checked by Engineer-in-Charge or his authorized representative. Such approval shall in no way release the contractor of his responsibility regarding completion of work, as per required specification until the contract is complete.
6. The electric connection, if required, for construction and testing purpose shall be arranged by the contractor at his own cost.
7. The contractor shall make his own arrangement regarding water required for the execution and testing of the work and shall also arrange for the supply of drinking water to his own employees. He shall defray all charges in this connection and should include in his rates a sufficient amount to cover such charges. All such facilities as are required now to be provided for the labour, made under labour welfare rules enforce, shall also be provided by the contractor at his own cost.
8. The contractor will be required to see that the usual hours of work are adhered too. No work shall be done after the sun set without the permission of the engineer-in-charge.
9. The contractor/firm or company while executing the work will adopt all safety measures at his cost to safeguard from any loss of life and damage of public and private property. If any loss and damage is occurred, they will pay the full compensation from their own pocket to the concern. All the consequence (legal and or financial) will be born by the contractor only and JDA will not be responsible in any way.
10. Water for construction / testing purpose shall have to arrange by contractor at his own cost. If water is supplied by the department, the same shall be recovered from the contractor from each running bill at the rate of 1% of total value of pipe line laying work, In case of metered connection the charges shall be recovered on the actual consumption basis on the commercial rates.
11. The contractor shall be fully responsible for structural safety and water tightness of pipeline when tested.
12. No secured advance against material procured at site will be allowed.
13. Pipeline laying should be done in the presence an Engineer not below the rank of Junior Engineer of the JDA, and trench shall be refilled after checking of Assistant engineer. After taking layout, the contractor shall submit day to day schedule of work to the Engineer-in-charge in advance.
14. The contractor/firm or company will take utmost care to safeguard the water mains, Electric and Telephone cable existing surface drains water connections etc., while executing the work. Any damages/rectification shall be born by the contractor only
15. The contractor shall, at his own cost, arrange to provide, erect and maintain necessary display boards/ flags/banners etc. at selection points of project site giving such information as considered necessary for public awareness/ information/ safety as directed by the Engineer-in-charge.
16. Contractor shall provide sufficient number of boards at site of work indicating "JDA AT WORK" at his own cost as required by Engineer-in-charge.
17. The surplus earth and damaged materials will be immediately removed from the site of work and dumped as per instruction of Engineer-in-charge.
18. The material collected at site and paid provisionally shall remain under the watch and ward of the contractor till it is consumed fully on the work.
19. Any material not conforming to the specifications collected at site shall have to be removed by the contractor within a period of 3 days of the instructions, issued by the Engineer-in-charge, failing which, such material shall be removed by the Engineer-in-charge at risk and the contractor after expiry of 3 days period.
20. The contractor/firm/company is bound to get the workmen insured against accident from the Insurance Company at his own cost.
21. Contractor shall be the sole custodian of the men and material at work and will be fully responsible for any loss of life or otherwise occurred during the execution of the works.
22. The Engineer – in – Charge or his authorized representative will carry out as and when considered necessary for the quantity and quality of work done and for the materials used in the work. The contractor, unless otherwise specified shall provide all facilities and arrangements to undertake these tests and all testing charges shall be borne by the contractor.
23. The contractor shall supply required quantity of samples desired by executive engineer, the samples so obtained shall be sent to authorized laboratory for testing, if the material is not found according to the specifications the entire lot of supply will also be rejected. The entire cost of samples and testing shall be borne by the contractor.

**24. Defects Liability period**

The defect liability period shall be as per JDA office order no. JDA/Ex.En. (TA to Dir. Eng.-1)/2016/D-29 dated 11.03.16 (Annexure 'E').

**25. As Built Drawings.**

The submission of the As-built drawings of the water line work is the precondition for the final payment. The final drawings shall be submitted in one reproducible set and 3 copies on linen bound in an album of an approved size. The contractor shall submit all the completion drawings. The scale of drawing and the size of drawing shall be as per the direction of the Engineer in Charge.

26. The contractor shall be solely responsible for all kind of liaison before starting the work with PHED/Other JDA zone/JVVNL & BSNL etc. which is required to avoid any damage of already laid pipe lines, Electric, BSNL cables. The contractor shall also liaison for the inter connection work with existing PHED system.
27. Before start of work contractor has to inform concerned JDA zone officers to avoid/minimize road damage
28. If there is any typographical error or otherwise in the 'G' Schedule. The nomenclature and the rates as given in the relevant BSR and JDA approved items/rates on which schedule 'G' is based, shall prevail.
29. O&M of mud pump and DI line (whole system) will be carried out by the contractor. Charges shall be payable by the society itself.

**The above conditions may be read very carefully and adhered strictly.**

**I/we confirm above**

**Signature of contractor**

**Executive Engineer (PHE-I)  
JDA, Jaipur**

## **Section A-4**

# **Specifications of Work**

**SUPPLY OF DI / HDPE PIPES, SPECIALS, VALVES AND LAYING OF PIPES FOR WATER SUPPLY****General****Standards**

Except as otherwise specified in this technical specification, the Indian/International Standards and Codes of Practice in their latest version shall be adhered to for the design, manufacturing, inspection, factory testing, packing, handling and transportation of product. Should any product be offered conforming to other standards, the equipment or products shall be equal to or superior to those specified and the documentary confirmation shall be submitted for the prior approval of the Engineer in Charge.

**This specification requires a reference to the following standard specifications**

IS: 4985	Unplasticized PVC pipes for potable water supplies
IS: 10151	PVC and its copolymers for its safe use in contact with foodstuffs, pharmaceuticals, and drinking water
IS: 10500	Drinking water specification
IS: 12235	Methods of test for unplasticized PVC pipes for potable water supplies
IS: 4669	Methods of test for PVC resin
IS: 12818	Unplasticized PVC screen and casing pipes for bore/tube well
IS: 3400	Methods of test for vulcanized rubber (part-1 to 22)
IS: 1387	General requirements for the supply of metallurgical material
IS: 210	Grey iron casting
IS: 1536	Centrifugally cast (spun) iron pressure pipe for water, gas and sewage
IS: 1537	Vertically cast iron pressure pipe for water, gas and sewage
IS: 1538	Cast iron fittings for pressure pipes for water, gas and sewage
IS: 5531	CI specials for Asbestos cement pressure pipes for water gas & sewage
IS: 1363	Hexagon head bolts, screws and nuts of product grade A and B (part:1-5)
IS: 1367	Technical supply conditions for threaded steel fasteners
IS: 780	Sluice valve for water works purposes
IS: 2906	Specifications for sluice valves for water works purposes
IS: 318	Leaded tin bronze ingots and casting
IS: 8543	Methods of testing plastics: Determination of density of solid plastics
IS: 7181	Horizontally cast iron double flanged pipes for water, gas and sewage.
IS: 8794	CI detachable joints for use with Asbestos cement pressure pipes
IS: 5382	Rubber sealing rings for gas mains, water mains and sewers
IS: 5531	Cast iron specials for asbestos cement pressure pipes for water, gas and sewage
IS: 779	Water meters
IS: 3624	Pressure and vacuum gauges
IS: 341	Black japan, types A, B and C
IS: 9862	Ready mixed paint, brushing, bituminous, black, lead free, acid, alkali, water and chlorine resisting
IS: 1239	Mild steel tubes, tubular and other wrought steel fittings
IS: 7328	High density polyethylene materials for moulding and extrusion
IS: 4984	Specification for high density polyethylene pipes for potable water supplies; sewage and industrial effluents
IS: 554	Dimensions for pipe threads where pressure tight joints are required on the threads
IS: 1592	Asbestos cement pressure pipes – Specifications
IS: 778	Specifications for copper alloy gate, globe and check valves for water works purposes
IS: 12820	Dimensional requirements for rubber gaskets for mechanical joints and push on joint for use with cast iron pipes and fittings for carrying water, gas and sewage.
IS: 9523	Specification for DI fittings for pressure pipes for water, gas, and sewage.
ISO: 2045	Single socket for uPVC and uPVC pressure pipes with elastic sealing ring type joints - Minimum depth of engagement
ISO: 2507	PVC pipes and fittings- Vicat softening temperature - Test method and specification
ISO: 3603	Fittings for PVC pipe with elastic sealing ring joints pressure test for leak profanes
ISO: 1167	Thermoplastics pipes for the transport of fluids - Resistance to internal pressure - Test method and basic specification
ISO 3451-5	Determination of Ash: Part-5 - Poly vinyl chloride
ASTM: D 2152	Standard test method for degree of fusion of extruded PVC pipe and moulded fittings by Acetone immersion
MTNL	Mahanagar Telephone Nigam Limited; Technical specifications for cable ducts.
BS: 4772	Specification for DI fittings
IS: 7634- Parts 1-3	Code of practice for plastic pipe works for potable water supplies
IS: 8329	Centrifugally cast (spun) ductile iron pressure pipes for water, gas and sewage.
IS: 12288	Code of practice for use and laying of ductile iron pipes
CPHEEO Manual on Water Supply and Treatment, III edition, Ministry of Urban Development, New Delhi- May 1999.	

## Ductile Iron Pipe:-

The pipes will be centrifugally cast (spun) Ductile Iron pipes for Water confirming to the IS 8329: 2000. The pipes used will be either with push on joints (Rubber Gasket Joints) or Flanged joints. The class of pipe to be used shall be of the class K-7 / Double Flange K-9.

The pipes shall be coated with bitumen as per appendix C and have factory provided cement mortar lining in the inside as per the provisions of Appendix B of the IS 8329: 2000.

The pipes will be supplied in standard length of 5.50 and 6.00 meters length with suitably rounded or chamfered ends. Each pipe of the push on joint variety will also be supplied with a rubber EPDM gasket. Any change in the stipulated lengths will be approved by the Engineer – in charge. The gaskets will confirm to the IS 5382:1985.

The gaskets should also be supplied by the manufacturer of the pipes. They should preferably be manufactured by the manufacturer of the pipes. In case they are not, it will be the responsibility of the manufacturer of the pipes to have them manufactured from a suitable manufacturer under its own supervision and have it tested at his/sub-contractors premises as per the contract. The pipe manufacturer will however be responsible for the compatibility and quality of the products.

The flanged joints will confirm to the Clause 6.2 of IS 8329. The pipe supply will also include one rubber gaskets for each flange.

### Inspection and Testing:

The pipes will be subjected to following tests for acceptance:

Visual and dimensional check as per Clause 13 and 15 of IS 8329

Mechanical Test as per Clause 10 of IS 8329

Hydrostatic Test as per Clause 11 of IS 8329

The test reports for the rubber gaskets shall be as per acceptance tests of the IS 5832 and will be in accordance to Clause 3.8

The sampling shall be as per the provisions of the IS 8329

### Marking

All pipes will be marked as per Clause 18 of IS 8329 and show as below:

Manufacturer name/ stamp

Nominal diameter

Class reference

A white ring line showing length of insertion at spigot end

### Packing and Transport:

The pipes should be preferably transported by road from the factory and stored as per the manufacturer specifications to protect damage.

### Specials for Ductile Iron Pipes

#### General

This section covers the general requirements for Ductile Iron (DI) fittings suitable for Tyton joints to be used with Ductile Iron pipes with flanged and Tyton jointing system.

#### Types of specials

The following types of DI fittings shall be manufactured and tested in accordance with IS: 9523 or BS: 4772.

flanged socket

flanged spigot

Double socket bends (900, 450, 22 1/2 0, 11 1/4 0)

Double socket branch flanged tee

All socket tee.

Double socket taper.

All Flanged Tee.

All Flanged taper.

### Supply

All the DI fittings shall be supplied with one rubber ring for each socket. The rubber ring shall conform to IS: 12820 and IS: 5382 as described in the preceding chapter. Flanged fittings shall be supplied with one rubber gasket per flange and the required number of nuts and bolts.

### General

This section covers the requirements for lubricant for the assembly of Ductile Iron pipes and specials suitable for Tyton push-in rubber ring joints

### Specification

The lubricant has to have the following characteristics:

must have a paste like consistency and be ready for use

has to adhere to wet and dry surfaces of DI pipes and rubber rings

to be applied in hot and cold weather; ambient temperature 0 - 50 °C, temperature of exposed pipes up to 70 °C

must be non toxic

must be water-soluble

must not affect the properties of the drinking water carried in the pipes

must not have an objectionable odour

has to inhibit bacterial growth

must not be harmful to the skin

must have a shelf live not less than 2 years

**Acceptance tests**

They shall be conducted in line with the provisions of the IS 9523

**Packing**

All the DI fittings shall be properly packed with jute cloth. Rubber rings shall be packed in polyethylene bags. Rubber rings in PE bags and nuts, bolts etc. shall be supplied in separate jute bags.

The fittings should also be supplied by the manufacturer of the pipes. They should preferably be manufactured by the manufacturer of the pipes. In case they are not, it will be the responsibility of the manufacturer of the pipes to have them manufactured from a suitable manufacturer under its own supervision and have it tested at his/sub contractors premises as per the contract. The pipe manufacturer will however be responsible for the compatibility and quality of the products.

**Laying and jointing of DI pipes**

Pipes should be lowered into the trench with tackle suitable for the weight of pipes. For smaller sizes, up to 200 mm nominal bore, the pipe may be lowered by the use of ropes but for heavier pipes suitable mechanical equipment have to be used.

All construction debris should be cleared from the inside of the pipe either before or just after a joint is made. This is done by passing a pull-through in the pipe, or by hand, depending on the size of the pipe. All persons should vacate any section of trench into which the pipe is being lowered

On gradients of 1:15 or steeper, precautions should be taken to ensure that the spigot of the pipe being laid does not move into or out of the socket of the laid pipe during the jointing operations. As soon as the joint assembly has been completed, the pipe should be held firmly in position while the trench is back filled over the barrel of the pipe.

The designed anchorage shall be provided to resist the thrusts developed by internal pressure at bends, tees, etc.

Where a pipeline crosses a watercourse, the design and method of construction should take into account the characteristics of the watercourse to ascertain the nature of bed, scour levels, maximum velocities, high flood levels, seasonal variation, etc. which affect the design and laying of pipeline.

The assembly of the pipes shall be made as recommended by the pipe manufacturer and using the suitable tools.

The socket and spigot ends of the pipes shall be brushed and cleaned. The chamfered surface and the end of the spigot end have to be coated with a suitable lubricant recommended by the manufacturer of the pipes. Oil, petroleum bound oils, grease or other material which may damage the rubber gasket shall not be used as lubricant. The rubber gasket shall be inserted into the cleaned groove of the socket. It has to be checked for correct positioning.

The two pipes shall be aligned properly in the pipe trench and the spigot end shall be pushed axially into the socket either manually or with a suitable tool specially designed for the assembly of pipes and as recommended by the manufacturer. The spigot has to be inserted up to the insertion mark on the pipe spigot. After insertion, the correct position of the socket has to be tested with a feeler blade

Deflection of the pipes -if any- shall be made only after they have fully been assembled. The deflection shall not exceed 75 % of the values indicated by the pipe manufacturer.

**Anchoring of the pipeline**

Thrust blocks shall be provided at each bend, tee, taper, end piece to prevent undue movements of the pipeline under pressure. They shall be constructed as per design of ENGINEER- IN- CHARGE according to the highest pressure during operation or testing of the pipes, the safe bearing pressure of the surrounding soil and the friction coefficient of the soil.

**Leakage Test**

After laying and jointing the pipeline shall be tested for tightness of barrels and joints, and stability of thrust blocks in sections approved by the Engineer in Charge. The length of the sections depends on the topographical conditions. Preferably the pipeline stretches to be tested shall be between two chambers (air valve, scour valve, bifurcation, other chamber). At the beginning, the Contractor shall test stretches not exceeding 2 km. After successful organization and execution of tests the length may be extended to more than 2 km after approval of the Engineer in Charge.

The water required for testing shall be arranged by the contractor himself. The Contractor shall fill the pipe and compensate the leakage during testing. The Contractor shall provide and maintain all requisite facilities, instruments, etc. for the field testing of the pipelines. The testing of the pipelines generally consists in three phases: preparation, pre-test/saturation and test immediately following the pre-test. Generally, the following steps are required which shall be monitored and recorded in a test protocol if required

The testing conditions for the pipelines are summarized as follows:

Maximum hydrostatic test pressure for DI K-7 / Double Flange K-9 pipes shall be 2.0 times of maximum design pressure in the pipeline.

Pre test and saturation period with addition of make-up water

Pressure:	Test pressure
Duration:	3 hrs for DI pipes without cement mortar lining / 24 hrs for DI pipes with cement mortar lining

Pressure test with addition of make-up water

Pressure:	Test pressure
Duration:	3 hrs

Test criteria for DI pipes: Q = 1 liter per km per 10mm of pipe per 30 m test pressure per 24 hrs.

All pressure testing at site should be carried out hydrostatically. The pipes shall be accepted to have passed the

pressure test satisfactorily, if the quantity of water required to restore the test pressure as per the latest codal provisions does not exceed the amount 'Q', calculated by the above formula.

If it is required to test a section of a pipeline with a free end, it is necessary to provide temporary support against the considerable end thrust developed by the application of the test pressure. The end support can be provided by inserting a wooden beam or similar strong material in a short trench excavated at right angle to the main trench and inserting suitable packing between the support and pipe end.

The pipeline stretch will pass the test if the water added during the test period is not exceeding the admissible limits. No section of the pipe work shall be accepted by the Engineer in charge until all requirements of the test have been obtained.

On completion of a satisfactory test any temporary anchor blocks shall be broken out and stop ends removed. Backfilling of the pipeline shall be completed.

#### **Failure to pass the test**

All pipes or joints which are proved to be in any way defective shall be replaced or remade and re-tested as often as may be necessary until a satisfactory test shall have been obtained. Any work, which fails or is proved by test to be unsatisfactory in any way, shall be redone by the Contractor.

#### **Flushing and disinfecting of pipelines**

After testing and commissioning the contractor shall flush the pipes with a velocity not less than 1 m/s or as approved by the Engineer in Charge. Disinfection of drinking water pipelines shall be made by engineer- in charge.

#### **Supply of Ductile Iron Pipes:-**

The Contractor will have to supply DI pipes manufactured by manufacturer who has been in business of supply of DI pipes rubber ring jointed and have proven record of successful supply and testing of pipeline for minimum one year.

### **Specifications for Laying and Jointing of Pipe Line System for Water Supply**

#### **Preparatory work**

The contractor will inspect the route along which the pipe line is proposed to be laid. He should observe/ find out the existing underground utilities/ construction and propose an alignment along which the pipeline is to be laid. He should make all efforts to keep the pipe as straight as possible with the help of ranging rods. Wherever there is need for deviation, it should be done with the use of necessary specials or by deflection in pipe joints (limited to 75% of permissible deflection as per manufacturer). The alignment as proposed should be marked on ground with a line of white chalk and got approved from Engineer In-Charge. The Contractor will then prepare an L-Section along this alignment showing the location of proposed pipeline. The L-section should be got approved from the site Engineer. The position of fittings, valves, should be shown on the plan.

#### **Alignment and the L-Sections**

The alignments, L-section (depth of laying) and location of specials, valves and chambers may be changed at site in co-operation with and after approval of the Engineer in Charge. The minimum cover to the top of the pipe shall be 1 m.

#### **Standards**

Except as otherwise specified in this technical specification, the Indian Standards and Codes of Practice in their latest version, National Building code, PWD specification of the state of Rajasthan and Manual of water supply of GOI shall be adhered to for the supply, handling, laying, installation, and site testing of all material and works.

#### **Tools and equipment**

The contractor has to provide all the tools and equipment required for the timely, efficient and professional implementation of the work as specified in the various sections of the contract and as specified by the instructions of manufacturers of the pipes and other material to be handled under this contract. On demand he shall provide to the Engineer in Charge a detailed list of tools and equipment available. If in the opinion of the Engineer in Charge the progress or the quality of the work cannot be guaranteed by the available quantity and type of tools and equipment the contractor has to provide additional ones to the satisfaction of the Engineer in Charge. The Contractor will always have a leveling instrument on site.

#### **Handling and laying of pipes**

##### ***Transportation of pipes and specials & Storage:-***

The Contractor has to transport the pipes and other materials from manufacturer to the site of laying as indicated by the Engineer in Charge. Pipes should be handled with care to avoid damage to the surface and the socket and spigot ends, deformation or bending. Pipes shall not be dragged along the ground or the loading bed of a vehicle. Pipes shall be transported on flat bed vehicles/trailers. The bed shall be smooth and free from any sharp objects. The pipes shall rest uniformly on the vehicle bed in their entire length during transportation. Pipes shall be loaded and un-loaded manually or by suitable mechanical means without causing any damage to the stacked pipes.

The transportation and handling of pipes shall be made as per IS 12288. Handling instructions of the manufacturers of the pipes shall be followed. All precautions set out shall be taken to prevent damage to the protective coating, damage of the jointing surfaces or the ends of the pipes.

Whatever method and means of transportation is used, it is essential that the pipes are carefully placed and firmly secured against uncontrolled movement during transportation to the satisfaction of engineer in charge.

Cranes or chain pulley block or other suitable handling and lifting equipment shall be used for loading and un-loading of heavy pipes. However, for pipes up to 400 mm nominal bore, skid timbers and ropes may be used. Where using crane hooks at sockets and spigot ends hooks shall be broad and protected by rubber or similar material, in order to avoid damage to pipe ends and lining. Damage to lining must be repaired before pipe laying according to the instructions of the pipe manufacturer. Pipes shall not be thrown directly on the ground or inside the trench.

When using mechanical handling equipment, it is necessary to employ sufficient personnel to carry out the operation efficiently with safety. The pipes should be lifted smoothly without any jerking motion and pipe movement should be controlled by the use of guide ropes in order to prevent damage caused by pipes bumping together or against surrounding objects.

Rolling or dragging pipes along the ground or over other pipes already stacked shall be avoided.

The pipe should be given adequate support at all times. Pipe should be stored on a reasonably flat surface free from stones and sharp projections so that the pipe is supported throughout its length. In storage, pipe racks should provide continuous support and sharp corners of metal racks should be avoided. Socket and Spigot pipes should be stacked in layer with sockets placed in alternate ends of the stack to avoid lop sided stacks.

Pipes should not be stored inside another pipe. On no account the pipes should be stored in stressed or bent condition or near the sources of heat. Pipes should not be stacked more than 1.5 m high and pipes of different sizes and classes should be stacked separately. The ends of the pipes should be protected from abrasion. The pipes should be protected from U.V. rays and excessive heat at all times. Their storage facility should be well ventilated.

The Contractor shall provide proper and adequate storage facilities to protect all the materials and equipment's against damage from any cause whatsoever and in case of any such damage/theft, the Contractor shall be held responsible.

The contractor will lay the pipelines along the alignments as per the layout given by the Engineer in Charge. The layout shall be given keeping in view the information available regarding existing services like water lines, sewers, telephone and electric lines/ cables. In the event some services fall in the alignment of lines to be laid, the contractor shall have to shift such services for which a provision has been made in the BOQ. The contractor shall take all due care to avoid damage to any such services and, in case of any damage occurring to them in progressing the work, the Contractor shall make good the same at his own cost. No additional time shall, however, be allowed on this account.

#### *Stringing of pipes along the alignment*

The pipes shall be laid out properly along the proposed alignment in a manner that they do not create any significant hindrance to the public and that they are not damaged.

Stringing of the pipe end to end along the working width should be done in such a manner that the least interference is caused in the land crossed. Gaps should be left at intervals to permit the passing of equipment across the working area. Pipes shall be laid out that they remain safe where placed and that no damage can occur to the pipes and the coating until incorporated in the pipeline. If necessary, pipes shall be wedged to prevent accidental movement. Precautions shall be made to prevent excessive soil, mud etc. entering the pipe.

Generally, the pipes shall be laid within two weeks from the date of their dispatch from the manufacturer /store .

### **Pipe trench**

#### *Trench excavation*

The trench excavation of pipeline shall be in accordance with IS 12288. Pipe trenches shall be excavated to the lines and levels shown on the drawings or as directed by the Engineer in Charge. The depth of the excavated trench shall be as given in the drawings or as directed by the Engineer in Charge. The width of the trench at bottom between the faces of sheeting shall be such as to provide 200 mm clearance on either side of the Diameter. No pipe shall be laid in a trench until the section of trench in which the pipe is to be laid has been approved by the Engineer in Charge.

The depth should be sufficient to provide a cover not less than 1000 mm. It may be necessary to increase the depth of pipeline to avoid land drains or in the vicinity of roads, railways or other crossings. Care should be taken to avoid the spoil bank causing an accumulation of rainwater.

The bottom of the trench shall be trimmed and leveled to permit even bedding of the pipes. It should be free from all extraneous matter, which may damage the pipe or the pipe coating. Additional excavation shall be made at the joints of the pipes, so that the pipe is supported along its entire length.

All excavated material shall be stacked in such a distance from the trench edge that it will not endanger the work or workmen and it will avoid obstructing footpaths, roads and driveways. Hydrants under pressure, surface boxes, fire or other utility controls shall be left unobstructed and accessible during the construction work. Gutters shall be kept clear or other satisfactory provisions made for street drainage, and natural watercourses shall not be obstructed.

To protect persons from injury and to avoid damage to property, adequate barricades, construction signs, torches, red lanterns and guards, as required, shall be placed and maintained during the progress of the work and until it is safe for traffic to use the roadways. All materials, piles equipment and pipes which may serve as obstruction to traffic shall be enclosed by fences or barricades and shall be protected by illuminating proper lights when the visibility is poor.

As far as possible, the pipe line shall be laid below existing services, like water and gas pipes, cables, cable ducts and drains but not below sewers, which are usually laid at greater depth. Where it is unavoidable, pipeline should be suitably protected. A minimum clearance of 150 mm shall be provided between the pipeline and such other services.

Trees, shrubbery fences, poles, and all other property and surface structures shall be protected. Tree roots shall be cut within a distance of 50 cm from pipe joints in order to prevent roots from entering them. Temporary support, adequate protection and maintenance of all underground and surface structures, drains, sewers and other obstructions encountered in the progress of the work shall be provided. The structures, which will be disturbed, shall be restored after completion of the work.

Where water forms or accumulates in any trench the Contractor shall maintain the trench free of water during pipe laying.

Wherever necessary to prevent caving, trench excavations in soils such as sand, gravel and sandy soil shall be adequately sheeted and braced. Where sheeting and bracing are used, the net trench width after sheeting shall not be less than that specified above. The sides of the excavation shall be adequately supported at all times and, except where described as permitted under the Contract, shall be not battered.

The Engineer in Charge in co-operation with the Contractor shall decide about the sheeting/ bracing of the trench according to the soil conditions in a particular stretch and taking into account the safety requirements of the Contractor's and Engineer-In-Charge's staff. Generally, safety measures against caving have to be provided for trenches with vertical walls if they are deeper than 2.0 m.

#### *Trench excavation to commensurate with the laying progress*

The work of trench excavation should be commensurate with laying and jointing of the pipeline. It should not be dug in advance for a length greater than 500 m ahead of work of laying and jointing of pipeline unless otherwise permitted by the Engineer in Charge. The Contractor has to ensure the following:

- safety protections as mentioned above have to be incorporated in the work process
- hindrances to the public have to be minimized
- the trench must not be eroded before the pipes are laid
- the trench must not be filled with water when the pipes are laid
- the trench must not be refilled before laying of the pipes

The bed for the laying of the pipes has to be prepared according to the L-Section immediately before laying of the pipes.

#### *Bedding of the pipes*

The trench bottom shall be even compact and smooth so as to provide a proper support for the pipe over its entire length, and shall be free from stones, lumps, roots and other hard objects that may injure the pipe or coating. Holes shall be dug in the trench bottom to accommodate sockets so as to ensure continuous contact between the trench and the entire pipe barrel between socket holes.

### **Laying and jointing of pipes**

#### *General*

The pipes will be cleaned in the whole length with special care of the spigot and sockets on the inside/ outside to ensure that they are free from dirt and unwarranted projections. The whole of the pipes shall be placed in position singly and shall be laid true to profile and direction of slope indicated on longitudinal sections. The pipes shall be laid without deflection in a straight alignment between bends and between high and low points. Vertical and horizontal deflections between individual pipes need the approval of the Engineer in Charge. In no case the deflection shall be more than 75 % of those recommended by the manufacturer.

Before pipes are jointed they shall be thoroughly cleaned of all earth lumps, stones, or any other objects that may have entered the interior of the pipes, particularly the spigot end and the socket including the groove for the rubber ring.

Pipes and the related specials shall be laid according to the instructions of the manufacturers and using the tools recommended by them.

Cutting of pipes shall be reduced to a minimum required to conform to the drawings. Cutting has to be made with suitable tools and according to the recommendations of the manufacturer. The spigot end has to be chamfered again at the same angle as the original chamfered end. Cutting shall be perpendicular to the Centre line of the pipe. In case of ductile iron pipes the cut and chamfered end shall be painted with two coats of epoxy paint. If there is no mark for the insertion depth on the spigot end of the (cut) pipe it shall be marked again according to the instructions of the manufacturer.

Before pipes are jointed they shall be thoroughly cleaned of all earth lumps, stones, or any other objects that may have entered the interior of the pipes, particularly the spigot end and the socket including the groove for the rubber ring. End caps are removed only just before laying and jointing

All specials like bends, tees etc. and appurtenances like sluice or butterfly valves etc. shall be laid in synchronization with the pipes. The Contractor has to ensure that the specials and accessories are ready in time to be installed together with the pipes.

At the end of each working day and whenever work is interrupted for any period of time, the free ends of laid pipes shall be protected against the entry of dirt or other foreign matter by means of approved plugs or end caps.

When pipe laying is not in progress, the open ends of installed pipe shall be closed by approved means to prevent entrance of trench water and dirt into the line.

No pipe shall be laid in wet trench conditions that preclude proper bedding, or when, in the opinion of the Engineer in Charge, the trench conditions or the weather are unsuitable for proper installation.

The pipeline laid should be absolutely straight unless planned otherwise. The accuracy of alignment should be tested before starting refilling with the help of stretching a string between two ends of the straight stretch of pipes to rectify possible small kinks in laying.

### **Special Cast Iron fittings and Accessories**

Normally when pipeline is laid, a certain number of cast iron fittings such as tees, bends, reducers, etc, and special fittings such as air or sluice valves are required.

**Laying of Fittings** – All cast iron fittings shall be plain ended to suit the outside diameter of Asbestos cement pressure pipes and to the class and diameter of pipe manufactured. When using such cast iron fittings, they are jointed by cast iron detachable joints only. For cast iron specials having flanges, they are jointed in the pipeline with cast iron flange adaptors having one end flanged and the other plain ended.

**Anchorage** - It should particularly be noted that the cast iron joints do not hold pipe ends within it firmly. During working or test pressure, there will be tendency for the pipe ends or special ends to slip out of the joint, more so with the case of blank end cap used for closure of pipeline and all degree bends and tees. In order to keep them firmly in the pipeline, anchoring of these specials are necessary against the direction of thrust.

The anchorage shall consist of either concrete cast-in-situ or masonry built in cement mortar. The anchors shall be extended to the firm soil of the trench side. The shape of the anchors will depend on the kind of specials used. They shall be spread full width of trench and carried vertically by the side and over the special to about 15 cm. The bearing area on sides of the trench will be proportional to the thrust and to bearing capacity of the sides of the trench.

### **Back filling and tamping**

The soil under the pipe and coupling shall be tamped in order to provide a firm and continuous support or the pipeline.

Tamping shall be done either by tamping bars or by using water to consolidate the back fill material.

The initial back fill material used shall be free of large stones and dry lumps. In stony areas the material for initial back fill can be shaved from the sides of the trenches. In bogs and marshes, the excavated material is usually little more than vegetable matter and this should not be used for bedding purposes. In such cases, gravel or crushed stone shall be hauled in.

The initial back fill shall be placed evenly in a layer of about 100 mm thick. This shall be properly

Consolidated and this shall be continued till there is a cushion of at least 300 mm of cover over the pipe.

If it is desired to observe the joint or coupling during the testing of mains they shall be left exposed.

Sufficient back fill shall be placed on the pipe to resist the movement due to pressure while testing.

Balance of the back fill need not be so carefully selected as the initial material. However, care shall be taken to avoid back filling with large stones, which might damage the pipe when spaded into the trench.

Pipes in trenches on a slope shall have extra attention to make certain that the newly placed back fill will not become a blind drain in effect because until back fill becomes completely consolidated, there is a tendency for ground or surface water to move along this looser soil resulting in a loss of support to the pipe. In such cases, the back fill should be tamped with extra care and the tamping continued in 100 mm layers right up to the ground level.

#### **Anchoring of the pipeline**

Thrust blocks shall be provided at each bend, tee, taper, end piece to prevent undue movements of the pipeline under pressure. They shall be constructed as per actual design and approval of Engineer in Charge according to the highest pressure during operation or testing of the pipes, the safe bearing pressure of the surrounding soil and the friction coefficient of the soil.

#### **Testing of the upvc pipelines**

**Sectional tests:-** After laying and jointing the pipeline shall be tested for tightness of barrels and joints, and stability of thrust blocks in sections approved by the Engineer in Charge as per IS Code.

## Specification of Works

### 1. Sluice Valves

Sluice valve on the delivery line of the pumps shall be electrically operated with a provision of manual operation through suitable gear box arrangement and handle, so as to ensure required effort at hand wheel periphery as 80N maximum. It shall conform to provisions of IS 14846. All tests shall be carried out as per these standards.

Valve Gate Position Indicator

Valves shall have two position marked at the shut end of the scale, first one corresponding to the position of the gate tangential to the bore of the seating and the second position below the first, corresponding to the position of the gate as it sits on the seating after moving a further distance equal to the depth of the seating.

Materials of Construction

(1) Body, Door, Dome, Wedge : For PN 1.0 - CI IS 210 Gr. FG 200 (all sizes)

*For PN 1.6 - CI IS 210 Gr. FG 260 (up to 800mm) and SG IS 1865 Gr 500/7 (900 to 1200mm)*

(2) Hand Wheel : Cast Iron IS 210 Gr FG 200  
 (3) Stem : Stainless Steel AISI 410/431  
 (4) Seat, Door Ring : SS 410/CA 15  
 (5) Shoe Channel & Wedge Nut : Stainless Steel AISI 410  
 (6) Back seat Bush : Halprene on SS 410  
 (7) Drain and air plug : Stainless Steel AISI 410  
 (8) Gland Packing : Hemp (greased)  
 (9) Gasket : Neoprene  
 (10) Rivets : Soft annealed SS

The material of construction, in general, shall conform to relevant IS standard.

#### NOTE:

1. All CI & SG Iron must have 2% Nickel and 0.5% Chromium.
2. No Gunmetal or Bronze parts are to be used inside the valve.

List of accessories/optional features to be furnished and accessories as approved by the Engineer-in-Charge to be supplied. The approved QAP for sluice valve in other project is enclosed in the tender document..

### 2. Double Ball Air Valve

#### General

- 1) *The valve shall be capable of exhausting air from pipe work automatically when been filled. Air being released at a sufficiently higher rate to prevent the restriction of the Inflow rate. Similarly the valve shall be capable of ventilating pipe work automatically when being emptied. The air inflow rate being sufficiently high to prevent the development of a vacuum in pipeline. The valve shall automatically release air accumulating in pipe line work during normal working condition.*
- 2) *For double ball air valve, Air valve shall be of double orifice type with a large orifice for ventilation for exhaust of the pipeline and small orifice for release of air under working pressure. The valve shall be suitable for maximum working pressure in the system. All double ball air valves shall be provided with isolating sluice valve and flanged end connection.*
- 3) *Air valve shall be design to prevent premature closure prior to all air having been discharge from the line. The orifice shall be positively sealed in the close position but float (Ball) shall only be raised by the liquid and not by mixer of air and liquid. The sealing shall be design to prevent the floats striking after long period in the close position.*
- 4) *All branched outlets including outlets for Air valves will be with compensation pads (Dia of Main / For branch Dia ratio greater than 3). Diameter of compensation pad will not be less than 1.75 times the O.D. of the branched outlet. Plate thickness for pads will be same as that of the main.*
- 5) *For outlets with above ratio less than three, then the joints will be of plate reinforcement type.*
- 6) *The aperture of valves must be properly designed for which the contractor shall submit design calculations for necessary approvals before the procurement of valves.*
- 7) *The air valve should be as per IS: 14845*
- 8) *All branched outlets including air valve tee's will be provided with one ½" BSP coupling duly plugged for measurement of pressure in due course. The closing plug will be in Stainless Steel (AISI 304 or equivalent) with Hex. Head. and will be provided with copper washer for sealing.*
- 9) *All flanges will be drilled as per I.S. 1538.*
- 10) *The gaskets shall be of nitrile rubber.*

#### Material of Construction

(1) Body : CI IS 210 Gr FG 260  
 (2) High Pressure Orifice & Plug : St. Steel AISI 410

- |     |  |   |   |
|-----|--|---|---|
| (3) | Low Pressure Ball  | : | Stainless steel float                         |
| (4) | High Pressure Ball   | : | Stainless steel float.                        |
| (5) | Low Pressure Seat Ring   | : | Dexine (Nitrile Rubber)                       |
| (6) | Sluice Valve   | : | Isolating Sluice Valve conforming to IS 14846 |
| (7) | Spindle  | : | Stainless steel                               |
| (8) | Bolts & Nuts   | : | MS  |
| (9) | The Isolating Sluice valve shall be as relevant IS/as per manufacturer's recommendations |   |   |

### Fixing

The work of fixing appurtenances, i.e. sluice valves, air valves, scour valves, etc. shall be carried out carefully so as not to damage them during handling, erection and fixing. The work shall be executed in a workmanlike manner under the direction Engineer-in-Charge.

### 3. Spring Loaded Dual Plate Check Valve

#### General

- 1) The valve shall be of flanged type suitable for mounting on a horizontal pipeline.
- 2) Valves shall possess high speed closing characteristics and be designed for minimum slam condition when closing.
- 3) Dual plate check valves conform to API 594 and API 598. They shall have resilient sealing. The spring action shall optimize the equal closing rates of each plate especially when the friction coefficients are uneven due to one plate resting upon one another. The plates shall not drag on the seat while opening. The plates shall not vibrate under full or partial flow condition.
- 4) The minimum body-wall thickness shall conform to those given in Table 1B of API Standard 594.
- 5) The face-to-face dimensions of valves (including valves with ring-joint facings) shall conform to those mentioned in Table 2B of API Standard 594.
- 6) The valve body shall be furnished with a clearly visible cast, forged, machined-in, or die-stamped arrow to indicate the direction of flow through the valve.

#### Constructional Features

Double Flanged quick closing non slam spring loaded dual plate generally conforming to API 594 for pressure rating as per requirement at particular section of size equivalent to the delivery pipe shall be provided with following material of construction:

#### Materials of Construction

(a)	Rating	As per requirement at particular section
(b)	Body	CI to IS 210 Gr FG 260
(c)	Plate	ASTM, A 216 Gr WCB
(d)	Hinge Pin /Stop Pin	SS. AISI 431
(e)	Springs	SS. AISI 316
(f)	Body & Plate Seat	13% Chromium overlay.
(g)	Seal	EPDM
(h)	Retainer	Carbon Steel
(i)	Body Bearing	SS AISC 316
(j)	Plate Bearing	SS AISC 316

#### Nut, Bolts, Washers

The jointing material such as nuts, bolts, washers, pig lead, rubber packing, etc. shall be provided by the Contractor.

Nuts and bolts shall be of the best quality bright steel, machined on the shank and under the head and nut. Studs, bolts and nuts shall be galvanized. Bolts shall be of accurate length so that only one thread shall show through the nut in the fully tightened conditions. Nuts and bolts shall conform to IS 1363 and IS 1367.

Washers, locking devices and anti-vibration arrangements shall be provided where necessary.

Where there is a risk of corrosion, bolts, nuts and studs shall be designed so that the maximum stress does not exceed half the yield stress of the material under any conditions. All bolts, nuts and screws that are subject to frequent adjustment or removal in the course of maintenance and repair shall be made of nickel bearing stainless steel.

The Contractor shall supply all holding down, alignment leveling bolts complete with anchorages, nuts washers and packing required to fix the plant to its foundations, bed plates, frames and other structural parts.

The Contractor shall procure and keep at site, reasonable excess quantities to cover wastage of those materials, which will be normally subject to waste during erection, commissioning and setting to work.

Throughout erection, the valves shall be supported properly on wooden sleepers, etc and shall be concreted immediately thereafter, as directed. Before the valves are actually fixed, they shall be cleaned and greased and it should be seen that all parts are in perfect working condition. In the case of air valves, the Contractor shall take special care of the dexine joints and the ebonite and /or vulcanite balls until they are fixed in position. They shall be kept immersed in water in suitable containers.

**4. Specifications of Mono block pumps/ Centrifugal Coupled Pump Sets**

The mono block pumps shall conform to the requirements of the required head and flow as given above. The construction features of the pump shall conform to IS 9079.

**Accessories and services required to be supplied by the Bidder with pump.**

The bidder is supposed to provide at least the following accessories

- Base Plate
- Foundation Bolts
- Coupling, if required
- Coupling guard, if required

**Drawings and information to be provided**

During detailed engineering the Bidder shall submit the following:

- General arrangement, cross-sectional and dimensional drawings/data pertaining to selected model.
- Complete detailed drawing of the base plate
- Complete performance curve with (for pumps of BHP more than 50 HP)
- H - Q curves.
- Test reports, performance curves and other particulars, as required by the applicable clauses of this specification.
- Instruction Manuals:
- Instruction manual for Erection
- Instruction for pre-commissioning check up, operation, abnormal conditions, maintenance and repair

**Delivery & Suction Pipes – Design considerations**

- The sizes of manifold pipes shall be as mentioned in the scope of work.
- All in house pipes shall be of MS as per IS 3589-2000. However the minimum thickness shall be as per IS 3589-1991 or as per design or 6.35 mm whichever is more.
- All the in house piping shall be provided with internal food grade epoxy painting and external enamel painting as approved by EIC.
- Pipes shall be welded with companion flanges of respective valves and dismantling joints etc.
- The suction and delivery pipes shown in the conceptual drawings clear water pumping stations are tentative. However the contractor shall check the same so as to limit the velocity of flow in respective pipes, below 2 m/sec. The velocity in the delivery pipes shall not exceed 1.8 m/s. The velocity in the suction pipe shall not exceed 1.0 m/s. The velocity in suction manifold shall not exceed 0.6 m/s. These velocities shall correspond to the ultimate demand of 2031.

**5. Specifications of Submersible Mono block pumps Sets for Lifting water:-**

- Submersible Mono block pump set conforming to IS 8034 and 02 pole motor operating at synchronized speed of speed 3000 RPM, with water proof winding.
- Pump shall be suitable for various delivery head and discharge with stainless steel shaft.
- Motor suitable for working on 415 V  $\pm$  10%, 3 Ph, 50 Hz AC and with water lubricated bearing to accept entire hydraulic thrust.
- Supply, with cable guard, thrust carbon/fiber bearing to withstand entire hydraulic thrust.
- The pump set shall be suitable for direct coupling, with suitable suction strainer.
- Pump should have suitable discharge out let as per manufacturer's design.
- Anti-thrust stream lined non return valve shall be provided with the pump and minimum 6 mm submersible copper conductor cable in single / double run and 2 pairs of suitable size erection clamp 10 mm thick shall be provided with each pump etc. complete in all respect as per specification, scope of work and direction of Engineer in Charge of following power rating, suitable for prescribed duty conditions.

**6. SPECIFICATIONS FOR PUMPING STATIONS (ELECTRICAL)****General**

It is not the intent to specify herein all the details pertaining to the design, drawing, selection of equipment/materials, procurement, manufacture, installation, testing & commissioning, however, the same shall be of high standard of engineering and shall comply with all currently applicable standards, regulations & safety codes. These specifications cover the equipment to be installed in switchgear, cables etc. along with the specifications for workmanship, laying cables, earthing systems, lightning protection etc.

It shall be the responsibility of the Bidder to design the electrical system based on the selection of the mechanical equipment. The work will be executed as per the detailed designs and drawings approved during execution.

Wherever the electrical equipment and system has to be connected with the Instrumentation system, the details of the connectivity of the electrical system/equipment with the Instrumentation system has to be worked out by the bidder to be commensurate with the requirement of the Instrumentation system to be provided, Irrespective of the provisions

given in these specifications for electrical equipment/works, in this chapter. The bidder shall provide all necessary accessories with the equipment dealt herein or additional equipment required for effective functioning of the electrical and Instrumentation systems.

The pre-dispatch inspection and pre-commissioning testing and commissioning details are provided in Chapters of Specifications for Pre-dispatch inspection and Specifications for Testing, Commissioning and Trial run respectively. The specifications of material and workmanship of all civil works and lighting fixtures shall be in compliance with the specifications given in the chapter for "Specifications for Civil Works".

The brief technical specifications of the various electrical equipments are given in subsequent clauses comprising the following:

- Applicable Indian Standards
- Other considerations (if any)
- Technical parameters supplied by the department
- Drawings and documents for review/approval

The various systems covering the installation practices are described separately.

The scope of the Bidder shall cover design and drawing of electrical systems, selection of the equipment/materials, procurement, expediting, inspection, packing and forwarding, delivery at site, erection, testing, commissioning, obtaining the statutory approvals, handing over the complete plant etc.

### Power Supply Information

The proposed power supplies are as follows:

(i)	415V AC System	Voltage variation +10 to -15% Freq. Variation +3 to -5%	Three Phase and neutral, 50 Hz, effectively earthed system, SC. rating of 50 kA
(ii)	240V AC System	Voltage variation + 10% to -15 % Freq. Variation + 3% to - 5%	Single phase and neutral, 50 Hz, effectively earthed system

The ambient temperature for design of the electrical equipment shall be 50° C.

### Fault Levels

The fault levels of the proposed units in the substation / pump house shall be as per IS: 2026 as follows:

415 system : 20 MVA

### Design Considerations

#### General

The electrical installations proposed under the contract are for the project requirement. Wherever found necessary, the installations shall be done considering the likely extension of the system/system component for integration with the future extensions.

#### Motor Control center

Main panel as per requirement on head work as per the requirement enclosed in vol III of tender document..

incoming Air Circuit Breaker / MCCB of required capacity as per SLD diagram of pump house.

Ammeter with ASS, Voltmeter with VSS, Multifunction meter with Port for interfacing with PLC, indicating lights

Out going Starter, Soft Starter with MCCB & Moter duty MCB ,KWH meter having port for PLC- interface, Motor protection relay with Over load, phase loss, Locked roter, stalling protections, local & remote start stop buttons, on off-trip indications, Auto / manual selector

APFC Panel with 12 stage microprocessor based relay, SFU, Contactor, Auto manual selector, indicating lamps

Fixed capacitor for Transformer at all pumping stations

#### Auxiliary panel

Reversible starter for actuators as per requirement.

Lighting Risings for internal & out door lights through MCB

Starter for dewatering pump

DP MCB for control supply of Flow, pressure, level sensors

Spare Rising 63A TPN -4 nos.

#### Rising for chlorinator

#### DRAWING AND DOCUMENTS REQUIRED

- GA drawing for operating mechanism.
- Schematic and wiring diagram.
- GA drawing of supporting structures with foundation details.
- Instruction manual for installation, operation and maintenance

#### METAL ENCLOSED LT SWITCHGEAR

#### STANDARDS

		Description
1.	IS 4237	Switchgear general requirements.
2.	IS 5578	Guide for making of insulated conductors

3.	IS 8623	Factory built assemblies of Sw Gr & Cont. Gr (for voltages < 650 V).
4.	IS 2147	Degree of protection of enclosure for LV switchgear and control gear.
5.	IS 1248	Electrical Indicating Instruments.
6.	IS 722	Integrating AC electric meters.
7.	IS 2705	Current transformers.
8.	IS 3156	Voltage transformers.
9.	S 10118	Installation and maintenance of switchgear.
10.	S 11353	Guide for uniform system of marking and identification of conductor and equipment terminals.
11.	S 13947	Specification for low voltage switchgear and control gear

### OTHER CONSIDERATIONS

This section is applicable for all 415V switchboard panels

- Motor Control center/Auxiliary panel

The switchboard panel shall be made out of sheet steel in compartmentalized design and shall be suitable for bottom cable entry. The horizontal bus bar chamber shall be on the top whereas vertical busbars shall be provided in bus alley at the front. The minimum clearance on the back and sides of each switchboard panel shall be >1000 mm <200mm and on the front side the same shall be 2500 mm.

At least 2 spare bays of adequate rating will be kept in the panel for additional circuits in future.

1	Sheet Steel Thickness Enclosure and Doors Partitions and covers Gland Plate Base Frame	2.0 mm CRCA 1.6 mm CRCA 3 mm HR Sheet min 3 mm HR Sheet
2	Degree of Protection	IP 52
3	Surface Finish	Powder coating
4	Shade (Interior & Exterior)	Light Grey, Shade : 631 ( IS : 5 )
5	PVC Heat shrink Sleeve	Black sleeve with coloured tape for R/Y/B
6	Control Connections for PT and other connections For CT circuits	1.5 mm <sup>2</sup> stranded Copper wire 2.5 mm <sup>2</sup> stranded Copper wire
7	Gasket for Doors	Neoprene Gasket shall be provided to make Panel dust & vermin proof, conforming to degree of protection IP 52.
8	Earth bus	Earth bus suitable for fault level of panel shall be provided throughout the length of panels. The horizontal earth bus shall project out of the panel at bottom and shall have at-least two holes for earth connections.
9	Door closing arrangement Cable lugs	All power switches shall be door interlocked Cu cable lugs for copper cables shall be fitted.
10	Cable glands	Double compression brass cable glands shall be provided.
11	Operating Height	Operating switches, push buttons and handles shall not be placed below 300 mm and above 2000 mm
12	Cubicle illumination	Shall be provided
13	Live connections	Live connections from Bus Bar up to switches shall be shrouded in order to avoid accidental touch.

### TECHNICAL PARAMETERS FOR MOTOR CONTROL PANELS

a)	TPN busbar details	High Conductivity Al grade E91E for TPN bare busbar, size shall be suitable for continuous current rating as per the detailed design.
b)	Min. clearance	Phase to phase - 25 mm & Phase to earth - 20 mm
c)	Power freq. Withstand	2.5 kV RMS, 50 Hz for one minute
d)	Short Circuit Current	25 kA (RMS) for 1 second
e)	Max. temp. of bus bar	70 °C
f)	CT details	Cast resin / bar primary type, 5 A CT CT ratio, burden and class shall be as per the maximum current expected at the point of installation in the circuit, indicative CT ratio and burden are shown in respective SLD
g)	MCB details	Rating shall be as per the maximum current expected on that circuit. MCB will be current limiting feature
h)	Contactors details	Rating shall be as per the requirement of the motors Duty shall be as per application

i)	Relays	Motor protection relay shall have over load , phase loss, Locked roter, stalling protections.
j)	Motor control supply	415/230 V, AC
k)	Selector switch details	AS for Ammeter with R, Y, B, OFF positions. VS for Voltmeter with RY, YB, BR, OFF positions
l)	Indicating Meter details	Moving iron type, 90 <sup>o</sup> scale, for AM & VM, Suppressed scale in case of AM for motors AM dial range to suit CT primary current. VM dial range 0-600 volt. Size 96 mm <sup>2</sup> Accuracy Class 1.0
m)	Multi-function meter	Shall have built in ammeter, voltmeter, kW meter, kVA meter, PF meter, kWh meter, kVAH meter
n)	Integrating Meter details	Electronic/Train gear type, calibrated for required CT-PT ratio Accuracy Class 1.0, for other details refer drawings
o)	Push button details	Momentary type, 2 NO & 2 NC contacts of 10 A at 240 V AC spare No, NC to be provide
p)	Indicating lamp details	LED type with series resistance,
q)	Control fuse details	HRC cartridge type with base & carrier. Contactor to select rating.
r)	Changeover switch	2 position, on load type
s)	Miscellaneous details	1. Control terminals shall be of 10 A, 1100 V grade, clip on type with din rail mounting. 2. CT terminals shall be provided with shorting link and earthing facility 3. Control wiring - marked with ferrule Nos. at both ends.

## SOFT STARTERS

### Specifications:

The Soft Starter shall be suitable to operate on AC 415 V (+ 10 % / - 15 %) 50 C / S +3% 3 Phase, 6 wire system and at an ambient temperature of 50 deg C.

Soft Start, Soft Stop adjustable current limit features.

Integrated micro Processor based overload relay with adjustable trip class 10/15/20. Overload relay shall remain active when soft starter is in by pass mode. Proper indications shall be there for on-off trip position optional free contracts shall be there for logic requirement for on-off trip.

Current rating of Soft Starter shall be considered on 50 deg temperature and it shall be 30 % higher then full load current of motor.

Panel Cooling fans shall be provided for soft starters Rising.

The Soft Starter shall have 1-120 second adjustment range for soft start and stop at site adjustment compatibility, kick start to over ride soft start for high torque and kick start and stop time selectable options. Soft stop control through selectable step down and end voltage level during stop ramp to prevent water hammering.

Power connection by Six wire connection with motor.

**Protections:** The Soft Starter should have following protections

Over Load Protection with trip class 10/20/30 A site selectable. Dual over load relay to select different trip class during start and normal run, Motor over temperature, Starter over temperature, Phase imbalance, Phase sequence, instantaneous high current, Under load, Motor connection, Phase loss, frequency fault, Shorted or open SCR, Soft Starter PCB fault, Communication failure and Reverse rotation.

**Warnings:** The Soft Starter should have provision for following warnings before tripping, Motor Over load warning, Thyristor over load warning and high current warning.

#### Operator

**Interface:** Digital key pad with LCD screen for at least 20 segment display, Local push button for start, Stop and reset, RYB Phase Start, Stop, Trip LED indications, Start Stop two programmable inputs, motor thermistor PTC input for monitoring motor temperature and protection, three programmable relay inputs, Motor current settings as – 30 % to 115%, flexible communication option as Modbus / Profibus / Devicenet / ASI.

## PROTECTION RELAY (EMPR) SPECIFICATION

Motor Protection Relay should be Micro-processor based having following protection with DIN Rail mounting through auxiliary supply 240 Volt AC supply

1. Thermal overload should have class 10,10A,20,30 to match the Characteristic of Motor.
2. Earth Fault protection 10% to 50% with difin ate time less then 300 mili sec.

3.Negative sequence 40% for 3 sec. mainly for singlr phasing protection.

4.Locked Rotor 3 Im for 1 sec.

5.Under current 0.5 Im for 3 sec.

6.Current unbalance.

The relay should have the facility to bye pass lock rotot and under current protection.

The relay should have the Power On LED and having the separate LED for faults indication means for under current ,lock rotor,earth fault,negative sequence & overload.

The relay should have inbuilt CBCT.

The rely should have following current settings.

1 A to 2.75 A, 2 A to 5.5 A, 4 A to 11 A, 8 A to 22 A, 16 A to 44 A, 32 A to 88 A

MAKE- L&T/SIEMENS/AREVA

## Capacitors

### LT CAPACITORS

#### Standards

Standard	Description
IS 2834	Power factor improvement capacitors

#### Other considerations

The Contractor shall check with manufacturer regarding providing of inductor coil.

The Contractor shall work out the automatic power factor control (APFC) scheme to achieve a power factor of 0.92. The power factor improving capacitor requirement shall be as per the power factor of the equipment selected by the Contractor.

#### Technical parameters

a)	Quantity and output	The quantity and output must be designed as per the requirement of load to achieve the objective.
b)	Power factor control	Through APFC / CAPACITORS
c)	Capacitor type	MPP
d)	Rated voltage and frequency	415 Volts 3 phase (line to line), 50 Hz
e)	Maximum over voltage the unit capacitor is capable of withstanding continuously	105 %

#### Drawing and documents required

- GA drawing of the capacitor unit, bank
- Instruction manual for installation, operation and maintenance for capacitor

## Cables

### HT/LT CABLES

#### Standards

No.	Standard	Description
1.	IS 1554	PVC insulated electric Cables.
2.	IS 8130	Conductors for insulated electric cables.
3.	IS 5831	PVC insulation and sheath of electric cables.
4.	IS 3975	Mild steel wires, strips and tapes for armouring of cables.
5.	IS 1753	Aluminium conductors for insulated cables.
6.	IS 7098	LT/HT XLPE cables

#### Other Considerations

Power cable shall be of Al conductor, whereas control and lighting cables shall be of Cu conductor. The minimum size of Al conductor cable shall be 4 mm<sup>2</sup> and Cu conductor cable of 2.5 mm<sup>2</sup>.

Power cable sizing shall be based on the various de-rating factors recommended by cable manufacturer, rated current, temperature rise of conductor and voltage drop.

Control cables of CTs shall be based on the VA burden of CT and relays, meters.

#### Technical parameters

LT Cables	PVC insulated, taped PVC inner sheath and outer sheath 650/1100 V grade, with multi-stranded aluminium/copper conductor, armoured						
Cable selection	Cable shall be selected considering following points Current rating of the load De-rating due to grouping of cables0. Voltage drop up to 3% in cable due to cable resistance De-rating factor due to ambient temperature. DE-RATING DUE TO DEPTH IN CASE OF BURIED CABLES						
Spare cores for control cables	Up to 4 cores - nil						
	5 cores	to	9 cores	-	1	core	
	10 cores	to	20 cores	-	2	core	
	21 cores	to	30 cores	-	3	core	

More than 30 cores - 4 core

**Drawing and documents required**

- Cable catalogue

**Lighting Fixtures****STANDARDS**

No.	Standard	Description
1.	IS 1913	General & Safety requirements for electric lighting fittings.
2.	IS 1777	Industrial lighting fittings with metal reflector
3	IS 5077	Decorative lighting outfits
4.	IS 2149	Luminaries for street lighting
5.	IS 6665	Code of practice for Industrial Lighting

**OTHER CONSIDERATIONS**

In order to have higher illumination for maintenance and repairs in the pump room area outlets of 16 A SPN shall be provided for the connection of portable lamps. 16 A SPN switch with socket shall be provided in every bay of the pump house on the suction and delivery sidewalls. The flexible lighting fixture shall be suitable for GLS lamps.

The bidder shall design the lighting system and get approval of the design along with related drawings and specifications for the fixtures proposed for lighting.

**Cabling System****INSTALLATION**

The cables shall be laid in trenches, trays or conduits or buried in ground. Cable routings shall be checked at site to avoid interference with structures, piping and ducting. All cables shall be carefully measured and cut to the required length, leaving sufficient length for final connections to the equipment on both ends.

The Bidder shall ascertain the exact requirement of cable, for a particular Rising, by measuring at site along the actual finalised route.

Cables shall be laid in complete uncut lengths from one item of equipment to another.

Cables shall be neatly arranged in the trenches, trays in such a manner that criss-crossing is avoided and final take off to the motor, switchgear is facilitated. LT Cables shall be laid a maximum two layers in each tray for cables up to 3-½ C x 95 mm<sup>2</sup>.

Arrangement of cables within the trench, tray shall be the responsibility of the Bidder.

Power and control cables shall be laid on different trays in one trench. 1.1 kV grade cable may be laid on one tray.

All cables shall be identified close to their termination point by cable numbers. Cable numbers will be punched on aluminium straps, (2 mm thick), securely fastened to the cable and wrapped around it.

Underground cables shall be provided with cable markers. These cable marker posts shall be located at every 50 metres and every corner or change of direction.

All temporary ends of cables shall be protected against dust and moisture to prevent damage to the insulation. While laying cables, the ends shall be taped with PVC tape.

Cables shall be handled carefully during installation to prevent mechanical injury to the cables. Ends of cables leaving trenches shall be coiled and provided with protective cover until the final termination to the equipment is completed.

Directly buried cable shall be laid underground in excavated cable trenches wherever required. The trenches shall be suitably designed for accommodating all the cables. Before cables are placed, the trench bottom shall be filled with a layer of sand. This sand shall be levelled and cables laid over it. The cable shall be covered with 150 mm of sand over the top of the largest dia. cable and sand shall be lightly pressed. A protective covering of RCC tiles shall then be laid on top in case of HT cable and ordinary brick in case of LT cables. The balance trench area shall then be back filled with soil, rammed and levelled.

As each cable is laid in the trench, it shall be subjected to an insulation test in the presence of the Engineer in Charge before covering. Any cable, which proves defective, shall be replaced at no additional cost.

All wall openings shall be effectively sealed after installation of cables.

Where cables rise from trenches to motors, control stations, lighting panels etc., they shall be taken up in GI pipes (rigid, flexible) for mechanical protection up to a minimum of 600 mm above grade level. The diameter of the GI pipe shall be at least 3 times the diameter of the cable.

Cable shall be carefully pulled through conduits to prevent damage.

Wherever cables are taken in conduits, pipe, the Bidder shall ensure that the area of conduit, pipe is at least 100 % more than the cable area.

If pipe sleeves installed are inadequate due to a greater number of cables being laid, then additional pipe sleeves shall be laid. After the cables are installed and all testing is complete, conduit ends above grade level shall be plugged with suitable weatherproof plastic compound.

Where cables pass through foundation walls or other underground structures, the necessary ducts or openings will be provided in advance for the same.

At road crossings and other places where cables enter pipe sleeves an adequate bed of sand shall be given.

Cables installed above grade level shall be run in trays, exposed on walls, ceilings or structures and shall be run parallel to, or at right angles to, beams, walls or columns. The cables shall be so routed that they will not be subjected to heat.

Cables running along with structures will be clamped by means of GI saddles and saddle bars at a spacing of 300 mm.

Cable carrier systems i.e. site fabricated ladder type cable trays and supporting steel shall be painted before laying of cables.

Painting shall have two coats of red oxide and one coat of Aluminium paint.

For all outdoor buried cables a 3-metre diameter loop shall be provided at both ends before termination.

**TERMINATION**

All XLPE insulated cables shall be terminated using HT termination kit only

All PVC cables shall be terminated at the equipment/panel by means of double compression type brass glands and tinned copper lugs.

Power cable cores shall be identified with red, yellow and blue PVC tapes.

In case of control cables, all cores shall be identified at both ends by their terminal numbers by means of PVC ferrules. Wire numbers shall be as per inter-connection diagrams, to be furnished to the Bidder.

The cable shall be taken through an adequate size gland inside the panel or any other electrical equipment.

Cable leads shall be terminated at the equipment terminals by means of crimped type solderless connectors.

Crimping shall be done by hand crimping/hydraulically-operated tool and conducting jelly shall be applied on the conductor. Insulation of the leads should be removed immediately before the crimping.

### TESTING OF CABLES

Before energizing, the insulation resistance shall be measured from phase to phase and phase to ground.

## Earthing System

### GENERAL

All the material required for the earthing system shall be supplied and installed by the Bidder. The hot dip GI strip shall be used.

All the material required for making earthing stations shall be supplied by the Bidder. Excavation and refilling for laying of earth strip and for earth pit shall also be in Bidders scope.

- The entire earthing system shall fully comply with Indian electricity act and rules. The Bidder shall carry out all changes desired by the electrical inspector, in order to make the installation conform to I.E. Rules.
- In trenches, earth strip shall be laid along the trench. It shall be protected against mechanical damage. Joints and tapping in the main earth grid shall be made in such a way that reliable and good electrical connections are permanently ensured. All joints except the equipment end shall be welded. All joints buried in ground shall be suitably protected by applying two coats of bitumen and covering with hessian tape.
- Conduits in which cables have been installed shall be bonded and earthed. Cable armours shall be earthed at both ends.
- Earth pipe electrodes shall be installed as per IS 3043. Their location shall be marked on earth pit chamber covers.
- The electrodes shall be tested for earth resistance by means of standard earth tester.
- A disconnecting facility shall be provided for individual earth pit to check earth resistance.
- All electrical equipment above 230 V shall be earthed at two points and equipment 230 V and below shall be earthed at one point.
- Conductor size for connections to various equipment shall be as per the table as follows:

Equipment		Conductor Size
Motors /Transformers/ Panel	Up to 11 kW	8 SWG GI wire
	11 kW to 22 kW	4 SWG GI wire
	22 kW to 90 kW	25 x 5 mm GI strip 40 x 5 mm strip
	90 kW to 200 kW	GI strip
	200kW to 200 kW	50 x 6 mm GI strip
Local control station, street light pole & its junction box		8 SWG GI wire
Lighting Panel, Auxiliary panel Indoor Light fixtures		25 x 3 mm GI strip Green insulated wire 1 mm sq copper

- All paint, scale etc. shall be removed before earthing connections are made.
- Anchor bolts or fixing bolts shall not be used for earthing connections.

## Lighting System

The cabling/wiring, installation and commissioning of complete illumination system shall comply with all currently applicable statutes, regulations, fire insurance and safety codes.

Outdoor lighting shall be carried out by using 1.1 kV grade four-core cable. The cabling for the outdoor lighting fixtures will be done in loop-in/loop-out at respective outdoor fixture mounted junction boxes. The indoor lighting shall also be carried out by using 2 Core, 2.5 mm<sup>2</sup> copper cables. The indoor office area wiring shall be carried in conduits.

Outdoor cabling shall be buried in ground whereas indoor lighting wiring (cable/conduit) shall be of exposed type.

### GENERAL REQUIREMENTS

Except as specifically approved by the Engineer in Charge in charge, installation of conduits and lighting fixtures shall be commenced only after all major services in that particular area have been completed.

Location of lighting fixtures, switches and receptacles shall be shown on the drawings or indicated by the Engineer in Charge and shall be relocated if required to suit the site conditions. 5A, 3 pin, 15A, 6 pin receptacles with switches shall be provided on the light control switchboards.

LP's shall be provided with labels indicating LP number and outgoing circuit Rising numbers.

LPs shall be provided with cable gland for incoming cable and knockouts for outgoing conduit termination.

Cable and Conduit supports shall be provided at an interval of 300-400 mm for horizontal runs and 400-500 mm for vertical runs.

Cables and Conduits shall be kept, wherever possible at least 300 mm away from pipes, heating devices and other equipment.

For the purpose of calculating connected loads of various circuits, a multiplying factor of 1.25 will be made to the rated lamp voltage for lamp fixtures to take into account the losses in the control gear.

Bidder shall supply junction boxes, pull boxes, terminal blocks, glands, conduits and accessories (elbows, tees, bends etc.) and supporting/anchoring materials, to make the installation complete.

In all types of cabling, due consideration shall be given to neatness and good appearance. The decision of the Engineer in Charge, regarding acceptance of appearance, shall be final.

The rate for installation, testing and commissioning of the indoor lighting shall include the mounting of fixtures with necessary materials, laying of cable/conduit, pulling of wires through conduit and external earth wire, providing all accessories for cable/conduit installation, including conduit fittings. Providing of light control switchboard with switches, switchboard mounted

5A, 3 pin receptacles with switches etc. The rate shall also be applicable for the lighting fixtures installed outside the building as perimeter lighting, entrance lighting below canopy etc.

### TESTING

Lighting installation shall be tested as per the instructions of the Engineer in Charge and shall include but not be limited to the following:

- Measure the insulation resistance of each circuit without the lamps being in place. It should be not less than 1 M ohms to earth.
- Current and voltage of all the phases shall be measured at the lighting panel busbars with all the circuits switched on with lamps. If required, load shall be re-balanced on the three phases.
- Check the earth continuity for all socket outlets. A fixed relative position of the phase and neutral connections inside the socket shall be established for all sockets.
- After inserting all the lamps and switching on all circuits, minimum and maximum illumination level shall be measured in the area with an approved industrial lightmeter. Bidder shall supply an approved luxmeter for testing at no extra cost.

### Miscellaneous

#### Cable glands and lugs

All HT cables shall be terminated with HT cable termination kit of indoor or outdoor type depending on the application.

All LT cable glands shall be made out of brass and shall be of double compression type.

All LT cable lugs shall be of tinned copper, crimping type.

#### CABLE TRAYS

Cable carrier system shall comprise of site fabricated ladder type cable trays made out of structural steel and painted with two coats of red oxide primer and a final coat of enamel paint. The construction of the cable trays shall be as per the site requirement and generally in line with the tender drawings.

#### LIGHTING PANELS (LP)/ FAN DB

The panels shall be of 14 gauge sheet metal construction. Panels shall be equipped with phase and neutral busbars of adequate capacity and miniature circuit breakers (MCB). The incomer shall be of ELMCB (earth leakage miniature circuit breaker) and outgoing circuits shall have only MCBs. MCB shall be of 9 kA. Miniature circuit breakers shall be mounted in such a way that operating levers project outside the front cover plates. A hinged door to cover the operating knobs shall be provided. Synthetic rubber gasketing shall be provided between box and cover. The board shall be provided with detachable top and bottom plates with 25 mm knockouts. All metal surfaces shall be cleaned free of rust, given powder coating of shade 631 as per IS 5. A 415V danger board and engraved nameplate shall be fixed on the panel. The lighting panels shall be marked with the voltage and No. of phases of the supply.

#### RUBBER MATS

Electrical grade rubber mats shall be provided in the switchgear room in front of all panels.

#### CIVIL WORKS

The civil works required for electrical installation will also be part of this package. The Bidder shall also co-ordinate all inter-discipline interfaces between civil and electrical work.

#### Local Push-button (PB) Stations

Construction	Outdoor type weatherproof
Main pump motor	On-off with ammeter
Other motors	On-off
Valve motors	Forward-stop –reverse spring return starter with indication for full open/close position of valve.

#### Spare parts for Electrical Equipment

The compulsory spare parts shall be provided as per the list enclosed under scope of work. All spare parts shall be packed for long storage under the climatic conditions prevailing at the site. Each spare part shall be labelled on the outside of its packing with its description, number and purpose and, if more than one spare is packed in a single case, a general description of the case contents shall be shown on the outside and a packing list enclosed.

Fire extinguishers

Dry powder type fire extinguishers shall be provide, near transformer & near main panel & Pump.

Signature of Contractor

Executive Engineer (PHE-I)  
JDA, Jaipur

# **Section A-5**

## **Annexure**

**Annexure A**  
**(RTPP Act/Rules)**

**Compliance with the Code of Integrity and No Conflict of Interest**

Any person participating in a procurement process shall-

- (a) Not offer any bribe, reward or gift or any material benefit either directly or indirectly in exchange for an unfair advantage in the procurement process or to otherwise influence the procurement process;
- (b) Not misrepresent or omit that misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- (c) Not indulge in any collusion, Bid-rigging or anti-competitive behavior to impair the transparency, fairness and progress of the procurement process;
- (d) Not misuse any information shared between the procuring entity and the bidders with an intent to gain an unfair advantage in the procurement process;
- (e) Not indulge in any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- (f) Not obstruct any investigation or audit of a procurement process;
- (g) Disclose conflict of interest, if any; and
- (h) Disclose any previous transgressions with any entity in India or any other country during the last three years or any debarment by any other procuring entity.

**Conflict of interest:**

The Bidder participating in a bidding process must not have a Conflict of Interest.

A Conflict of interest is considered to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations.

A bidder may be considered to be in conflict of interest with one or more parties in the bidding process if, including but not limited to:

- (a) Have controlling partners/shareholders in common; or
- (b) Receive or have received any direct or indirect subsidy from any of them; or
- (c) Have the same legal representative for purposes of the bid; or
- (d) have a relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another bidder, or influence the decisions of the procuring Entity regarding the bidding process; or
- (e) The bidder participates in more than one bid in a bidding process. Participation by a bidder in more than one bid will result in the disqualification of all bids in which the bidder is involved. However, this does not limit the inclusion of the same subcontractor, not otherwise participating as a bidder, in more than one bid; or
- (f) the bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the goods, works or services that are the subject of the Bid; or
- (g) Bidder or any of its affiliates has been hired (or proposed to be hired) by the procuring entity as engineer-in-charge/consultant for the contract.

**Annexure B**  
**(RTPP Act/Rules)**

**Declaration by the Bidder regarding Qualifications**

**Declaration by the Bidder**

In relation to my/our Bid submitted to **EE-PHE-I** for procurement of

\_\_\_\_\_ in response to their Notice inviting Bids No

\_\_\_\_\_ Dated \_\_\_\_\_ I/we .....hereby declare under Section 7 of Rajasthan Transparency in Public Procurement Act, 2012 that:

1. I/we possess the necessary professional, technical, financial and managerial resources and competence required by the Bidding Document issued by the Procuring Entry;
2. I/we have fulfilled my/our obligation to pay such of the taxes payable to the union and the state government or any local authority as specified in the Bidding Document.
3. I/we are not insolvent, in receivership, bankrupt or being wound up, not have my/our affairs administered by a court or a judicial officer, not have my/our business activities suspended and not the subject of legal proceedings for any of the foregoing reasons;
4. I/we do not have, and our directors and officers not have, been convicted of any criminal offense related to my/our professional conduct or the making of false statements or misrepresentations as to my/our qualifications to enter into a procurement contract within a period of three years preceding the commencement of this procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
5. I/we do not have a conflict of interest as specified in the Act, Rules and the Bidding Document, which materially affects fair competition;

Date:	Signature of the bidder
Place:	Name:
	Designation:
	Address:

**Note:- Annexure “B” is mandatory to be fulfilled & signed with seal by the bidder failing which the bid shall summarily be rejected without asking any clarification.**

**Annexure C**  
**(RTPP Act/Rules)**

**Grievance Redressal during Procurement Process**

The designation and address of the First Appellate Authority :

For works costing up to Rs. 300.00Lakhs - Jaipur Development Commissioner, JDA, Jaipur.

For works costing above Rs. 300.00Lakhs - Executive Committee, JDA, Jaipur.

The designation and address of the Second Appellate Authority: .....

For works costing up to Rs. 300.00Lakhs - Executive Committee, JDA, Jaipur.

For works costing above Rs. 300.00Lakhs - Principle Secretary/ACS, Urban Development  
& Housing Department, GOR, Jaipur.

**(1) Filing an appeal: -**

if any bidder or prospective bidder is aggrieved that any decision, action or omission of the procuring entity is in contravention to the provisions of the Act or the rules or the guidelines issued there under, he may file an appeal to First Appellate authority, as specified in the Bidding document within a period of ten days from the date of such decision or action, omission, as the case may be, clearly giving the specific ground or grounds on which, he feels aggrieved:

Provided that after the declaration of a bidder as successful the appeal may be filed only by a bidder who has participated in procurement proceedings:

Provided further that in case a procuring entity evaluates the technical bids before the opening of the financial bids, an appeal related to the matter of financial bids may be filed only by a bidder whose technical bid is found to be acceptable.

**(2)** The officer to whom an appeal is filed under Para (1) shall deal with the appeal as expeditiously as possible and shall Endeavour to dispose it of within thirty days from the date of the appeal.

**(3)** If the officer designated under Para (1) fails to dispose of the appeal filed within the period specified in Para (2), or if the bidder or prospective bidder or the procuring entity is aggrieved by the order passed by the first appellate authority, the bidder or prospective bidder or the procuring entity, as the case may be, may file a second appeal to the second appellate authority specified in the bidding document in this behalf within fifteen days from the expiry of the period specified in Para (2) or of the date of receipt of the order passed by the first appellate authority, as the case may be.

**(4) Appeals not to lie in certain cases: -**

No appeal shall lie against any decision of the procuring entity relating to the following matters, namely: -

- (a) Determination of the need of procurement
- (b) Provisions limiting the participation of bidders in the bid process
- (c) The decision of whether or not to enter into negotiations
- (d) Cancellation of a procurement process
- (e) Applicability of the provisions of confidentiality

**(5) Form of Appeals: -**

(a) An appeal under Para (1) or (3) above shall be in the annexed form along with as many copies as there are respondents in the appeal.

(b) Every appeal shall be accompanied by an order appealed against, if any, Affidavit verifying the facts stated in the appeal and proof of payment of fee,

(c) Every appeal may be presented to the first appellate authority or second

The appellate authority, as the case may be, in person or through registered post or authorized representative.

**(6) Fee for filing Appeal: -**

(a) Fee for the first appeal shall be rupees two thousand five hundred and for the second appeal shall be rupees ten thousand, which shall be non-refundable.

- (b) The fee shall be paid in the form of a bank demand draft or banker's cheque of a scheduled bank in India payable in the name of the appellate authority concerned.

**(7) Procedure for disposal of Appeal: -**

- (a) The first appellate authority or second appellate authority as the case may be, upon the filing of the appeal, shall issue notice accompanied by a copy of the appeal, affidavit and documents, if any, to the respondents and fix a date of hearing
- (b) On the date fixed for hearing, the first appellate authority of the second appellate authority, as the case may be shall-
  - (i) Hear all the parties appeal presenting before him; and
  - (ii) Peruse or inspect documents, relevant records or copies thereof relating to the matter.
- (c) After hearing the parties, perusal or inspection of documents and relevant records or copies thereof relating to the matter, the appellate authority concerned shall pass an order in writing and provide a copy of the order to the parties to appeal free of cost.
- (d) The order passed under sub-clause (c) above shall also be placed on the state public procurement portal.

Annexure D  
(RTPP Act/Rules)

**Additional Conditions of Contract**

**1. Correction of arithmetical errors**

Provided that a financial bid is substantially responsive, the procuring entity will correct arithmetical errors during the evaluation of financial Bids on the following basis:

- (i) if there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected unless in the opinion of the procuring entity, there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price shall be corrected;
- (ii) if there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected; and
- (iii) if there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (i) and (ii) above.

If the Bidder that submitted the lowest evaluated bid does not accept the correction of errors, its bid shall be disqualified and its bid security shall be forfeited or its bid securing declaration shall be executed.

**2. Procuring Entity's Right to Vary quantities.**

- (i) At the time of award of the contract, the quantity of goods, works or services originally specified in the bidding documents may be increased or decreased, by a specified percentage, but such increase or decrease shall not exceed fifty percent, of the quantity specified in the bidding documents. It shall be without any change in the unit prices or other terms and conditions of the bid and the conditions of the contract.
- (ii) If the Procuring entity does not procure any subject matter of procurement or procures less than the quantity specified in the bidding document due to change circumstances, the bidder shall not be entitled to any claim or compensation except otherwise provided in the conditions of the contract.
- (iii) In case of procurement of goods or services, additional quantity may be procured by placing a repeat order on the rates and conditions of the original order. However, the additional quantity shall not be more than 25% of the value of goods of the original contract and shall be within one month from the date of expiry of the last supply. If the supplier fails to do so, the procuring entity shall be free to arrange for the balance supply by limited bidding or otherwise and the extra cost incurred shall be recovered from the supplier.

**3. Dividing quantities among more than one bidder at the time of award (In case of procurement of Goods):-**

As a general rule, all the quantities of the subject matter of procurement shall be procured from the Bidder, whose Bid is accepted. However, when it is considered that the quantity of the subject matter of procurement to be procured is very large and it may not be in the capacity of the Bidder, whose Bid is accepted, to deliver the entire quantity or when it is considered that the subject matter of procurement to be procured is of critical and vital nature, then in such cases, the quantity may be divided between the Bidder, whose Bid is accepted and the second lowest Bidder or even more Bidder in that order, in a fair, transparent and equitable manner at the rates of the Bidder, whose Bid is accepted.

Signature of Contractor  
with full address & Mobile No.

Executive Engineer (PHE-I)  
JDA, Jaipur

## JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

No. JDA/Ex.En. (TA to Dir. Engg.-I)/2016/D-29

Dated: 11/3/2016

## Office Order

Subject: - DLP period for various type of works.

As per the decision taken in the 201<sup>st</sup> meeting of Executive Committee held on 23.02.2016 w.r.t. agenda no. 201:22, DLP period of various natures of works amounting more than Rs. 25 lakhs has been revised as per following time periods based on nature of works.

This order will supersede the earlier orders issued in this regard i.e. order No. JDA/TA to D(E)/2010-11/D-317 dated 28.04.2011 including Special Condition No. 2.2.2 & 2.2.3 of Annexure-I related to SD refund & forfeiture (other Special Condition of annexure-I of this order will remain valid) and order No. JDA/Ex.En.(Pr.-5 & TA)/2013/D-43 dated 27.02.2013 and also all pertaining orders, in contract agreements or in PWF&AR having DLP period different than what is being enforced through this present order for concerned type of work.

Table-I

S.No.	Type of Work	Existing DLP Period	As per approved in E.C. held on 23.02.2016
1.	Bridge Work	3 years	5 Years
2.	CD Work	3 years	5 Years
3.	CC Road, PQC Work	3 years	5 Years
4.	CC tiles/Kerbs/medians	3 years	5 years
5.	Drains	6 months	3 years
6.	Roads		
	(i) Two layer WBM/CSB	3 years	6 Months or one full rainy season which ever is later
	(ii) For Renewal/Strengthening		
	(a) BT upto 30 mm thickness	3 years	1 year
	(b) BT above 30 mm to upto 40 mm	3 years	2 years
	(c) BT above 40 mm to upto 90 mm	3 years	3 years
	(d) ET Above 90 mm	3 years	5 years
	(iii) New Roads		
	(a) BT upto 90 mm	3 years	3 years
	(b) BT more than 90 mm	3 years	5 years
7.	Compound wall	6 months	3 years
8.	Buildings work		
	(i) Work pertaining to Sanitary works electrical works, joinery works and painting works.	6 months	2 years
	(ii) Work pertaining to Building structure and other civil works.	6 months	5 years
9.	Electric work except maintenance	6 months	3 years
10.	Sewer/Water supply all including STP and water supply related work except maintenance works.	6 months	3 years

The release of SD amount shall be as per following table:-

**Table-II**

S. No.	Rele. sed SD DLP period	1 <sup>st</sup> year	2 <sup>nd</sup> year	3 <sup>rd</sup> year	5 <sup>th</sup> year
1.	Upto 1 year	100%	40%	20% ✓	10%
2.	Upto 2 year		60%	20% ✓	10%
3.	Upto 3 year			60% ✓	10%
4.	Upto 4 year				20%
5.	Upto 5 year				50%

Various conditions for managing DLP are as under:-

- (i) At the time of completion of work, final component shall be worked out for each individual item like BT/CC/tiles/drains etc (as per different categories in Table I), DLP shall be operative based upon type of individual item ex- CC-5 years, BT- 1/2/3/5 years, Drain- 3 years etc.
- (ii) Similarly for all new works, these components should be calculated at the time of TS itself, which should be made part of BID document.
- (iii) If any work, amount is less than Rs. 25 lakhs but later on due to extra/excess work, if amount of final work crosses more than Rs. 25 lakhs, DLP shall be operative as per rule for each individual item.
- (iv) Similarly if any work is more than Rs. 25 lakhs but after finalization amount of work is less than Rs. 25 lakhs, DLP should be operative for six months or rainy season whichever is late.
- (v) During DLP period if contractor fails to repair any work even after issue of 7 days written notice, same work shall be got executed by respective Executive Engineer at the contractor's risk and cost. This process shall be applicable throughout the DLP period. After completion of DLP period in such works contractor should be debarred and blacklisted from JDA for three years as per RTPP Rule 2012 and 2013 where he defaults twice in a single agreement or in two different works.
- (vi) Quarterly inspection as per rules shall be carried out and DLP registers shall be maintained by respective Executive Engineers to monitor the DLP repairs.
- (vii) Special and regular inspection shall also be carried out as per order no. JDA/Ex.En & TA to DE-I/2014-15/D-223 dated 12.03.2015 and order no. SE (PMGSY) CIRCULAR 2006/D-115 dated 04.05.2006 Point no. 3.
- (viii) In case JDA feels to take up work on any existing DLP road due to any reason, following procedure should be adopted:
  - (a) At the time of withdrawal total liability of repairs as per DLP conditions to be carried out and contractor shall be asked to complete the same. After completion of assessed repairs DLP period shall be released after deduction amt. as per table III.

Table-III

% Recovery on Withdrawal of DLP, of work order DLP period	1 year	2 year	3 year	4 year	5 year
1 year	1.12	-	-	-	-
2 year	2.55	1.43	-	-	-
3 year	4.38	3.26	1.83	-	-
5 year	9	7.88	6.45	4.62	2.47

Note:- Calculation is to be done on quarterly basis.

(b) In case Contractor fails to carry out these repairs, same shall be carried out at his risk and cost. If the total amt. of such repairs works out to be more than total retained amt. of SD, same shall be recovered from other works and as per PDR rules. The amount as per Table III is also to be deducted in addition to this amount.

(ix) Based upon type of work, DLP conditions for works to be carried out during DLP period with their frequency of respective type of work shall be prepared by respective SE's after approval of these periods.

This order shall come in force with immediate effect and will be applicable on all new works whose NIB is to be called.

Sd/-  
Director (Engineering-I)  
JDA, Jaipur

Copy to following for information and necessary action:-

1. PS to JDC, JDA, Jaipur.
2. PS to Secretary, JDA, Jaipur.
3. Director Engineer I/II, JDA, Jaipur.
4. Director (Fin.), JDA, Jaipur.
5. C.F, JDA, Jaipur.
6. All Add. Chief Engineers, JDA, Jaipur.
7. All Superintendent Engineers, JDA, Jaipur.
8. OSD (RM), JDA, Jaipur.
9. Additional Director (REV.&DP.)
10. CAO (P&A) JDA, Jaipur.
11. Sr. Horticulturist, JDA, Jaipur
12. All Executive Engineer, JDA, Jaipur.
13. DD (E&B) JDA, Jaipur.
14. All AOs, JDA, Jaipur.
15. All AAOs, JDA, Jaipur.
16. System Analyst
17. All Contractors' Association, JDA, Jaipur.
18. Guard file

Sd/-  
S.E. & TA to Dir. (Engg.-I)  
JDA, Jaipur

## Jaipur Development Authority, Jaipur

### Office Order

No. : JDA/IT(1074501)/E-Services/2015-16/D-399

Dated: 4-10-2016

### **Subject: Payment mechanism for participating in tender.**

Jaipur Development Authority has decided to receive Earnest Money Deposit (EMD) (Bid Security), Tender Fee and RISL processing fee online through JDA Portal. The bid security options available in tender for participants are as mentioned below:

#### **A. Payment Options:**

##### **Option-1: Bank Guarantee (BG) against EMD / Bid Security**

Bidder may opt Bank Guarantee (BG) against EMD (Bid Security), for which bidder requires to prepare BG before applying in the tender. The details of BG requires to be fed on JDA portal before paying balance amount (Tender Fee + RISL Processing Fee). This amount will be paid through **Payment Gateway only**, option to make balance payment through EFT (RTGS/NEFT) will not be available.

If bidder does not opt for BG against EMD, options of making complete payment through Payment Gateway or through EFT (NEFT / RTGS) will be available.

##### **Option-2: Electronic Fund Transfer (EFT: NEFT/RTGS)**

If the bidder selects payment mode as EFT (NEFT/RTGS), "Paying Slip for EFT (NEFT/RTGS)" will be generated by the system for the complete amount. The payment can be made from **any Bank any Branch** using this Paying Slip through NEFT/RTGS (Claim against payment made through EFT in any other JDA bank account will not be acceptable and bidder stands disqualified from participation in the bid applied for). After successful transaction through NEFT/RTGS, as per the standard procedures it may take 4 to 24 hours in process of confirmation of EFT through Auto-Process depending on the time of EFT done. Therefore, option to make payment through EFT (NEFT/RTGS) will be available till 2 days prior to closing date of bid participation.

##### **Option-3: Payment Gateway (Aggregator)**

The facility to make payment through Debit Card, Credit Card, Net banking etc., will be available. User can use this facility from **anywhere any time** till the closing date & time of bid participation.

#### **B. Bid Participation Receipt**

After confirming payment, the bidder will get Bid Participation Receipt on the basis of which user will get the payment details along with other details for bidding on e-Procurement portal of GOR.

- In case of BG as the remaining payment will be done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis.

- In case complete payment is done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis.
- In case complete payment is done through EFT (NEFT/RTGS), on confirmation of payment from ICICI Bank (Auto Process) "Bid Participation Receipt" will be available on Login of Bidder on JDA portal.

This payment mechanism will come into force w.e.f 15/10/2016. Thereafter, old payment mechanism related to NEFT/ RTGS in which the bidder makes direct payment without "Paying Slip for EFT (NEFT/RTGS)" in JDA's bank account will be discontinued.

All procuring entities are hereby directed to clearly mention this procedure in NIB document.

  
(Pawan Arora)  
Secretary

**Copy for information and further necessary action to:**

1. P.S. to JDC, JDA, Jaipur.
2. P.S. to Secretary, Secretary, JDA, Jaipur.
3. Director (Law / Finance / Town Planning / Engineering-I / Engineering-II), JDA, Jaipur.
4. All Additional Chief Engineer \_\_\_\_\_, JDA, Jaipur
5. DC (Administration)/DC(Store)/DC (Vehicle), JDA, Jaipur
6. System Analyst, JDA, Jaipur
7. Analyst-cum-Programmer, JDA to ensure integration of software w.e.f 01/10/2016.
8. All Xen \_\_\_\_\_, JDA, Jaipur.
9. Officer-in-charge, SPPP Portal, Jaipur.
10. OSD (Public Relation) / PRO, JDA, Jaipur.

  
(Brijesh Kishore Sharma)  
OSD (RM)

## Annexure G:

## जयपुर विकास प्राधिकरण, जयपुर

क्रमांक :- F-( )JDA/Sr.Ao.works-II/2017/D-172

दिनांक :- 12.7.17

आदेश

1 जुलाई 2017 से भारत सरकार के नोटिफिकेशन द्वारा GST लागू होने के कारण व्यक्तियों/फर्मों/कम्पनी/संस्था/टेकेदार के निर्माण/सिविल आपूर्ति/सेवाओं इत्यादि के कार्यों के प्राधिकरण द्वारा बिल भुगतान किये जाने के लिये प्राधिकरण कर सलाहकार चार्टर्ड एकाउन्टेन्ट से प्राप्त हुई राय के क्रम में निम्नांकित प्रमाण पत्र/शपथ पत्र/Invoice बिलों के साथ प्रस्तुत किया जाना सुनिश्चित करावे :-

1. व्यक्ति/फर्म/कम्पनी/संस्था/टेकेदार का GST के अन्तर्गत रजिस्ट्रेशन प्रमाण पत्र की स्व:प्रमाणित फोटो प्रति।
2. व्यक्ति/फर्म/कम्पनी/संस्था/टेकेदार का GST के रजिस्ट्रेशन नहीं होने के स्थिति में स्व:प्रमाणित शपथ पत्र।
3. अपंजीकृत व्यक्ति/फर्म/कम्पनी/संस्था/टेकेदार के बिलों के भुगतान की स्थिति में मासिक टैक्स Invoice भुगतान-अधिकारी द्वारा मासिक आधार पर उसी माह के अंत में तैयार करवाया जाना सुनिश्चित किया जावेगा।
4. आपूर्ति एवं सेवा के विरुद्ध भुगतान बिलों में Vat/Service Tax चार्ज होने ( Vat/Service Tax होने) पर (दिनांक 30.06.17 तक आपूर्ति एवं Invoice जारी करने पर) Taxable Invoice नहीं बनाया जावेगा एवं इनका भुगतान पूर्वानुसार (01.07.2017 से पूर्व निहित प्रक्रिया अनुसार) किया जाना सुनिश्चित करावे।

स्पष्टीकरण :- दिनांक 30.06.17 तक सामान की आपूर्ति के बिलों में Vat Invoice होने पर या अन्यथा होने पर इनका भुगतान पूर्वानुसार 01.07.2017 से पूर्व निहित प्रक्रिया अनुसार किया जावेगा।

संलग्न :- GST रेट तथा HSN/SAC CODE की फोटो प्रति

(बृजेश किशोर शर्मा)  
निदेशक(वित्त)

प्रतिलिपि निम्न को सूचनार्थ एवं आवश्यक कार्यवाही हेतु :-

1. वारंष्ट निजी सचिव, आयुक्त, जयपुर।
2. वारंष्ट निजी सचिव, संचिद, जयपुर।
3. निदेशक (वित्त/वित्त/अभियंत्रिकी-प्रथम व द्वितीय/आयोजना/परियोजना, जयपुर।
4. अतिरिक्त आयुक्त(प्रशासन/पूर्व/पश्चिम/एल.पी.सी./भूमि), जयपुर।
5. संयुक्त आयुक्त(सिस्टम मैनेजमेन्ट/संसाधन एवं समन्वय), जयपुर।
6. विशेषाधिकारी(संसाधन विकास), जयपुर।
7. अतिरिक्त निदेशक(राजस्व एवं सम्पत्ति निस्तारण), जयपुर।
8. समस्त जोन उपायुक्तगण ..... , जयपुर।
9. मुख्य लेखाधिकारी(पी. एण्ड ए.), जयपुर।
10. उपनिदेशक(व्यय एवं बजट), जयपुर।
11. वरिष्ठ लेखाधिकारी(निर्माण-प्रथम/द्वितीय/आर.सी.आर./पेंशन/सीनार्मी), जयपुर।
12. सिस्टम एनालिस्ट, जयपुर को प्रेषित कर लेख है कि सिस्टम में GST नम्बर सम्मिलित करने एवं Tax Invoice बनाने की प्रक्रिया तैयार करावे।
13. उप रजिस्ट्रार(सहकारिता), जयपुर।
14. अधिशाषी अभियन्ता जोन ..... , जयपुर।
15. वरिष्ठ उद्यानविज्ञ, जयपुर।
16. लेखाधिकारी (भुगतान/योजना/निर्माण)/सहायक लेखाधिकारी, जयपुर।
17. प्रभारी अधिकारी, नागरिक सेवाकेन्द्र, जयपुर।
18. सलाहकार(जनसम्पर्क), जयपुर।
19. रोकड़ियों(निर्माण/सिविल/भूमि आवांति), जयपुर।
20. रक्षित पत्रावली

अति.निदेशक(रा.एवं स.नि.)



 सत्यमेव जयते	<b>राजस्थान राजपत्र</b> <b>विशेषांक</b>	<b>RAJASTHAN GAZETTE</b> <b>Extraordinary</b>
	<b>साधिकार प्रकाशित</b>	<b>Published by Authority</b>
	आश्विन 30, शुक्रवार, शाके 1943-अक्टूबर 22, 2021 <i>Asvina 30, Friday, Saka 1943- October 22, 2021</i>	

भाग 4 (ग)

उप-खण्ड (1)

राज्य सरकार तथा अन्य राज्य-प्राधिकारियों द्वारा जारी किये गये (सामान्य आदेशों, उप-विधियों आदि को सम्मिलित करते हुए) सामान्य कानूनी नियम।

**FINANCE (G&T) DEPARTMENT**

**NOTIFICATION**

**Jaipur, October 22, 2021**

**G.S.R.364** .-In exercise of the powers conferred by section 55 of the Rajasthan Transparency in Public Procurement Act, 2012 (Act No. 21 of 2012), the State Government hereby makes the following rules further to amend the Rajasthan Transparency in Public Procurement Rules, 2013, namely:-

**1. Short title and commencement.**- (1) These rules may be called the Rajasthan Transparency in Public Procurement (Fourth Amendment) Rules, 2021.

(2) They shall come into force from the date of their publication in the Official Gazette.

**2. Insertion of new rule 75A.**- After the existing rule 75 and before the existing rule 76 of the Rajasthan Transparency in Public Procurement Rules, 2013, the following new rule 75A shall be inserted, namely:-

**"75A. Additional Performance Security.**- (1) In addition to Performance Security as specified in rule 75, an Additional Performance Security shall also be taken from the successful bidder in case of unbalanced bid. The Additional Performance Security shall be equal to fifty percent of Unbalanced Bid Amount. The Additional Performance Security shall be deposited in lump sum by the successful bidder before execution of Agreement. The Additional Performance Security shall be deposited through e-Grass, Demand Draft, Banker's Cheque, Government Securities or Bank Guarantee.

**Explanation :** For the purpose of this rule,-

- (i) Unbalanced Bid means any bid below more than fifteen percent of Estimated Bid Value.
- (ii) Estimated Bid Value means value of subject matter of procurement mention in bidding documents by the Procuring Entity.
- (iii) Unbalanced Bid Amount means positive difference of eighty five percent of Estimated Bid Value minus Bid Amount Quoted by the bidder.



1827

राजस्थान राज-पत्र, अक्टूबर 22, 2021

भाग 4 (ग)

(2) The Additional Performance Security shall be refunded to the contractor after satisfactory completion of the entire work. The Additional Performance Security shall be forfeited by the Procuring Entity when work is not completed within stipulated period by the contractor. Provision for 'Unbalanced Bid' and 'Additional Performance Security' shall be mentioned in the Bidding Documents by the Procuring Entity."

[No. F.2(1)FD/G&T(SPFC)/2017]  
By Order of the Governor,

Vimal Kumar Gupta,  
Joint Secretary to the Government.

राज्य केन्द्रीय मुद्रणालय, जयपुर।



## जयपुर विकास प्राधिकरण, जयपुर

www.jda.urban.rajasthan.gov.in

क्रमांक जविप्रा/अधि. अभि./त.स.नि.अ.-1/2021/डी-75

दिनांक :- 26/01/2021


To

Contractor's Association  
Jaipur Development Authority  
Jaipur.

जयपुर विकास प्राधिकरण में विभिन्न कार्यों हेतु कार्यों की प्रकृति के अनुसार निविदाएँ, कार्यालय आदेश क्रमांक JDA/Ex.En. (TA to Dir.Engg.-I)/2014-15/D-202 Dated:16.02.2015 द्वारा एकल बिड व Two bid में invite की जाती है। निविदाएँ प्राधिकरण की EC द्वारा अनुमोदित निविदा दस्तावेज के अनुसार की जाती है। निविदाओं के evaluation के दौरान प्रायः यह देखा जाता है कि निविदाकर्ता द्वारा निविदा प्रपत्र में अंकित दिशानिर्देशों के अनुसार प्रस्तुत किए गये आवश्यक दस्तावेज या तो अधूरे होते हैं या चाहे गये प्रफोर्मा प्रपत्र के अनुसार नहीं आवेदित किए जाते हैं। इस कारण से कई बार निविदाएं छोटी-छोटी गलतियों की वजह से निरस्त हो जाती है या Particular bidder disqualify हो जाते हैं। कुछ सामान्य गलतियाँ निम्नानुसार हैं:-

1. Schedule 1 to 4 को नहीं भरना।
2. RTPP प्रपत्र A,B,C,D को नहीं भरना व हस्ताक्षर नहीं करना।
3. निविदा दस्तावेज विभिन्न दस्तावेजों पर स्वयं के या नोटेरी के हस्ताक्षर नहीं होना।
4. रजिस्ट्रेशन की प्रति नहीं लगाना।
5. EMD Receipt नहीं लगाना।
6. Work performance certificate नहीं लगाना।
7. Non Judicial Stamp पर दी जाने वाली सूचनाएं सामान्य प्रष्ठ पर देना।
8. Two bid निविदाओं में वर्ष वार कार्य की मात्राएं एवं राशि नहीं देना।
9. अनावश्यक दस्तावेज उपलब्ध कराना।
10. Online bidding के लिए आवश्यक विभिन्न शुल्क जमा नहीं कराना।
11. GST Clearance Certificate नहीं लगा होना।
12. Certificate having quantities financial year wise should not be missing.
13. Certificate of maximum value of similar nature work executed in any one last financial year out of last five financial year.
14. Annual turn our certificate by CA नहीं लगाना।
15. मशीनरी की details संलग्न नहीं करना।
16. Bid Fee, Bid Processing Fee, Tax Clearance Certificate should not be missing.
17. Completion certificate of required similar nature component is to be enclosed.
18. Litigation History Should be enclosed.
19. Information regarding existing commitments and ongoing works should be enclosed.

इस सम्वन्ध में सभी निविदाताओं को सूचित किया जाता है कि निविदाएं जमा करने से पहले निविदा प्रपत्र में अंकित व चाहे गयी सूचनाएं उचित तरीके से भर कर ही निविदा प्रस्तुत करें जिससे अनावश्यक रूप से निविदा निरस्तीकरण से बचा जा सके। त्रुटीपूर्ण निविदा की स्थिति में निविदाता स्वयं ही जिम्मेदार होंगे।

  
अधीक्षक अभियन्ता एवं  
तक.सहा. निदे. (अभि.-प्रथम)  
जविप्रा, जयपुर

रामकिशोरव्यासभवन, इन्दिरासर्किल, जवाहरलालनेहरूमार्ग, जयपुर-302004

दूरभाष- : ईपीबीएक्स - +91-141-2569696 एक्सटेंशन: (7209); फैक्स- +91-141-2574555

e-Mail : (sudhirsharma.jda@rajasthan.gov.in)

Scanned with CamScanner



## जयपुर विकास प्राधिकरण, जयपुर

www.jda.urban.rajasthan.gov.in

क्रमांक जविप्रा/अधि. अभि./त.स.नि.अ.-1/2021/डी-75

दिनांक :- 26/8/2021

प्रतिलिपि निम्न को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित है:-

1. निजी सचिव, आयुक्त, जविप्रा, जयपुर।
2. निजी सचिव, सचिव, जविप्रा, जयपुर।
3. निदेशक (अभियांत्रिकी-प्रथम/द्वितीय/वित्त), जविप्रा, जयपुर।
4. समस्त अतिरिक्त मुख्य अभियन्ता, जविप्रा, जयपुर।
5. समस्त अधीक्षण अभियन्ता, जविप्रा, जयपुर।
6. समस्त अधिशाषी अभियन्ता, जविप्रा, जयपुर।
7. रक्षित पत्रावली।

अधिशाषी-अभियन्ता एवं  
तक.सहा. निदे. (अभि.-प्रथम)  
जविप्रा, जयपुर

रामकिशोरव्यासभवन, इन्दिरासर्किल, जवाहरलालनेहरुमार्ग, जयपुर-302004

दूरभाष - : ईपीबीएक्स - +91-141-2569696 एक्सटेंशन: (7209); फ़ैक्स- +91-141-2574555

e-Mail : {sudhirsharma.jda@rajasthan.gov.in}

Scanned with CamScanner

	<b>राजस्थान राजपत्र</b>	<b>RAJASTHAN GAZETTE</b>
	<b>विशेषांक</b>	<b>Extraordinary</b>
	<b>साधिकार प्रकाशित</b>	<b>Published by Authority</b>
पौष 22, बुधवार, शाके 1943-जनवरी 12, 2022 <i>Pousa 22, Wednesday, Saka 1943- January 12, 2022</i>		

भाग 4 (ग)

उप-खण्ड (1)

राज्य सरकार तथा अन्य राज्य-प्राधिकारियों द्वारा जारी किये गये (सामान्य आदेशों, उप-विधियों आदि को सम्मिलित करते हुए) सामान्य कानूनी नियम।

## FINANCE (G&amp;T) DEPARTMENT

## NOTIFICATION

Jaipur, January 12, 2022

**G.S.R.398** .-In exercise of the powers conferred by section 55 of the Rajasthan Transparency in Public Procurement Act, 2012 (Act No. 21 of 2012), the State Government hereby makes the following rules further to amend the Rajasthan Transparency in Public Procurement Rules, 2013, namely:-

**1. Short title and commencement.-** (1) These rules may be called the Rajasthan Transparency in Public Procurement (Amendment) Rules, 2022.  
(2) They shall come into force from the date of their publication in the Official Gazette.

**2. Amendment of rule 75.-** In rule 75 of the said rules,-

- (i) in proviso to sub-rule (2), for the existing expression "31.12.2021", the expression "31.03.2023" shall be substituted; and
- (ii) in proviso to clause (f) of sub-rule (3), for the existing expression "31.12.2021", the expression "31.03.2023" shall be substituted.

[No. F.2(1)FD/G&amp;T(SPFC)/2017]

By Order of the Governor,

Vimal Kumar Gupta,  
Joint Secretary to the Government.

1936

Government Central Press, Jaipur.

## JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

www.jda.urban.rajasthan.gov.in

No. JDA/ E.E. & (TA to Dir. Engg.-I)/2022/D-194

Dated: - 6/9/2022

### Office Order

In the standard bid document (Two bid system) of JDA, Clause 5: Rejection of Bids, subclause (iii) shall be replaced and read as under with immediate effect:-

S.N.	Provision as per standard Bid document	As per GoR orders F.8(15)Fin/SPFC/2020 dated 17.05.2022
1.	"If all the copies enclosed in support and affidavit is not duly attested by notary public/gazetted officer/Self (as per order No F 14(22)JDA/Estt./2014 Dated 01.01.2015) then bid of the bidder is to be rejected."	<b>The Bidder shall prepare bid in the digital/electronic mode for uploading on e-Procurement portal in the format/type of file specified in evaluation and Qualification criteria 'All the documents uploaded, should be digitally signed with the DSC of authorized signatory, deemed as all the pages of the uploaded documents are signed'.</b>

The following additional condition should be added in the standard Bid document (Two Bid system)

1. The Affidavits and Annexure 'B': be enclosed by the bidder regarding Qualification of RTPP Act-2012 & Rule-2013 along with Bid document, should be signed by the participating bidders before uploading the tender document otherwise the Bid of the bidder will be rejected.
2. In case of single Bid system Annexure 'B': be enclosed by the bidder regarding Qualification of RTPP Act-2012 & Rule-2013 along with Bid document, should be signed by the participating bidders before uploading the tender document otherwise the Bid of the bidder will be rejected.

This will be enforced with immediate effect.

  
Director Engineering-I  
JDA, Jaipur

Copy to:-

1. Director (Engineering-I/II/III/IV), JDA, Jaipur.
2. Director (Finance), JDA, Jaipur.
3. C.F. JDA, Jaipur.
4. All Additional Chief Engineers, JDA, Jaipur.
5. All Superintending Engineers, JDA, Jaipur.
6. All Executive Engineers, JDA, Jaipur for include this in every bid instead of previous condition.
7. O.S.D. (RM)/A.D.R. , JDA, Jaipur.
8. Sr. Horticulture, JDA, Jaipur.
9. Sr. A.O., JDA, Jaipur.

  
Director Engineering-I  
JDA, Jaipur

C:\Users\Admin\Desktop\Office Order Letter Head-English UO Note 2022.docx

Ram Kishor Vyas Bhawan, Indira Circle, Jawahar Lal Nehru Marg, Jaipur-302004  
Direct Line- (+91-141-2563234) : EPABX - +91-141-2569696 Extn : (7203) : Fax - +91-141-2574555

Scanned with CamScanner

## SPECIAL CONDITIONS

1. If there is any typographical error or otherwise in the 'G' Schedule the rates given in the relevant BSR on which schedule 'G' has been prepared, shall prevail.
2. The contractor shall follow the contractor labour regulation and abolition Act 1970 & Rule 1971.
3. The JDA shall have right to cause on audit and technical examination of the work and the final bills of the contractor including all supporting vouchers, abstract etc. to be made within two years after payment of the final bills and if as a result such audit any amount is found to have been over paid/excess in respect of any work done by the contractor under the contract or any work claimed by him to have been done under this contract and found not to have been executed the contractor shall be liable to refund such amount and it shall be lawful ;for the JDA to recover such sum from him in ;the manner prescribed in special condition no. 8 or any other manner legally permissible and if it is found that the contractor was paid less then that was due to him under the contract in respect of any work executed by him under it, the amount of such under payment shall be paid by the JDA to the contractor.
4. Tax exemption/ Tax liabilities if any shall be applicable as per prevailing government rule and bidder has to consider this while quoting the rates.
5. The contractor shall not work after the sunset and before sunrise without specific permission of the authority Engineer.
6. Whenever any claim against the contractor for the payment of a sum of money arises out or under the contracts, the JDA shall be entered to recover the sum by appropriating in part or whole of the security deposit of the contractor. In the event of the security being insufficient or if no security has been taken from the contractor then the balance of the total sum recoverable as the case may shall be deducted from any sum then due or which a any time there contract with the JDA should this sum be sufficient to recover the full amount recoverable, the contractor shall pay to JDA on demand the balance remaining due. The JDA shall further have the right to effect such recoveries under P.D.R. Act.
7. The rate quoted by the contractor shall remain valid for a period of 120 days from the date of opening of the tenders.
8. By submission of this tender the contractor agree to abide with all printed conditions provided in the PWD manual from 64 (Chapter 3-para 36) and subsequent modification.
9. No conditions are to be added by the contractor and conditional tender is liable to be rejected.
10. All transaction in the execution of this work and this tender will be liable to GST & other taxes levied by GOR & GOI.
11. If any Bid withdraws his Bid prior to expiry of said validity period given at S.No. 7 or mutually extended prior or makes modifications in the rates, terms and conditions of the tender within the said period which are not acceptable to the department or fails to commence the work in the specified period, fails to execute the agreement and fails to furnish performance guarantee the department shall without prejudice to any, other right or remedy, be at liberty to forfeit the amount of earnest money given in any form absolutely. If any contractor, who having submitted a Bid does not execute the agreement or start the work or dose not complete the work and the work has to be put to re-bidding, he shall stand debarred from participating in bidding in JDA for Six Months in addition to forfeiture of Earnest Money / Security Deposit /Performance Guarantee and other action under agreement
12. Rules regarding enlistment of contractors provide that work upto five times limit for which they are qualified for tendering can be allotted to them. Therefore, before tender the contractors will keep this in mind, and submit the details of work. Bids with incomplete or incorrect information are liable to be rejected.
13. Any material not conforming to the specifications collected at site shall have to be removed by the contractor within a period of 3 days of the instructions, issued by the Engineer-Incharge in writing. Failing which, such material shall be removed by the Engineer-Incharge at risk and the contractor after expiry of 3 days period.
14. The material collected at site and paid provisionally shall remain under the watch and ward of the contractor till it is consumed, fully on the work.
15. The rates provided in Bid documents are inclusive of all Taxes, royalty.
16. No extra lead of earth/material shall be paid over and above as specified in 'G' schedule. Source/borrow pit area for earth shall have to be arranged by the Contractor at his own cost.
17. Undersigned has full right to reject any or all Bids without given any reasons.


18. Mortar of Masonry work and lean concrete will be permitted mixer with hopper.
19. As per Supreme Court decision "All contracts with Governments shall require registration of workers under the building and other construction workers (Regulation of Employment and Conditions of Service) Act, 1996 and extension of benefits to such workers under the act."
20. The Bidder are required to submit copy of their enlistment as contractor.
21. Conditions of RPWA-100 will be mandatory & acceptable to the contractor.
22. Any Bid received with unattested cutting/overwriting in rates shall be rejected and such bidder will be debarred from Bidding for three months in JDA.
23. All the provisions of THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT, 2012 and Rules, 2013 will be applicable. If there is any contradictions in existing special conditions and provisions of THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT, 2012 and RULES, 2013 shall be applicable.
24. Time period of work can be increased as per RTPP Rules.
25. **In case of single bid system Annexure "B" enclosed by the bidder regarding qualification of RTPP Act 2012 & Rule 2013 along with bid document, should be signed by the participating bidder before uploading the tender document otherwise the bid of the bidder will be rejected.**
26. **After dated 31.12.2022 contractor cannot participate in bid without Review Registration.**

Signature of Contractor  
with full address & Mobile No.

Executive Engineer (PHE-I)  
JDA, Jaipur

**ANNEXURE- I**

[Reference Clause 3(i)]



To be given on Non-Judicial stamp  
Paper of Rs. 10/- only,

**AFFIDAVIT**

I/We..... Proprietor/ Partner/ Authorized signatory of M/s ..... under take the oath that the information furnished by me/us in schedule I to VII of the assessment Bid for ..... is correct to the best of my/our knowledge and nothing has been concealed by me. I acknowledge that if in future any information furnished by me is found incorrect I will be solely responsible and shall be punished as per the law and also any benefits in any form obtained by me shall be recoverable.

.....  
Proprietor/ Partner/ Authorized signatory  
M/s .....  
.....

**Note:-**

**The applicant has to enclose a self attested photo identity card with the above affidavit.**

**Annexure-2A****Specified Bank Guarantee Performa for Bid Security****Section - 6****Form of (Bank Guarantee) -En cashable at the branch of the bank in Jaipur City.**

To  
Secretary,  
Jaipur Development Authority,  
Jaipur

Sub:

Bank Guarantee No. \_\_\_\_\_ dated \_\_\_\_\_ for [amount of Security in figures] [in words] on behalf of \_\_\_\_\_ [Name of the Bidder] against Bid Security for the work of **“Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.”** WHEREAS, \_\_\_\_\_ [name of Bidder with address] (hereinafter called **“the Bidder”**) has submitted his Bid dated ..... for the work of **“Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.”** (here in after called **“ the Bid ”**).

KNOW ALL PEOPLE by these presents that we \_\_\_\_\_ (Name of Bank) of having our registered office at \_\_\_\_\_ [name of country] having our registered office at \_\_\_\_\_ (hereinafter called **“the Bank”**) are bound unto Secretary, Jaipur Development Authority. (Hereinafter called **“the Employer”**) in the sum of Rupees \_\_\_\_\_ **[Amount of Security in figures]** \_\_\_\_\_ (in words) only for which payment will and truly to be made to the said Employer, the Bank binds itself, its successors, and assigns by these presents. That on demand of JDA , this Bank Guarantee is cashable at the following branch in Jaipur City.

1. Name of Bank:

2. Name of the branch with branch code:

3. Address:

4. E-Mail Id:

5. Telephone No.

6. Fax No.:

SEALED with the Common Seal of the said Bank this \_\_\_\_\_ day of \_\_\_\_\_ of 20\_\_\_\_.

THE CONDITIONS of this obligation are:

- (1) if the Bidder withdraws his Bid during the period of Bid validity specified in the Form of Bid;
- (2) if the Bidder refuses to accept the correction of errors in his bid;
- (3) If the Bidder, having been notified of the acceptance of his Bid by the Employer during the period of Bid validity;

- (a) fails or refuses to execute the Form of Agreement in accordance with the Instructions to Bidders, or
- (b) fails or refuses to furnish the Performance Security, in accordance with the Instructions to Bidders;

We undertake to pay to the Employer up to the above amount upon receipt of his first written demand, without the Employer having to substantiate his demand, provided that in his demand the Employer will note that the amount claimed by him is due to him owing to the occurrence of one or more of the above conditions, specifying the occurred condition or conditions.

This Guarantee will remain in force up to and including the date 30 days after the date of expiration of the Bid Validity, as stated in the Instructions to Bidders, or any such extension thereto as may be agreed by the Bidder, a notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank no later than the above date.

The amount covered under the above Bank Guarantee shall be automatically credited in the accounts of JDA in ICICI Bank, JDA Campus, Jaipur through **ISFC code No ICICI 0006754. Bank Account No. 675401700518** on the date of expiry or its validity, unless the agencies get it re-validated well before its expiry date or produce NOC from JDA in writing for its release.

Date \_\_\_\_\_ Signature of the Bank \_\_\_\_\_

Witness \_\_\_\_\_ Seal \_\_\_\_\_

[Signature, Name, and Address]

**[Note: To be furnished on appropriate non-judicial stamps & should be valid for the next 7 months from the bid opening date]**

**Annexure-2B**

**Specified Bank Guarantee Performa for Performance Security**

**Section - 6**

Form of (Bank Guarantee) -En cashable at the branch of the bank in Jaipur City.

To  
Secretary,  
Jaipur Development Authority,  
Jaipur  
Sub:

Bank Guarantee No. \_\_\_\_\_ dated \_\_\_\_\_ for [amount of Security in figures] [in words] on behalf of \_\_\_\_\_ [Name of the Bidder] against Performance Security for the work of **“Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.”** WHEREAS, \_\_\_\_\_ [name of Bidder with address] (hereinafter called **“the Bidder”**) has submitted his Bid dated ..... for the work of **“Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.”** (herein after called **“ the Bid ”**).

KNOW ALL PEOPLE by these presents that we \_\_\_\_\_  
\_\_\_\_\_ (Name of Bank) of having our registered office at \_\_\_\_\_ [name of country] having our registered office at \_\_\_\_\_ (hereinafter called **“the Bank”**) are bound unto Secretary, Jaipur Development Authority. (Hereinafter called **“the Employer”**) in the sum of Rupees \_\_\_\_\_ **[Amount of Security in figures]** \_\_\_\_\_ (in words) only for which payment will and truly to be made to the said Employer, the Bank binds itself, its successors, and assigns by these presents.

That on demand of JDA, this Bank Guarantee is cashable at the following branch in Jaipur City.

- 1. Name of Bank:
- 2. Name of the branch with branch code:
- 3. Address:
- 4. E-Mail Id:
- 5. Telephone No.
- 6. Fax No.:

SEALED with the Common Seal of the said Bank this \_\_\_\_\_ day of \_\_\_\_\_ of 20\_\_\_\_.

We undertake to pay to the Employer up to the above amount upon receipt of his first written demand within valid period of this guarantee.

This Guarantee will remain in force up to and including the date 30 days after the date of expiration of the Bid Validity, as stated in the Instructions to Bidders, or any such extension thereto as may be agreed by the Bidder, a notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank no later than the above date.

The amount covered under the above Bank Guarantee shall be automatically credited to the accounts of JDA in ICICI Bank, JDA Campus, Jaipur through **ISFC code No ICICI0006754. Bank Account No. 675401700518** on the date of expiry or its validity, unless the agencies get it re-validated well before its expiry date or produce NOC from JDA in writing for its release.

Date \_\_\_\_\_ Signature of the Bank \_\_\_\_\_

Witness \_\_\_\_\_ Seal \_\_\_\_\_

[Signature, Name and Address]

[Note: To be furnished on appropriate non-judicial stamps.]

## **PAYMENT MECHANISM FOR PARTICIPATING IN TENDER**

Jaipur Development Authority has decided to receive Earnest Money Deposit (EMD) (Bid Security) Tender fee online through JDA portal. The bid security options available in tender for participants are as mentioned below :

### **A. Payment Options:**

#### **Option-1: Bank Guarantee (BG), against EMD / Bid Security**

Bidder may opt Bank Guarantee (BG) against EMD (Bid Security) for which bidder requires to prepare BG before applying in the tender. The details of BG requires to be fed on JDA portal before paying balance amount (Tender Fee). This amount will be paid through **Payment Gateway only**, option to make balance payment through EFT (RTGS/NEFT) will not be available

If bidder does not opt for BG against EMD, options of making complete payment through Payment Gateway or through EFT (NEFT/RTGS) will be available

#### **Option-2: Electronic Fund Transfer (EFT: NEFT/RTGS)**

If the bidder selects payment mode as EFT (NEFT/RTGS) **"Paying Slip for EFT (NEFT/RTGS)"** will be generated by the system for the complete amount. The payment can be made from **any Bank any Branch** using this Paying Slip through NEFT/RTGS (Claim against payment made through EFT in any other JDA bank account will not be acceptable and bidder stands disqualified from participation in the bid applied for). After successful transaction through NEFT/RTGS, as per the standard procedures it may take 4 to 24 hours in process of confirmation of EFT through Auto-Process depending on the time of EFT done. Therefore, option to make payment through EFT (NEFT/RTGS) will be available till 2 days prior to closing date of bid participation.

#### **Option-3: Payment Gateway (Aggregator)**

The facility to make payment through Debit Card, Credit Card, Net banking etc., will be available. User can use this facility from **anywhere any time** till the closing date & time of bid participation

### **B. Bid Participation Receipt**

After confirming payment, the bidder will get Bid Participation Receipt on the basis of which user will get the payment details along with other details for bidding on e-Procurement portal of GOR

- In case of BG as the remaining payment will be done through Payment Gateway, on successful transaction the **"Bid Participation Receipt"** will be generated on real time basis
- In case complete payment is done through Payment Gateway, on successful transaction the **"Bid Participation Receipt"** will be generated on real time basis
- In case complete payment is done through EFT (NEFT/RTGS), on confirmation of payment from ICICI Bank (Auto Process) **"Bid Participation Receipt"** will be available on Login of Bidder on JDA portal.

**Executive Engineer (PHE-I)  
JDA, Jaipur**

# Section A6

## Drawings

# **Section A-7**

## **Bill of Quantities**

## JAIPUR DEVELOPMENT AUTHORITY

**Name of work: Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.**

### H-Schedule

#### Part- A (Non BSR Items)

S.No.	Particular	Qty	Unit	Rate	Total Amount (In Rs.)
1	Supply & fixing of submersible sewerage mud pump having discharge 100 to 150 M3/hr and head 5-15 mtr. including G.I. fitting (G.I. flange, G.I. pipe etc.) and 50 mtr armoured cable (10Sq.mm,4 core) (Make KSB, Kirlosker or equivalent ISI mark).	2.00	Each		
2	Providing, lowering, laying in trenches, aligning, fixing in position and jointing Ductile Iron (DI) ISI marked K-7 grade S&S pipes as per IS:8329-2000 (amended up to date), with internal High Alumina Cement (HAC) mortar lining for gravity sewer network with rubber ring (EPDM) joints as per IS: 5382-1985 (excluding special accessories) complete including all material, labour, hydraulic testing and commissioning as per technical specifications and as per direction of Engineer. Note : E/w to be measured and paid separately.				
2.01	150 mm	700.00	metre		
3	Providing, lowering, laying, aligning, fixing in position at and jointing at all level/depths S&S standard specials with rubber ring (EPDM/SBR) joints as per IS: 5382-1985 such as tees, bends, tapers, caps etc. within trenches in DI pipe line complete including all material, labour, testing and commissioning along with pipe line as per technical specifications and as per direction of Engineer. Specials S&S DI K-12				
3.01	Upto 300mm dia	400.00	kg		
				<b>Total Part-A = Rs.</b>	

Executive Engineer (PHE-I)  
JDA, Jaipur

## JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

**Name of work:- Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.**

### Estimate

- - - - -

**Part B: P/L/J of 150 mm Dia DI Pipe line**

**Based on JDA PHE BSR-2016**

S. No.	PARTICULARS	Qty.	Unit	Rate	AMOUNT (in Rs.)
1	Providing, fabricating and installing MS specials including rolling, cutting, welding in different shape and size. <b>(D-547 dt. 20.12.2011)</b>	1000.00	Kg.	80.00	80000.00
2	Supply and fixing & testing of feeder type penal board suitable for upto 15 HP electric motor having star delta/ DOL starter ( L&T /BCH), MCB 32 amp. (havals /L&T), capacitor 3 KVR (L&T/Havals), Single phase priventor (L&T/havals), indicating lamp RYB , Amp. Meter ( 0 to 30Amp) , Volt Meter with selector switch ( 0 to 500 V) size 100 mm, kit kat fuse unit 100 amp,backlite sheet for fixing of 3 phase electric meter of JVVNL electric feeder penal approved as per design and specification mounted on angle iron fram and fixed plain on plain cement concrete plateform, size of feeder penal box 900X 450X1200mm (D-547 dt. 20.12.2011)				
2.01	Star Delta above 5 HP to 15 HP	1.00	Each	24915.00	24915.00

3	P/Laying P.V.C. / XLPE insulated & P.V.C. sheathed cable of 1.1 KV grade with aluminium conductor of IS:1554 P-I / IS : 7098 P - I of Group 1 of approved make in ground as per IS:1255 including excavation of 30cmx75cm size trench, 25 cm thick under layer of sand, 11nd class bricks covering, refilling earth, compaction of earth, making necessary connection, testing etc. as required of size. 10.0 Sq.mm 4 core				
3.01	Complete Rate Armoured	50.00	Mtr.	136.00	6800.00
4	P/Laying ISI marked P.V.C. insulated submersible cable confirming to IS:694 with flexible copper conductor including making connection etc. as required. 4.0 Sq.mm 3 core flat / Round				
4.01	Complete Rate Group 1	50.00	Mtr.	102.40	5120.00
5.00	Earth work in excavation by mechanical means (Hydraulic Excavator )/ manual means in foundation trenches or drains (not exceeding 1.5 m in width or 10 sum on plan) including dressing of sides and ramming of bottoms, lift upto 1.5 m, including taking out the excavated soil and depositing and refilling of jhiri with watering & ramming and disposal of surplus excavated soil as directed with in a lead of 50 meter. All kinds of soils	700.00	Cum	111.60	78120.00
<b>Total</b>				<b>Rs.</b>	<b>194955.00</b>

Executive Engineer (PHE-I)  
JDA, Jaipur

I/We Quote as ..... % Above/ Below the schedule " G "

(In Words.....)'

Signature of Contractor  
With full Address & Mobile No.

**JAIPUR DEVELOPMENT AUTHORITY**

**Name of work: Work of connection of sewerage outlet at Felicity Roongtas Aventura Residents with existing trunk line through pumping method including O&M for 1 year, Jagatpura PHE-I, JDA, Jaipur.**

**H-Schedule****Part- C (O&M)**

<b>S.No.</b>	<b>Particular</b>	<b>Qty</b>	<b>Unit</b>	<b>Rate</b>	<b>Total Amount (In Rs.)</b>
1	Operation and maintenance of Submersible sewerage mud pump and DI line for sewerage work at Felicity Roongtas Aventura resident (except Electricity Bill)	12.00	Per Month		
				<b>Total Part-A = Rs.</b>	

Executive Engineer (PHE-I)  
JDA, Jaipur