



जयपुर विकास प्राधिकरण, जयपुर

www.jda.urban.rajasthan.gov.in

NO. JDA/EE (PHE-I)/2025/D-

DATE:

CORRIGENDUM TO NIT NO. 16/2025-26

(a) The following corrigendum have been made in NIB No. EE (PHE-I)/ 16/2025-26 dated 08.11.2025

1. In clause 2.3 “Detailed SCOPE OF WORK” 2.3.1 “Design Basis” point no. 10 Soil Bearing Capacity consider as 10 tonne/m² at 1.5 m below NGL (**subjected to maximum 10tonne/m² for entire plant**). The Contractor shall carry our Geotechnical Investigation work at the proposed location of treatment plant. The no. of bore holes to be taken, depth of boring etc. shall be decided in consultation with the Engineer In-charge. The Contractor has to provide the hard and soft copies of the test reports. If the bearing capacity of the soil found lower than that is mentioned in the soil report provided with the Tender document, the **lower of the two values shall be considered for design.**
2. In clause 1.16.5 “The comparison of the bid values shall be based on THE EVALUATED PRICE OF THE BIDDER. The evaluated price shall include Capital Cost (includes 3 months trial run followed by 1 year O&M) + 10 years O&M Cost + (1+10) years Electricity Cost”. Now electricity cost should not be added for financial bid as it is fixed power. So the evaluated price shall include **Capital Cost (includes 3 months trial run followed by 1 year O&M) + 10 years O&M Cost** only.

The all conditions of the tender will be as per Pre-uploaded tender document.

Executive Engineer (PHE-I)

JDA, Jaipur

Signature valid

Digitally signed by Dileep Lamba
Designation: Executive Engineer
Date: 2025.12.02 12:45:19 IST
Reason: Approved



राम किशोर व्यास भवन, इन्दिरा सर्किल, जवाहर लाल नेहरू मार्ग, जयपुर – 302004

दूरभाष : +91-141-2563234: ईपीबीएक्स – +91-141-2569696 : एक्सटे.: 5004 :

फैक्स +91-141-2574555

RajKaj Ref No.:
19148481